



5.10. Example of Design Problems for Trufin in Boiling Heat Transfer

5.10.1. Design Example - Kettle Reboiler

Size a kettle reboiler to transfer $43.3(10^6)$ Btu/hr to vaporize a hydrocarbon mixture at 170 psia using steam available at 395°F. The critical pressure of this liquid is 434 psia and it has a boiling range of 60°F. The boiling temperature is 330°F.

Design the reboiler using 3/4-in. OD tubes on 1.125-in square pitch. We will estimate the latent heat as 144 Btu/lb_m and liquid density as 41 lb_m/ft³.

Step 1. Calculate or estimate heating medium, tube wall, and fouling coefficients.

For this example (and in order to compare to a test unit) the steam coefficient is 2000 and the tube wall is 4800. This reboiler was claimed to be clean; hence,

$$R_o = \frac{1}{h_o} + \frac{1}{h_w} + R_f$$

$$R_o = 1/2000 + 1/4800 = 0.000708$$

Step 2. Calculate the mixture correction factor, F_m from eq. 5.38.

$$F_m = \exp(-0.015 \times 60) = 0.41$$

Step 3. Calculate B and $R_o B$ and find q. From eqns. 5.8a, 5.10 and 5.62.

$$A^* = 0.00658(434)^{.69} = 0.435$$

$$F(P)_2 = 1.8 \left(\frac{170}{434} \right)^{.17} = 1.535$$

$$B = [(0.435)(1.535)]^{3.33} = 0.26$$

Correcting B for the mixture, use fig. 5.29 at BR of 60°F,

$$B = 0.26 \times 0.41 = 0.1066$$

hence

$$R_o B = 0.1066 \times 0.000708 = 7.5(10^{-5})$$

At $\Delta T=65$ Figure 5.33 gives $q/B=280,000$ hence

$$q = 0.1066 \times 280,000 = 29,848 \text{ Btu/hr ft}^2$$

Step 4. Calculate single tube maximum q_1 , eq. 5.5



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

$$q_{1\max} = 803(434)(170/434)^{.35} (1 - 170/434)^9 = 160,488 \text{ Btu/hr ft}^2$$

Step 5. Preliminary estimate of bundle size

For a bundle

$$q_b = q_{1\max} \Phi_b$$

where

$$\Phi_b = 2.2(\pi D_B L / A_s).$$

If we approximate

$$\Phi = 2.2\Psi$$

by letting Ψ be (for square pitch)

$$\frac{\pi D_B L}{A_s} = \frac{\pi D_B L}{\frac{\pi D_B^2 L}{4} \times \frac{\pi d_o^2}{p_t^2}} = \frac{4 p_t^2}{\pi D_B d_o}$$

Now let

$$\Phi_b = 2.2 \left(\frac{4 p_t^2}{\pi D_B d_o} \right) = \frac{q_b}{q_{1\max}}$$

$$\therefore D_B = \frac{(2.2)(4) p_t^2 q_{1\max}}{q_b \pi d_o} = \frac{(2.2)(4)(1.125/12)^2 (160,488)}{(29,848)(\pi)(0.75/12)} = 2.118 \text{ ft}$$

As the above approximation ignores the additional effect of circulation on the boiling coefficient, $D_B = 2 \text{ ft}$.

Step 6. Calculate bundle maximum flux, eqn, 5.23

For U-tube on this pitch a total of 180 U-tubes or 360 ends will form a 2 foot diameter.

For one foot of bundle length

$$\Psi = \frac{\pi D_B L}{A_s} = \frac{\pi(2)(1)}{(360)\pi(.75/12)} = 0.0889$$

$$\Phi_b = 2.2\Psi = (2.2)(0.0889) = .1956$$

maximum bundle flux

$$q = \Phi_b q_{1\max}$$



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

$$q = 0.1956 \times 160,488 = 31,392 \text{ Btu/hr ft}^2$$

Step 7 Calculate the bundle heat transfer

For a 2 ft bundle assume $q = 28,600 \text{ Btu/hr ft}^2$ and calculate heat transfer coefficients based on this flux and the values obtained in steps 3 and 5.

From eqn. 5.8 calculate h_{nbl}

$$h_{nbl} = (0.435)(1.535)(28,600)^{0.7} = 878.3 \text{ Btu/hr ft}^2\text{°F}$$

Step 8. Calculate natural convection coefficient, eqn 5.7

We have insufficient information to calculate this coefficient but we will assume it is $40 \text{ Btu/hr ft}^2\text{°F}$.

Step 9. Calculate bundle coefficient, eqn. 5.22

$$h_b = 878.3 \times 0.41 \times 1.5 + 40 = 580.1 \text{ Btu/hr ft}^2\text{°F}$$

$$U = 1/(1/580.1 + 0.000708) = 411.2 \text{ Btu/hr ft}^2\text{°F}$$

$$q = U\Delta T$$

$$q = 411.2 \times 65 = 26,730 \text{ Btu/hr ft}^2\text{°F}$$

The measured coefficient for this reboiler (72) was $440 \text{ Btu/hr ft}^2\text{°F}$ or 7% higher.

Step 10. Check bundle design.

Step 9 heat flux (26,730) is less than the maximum allowed bundle flux of step 6 (31,392) hence OK. Since Φ_b in step 6 is greater than 0.1 no vapor lanes or larger pitches are required; therefore, bundle is OK.

Step 11. Size the bundle.

$$\text{Required length} = \frac{43 \times 10^6}{26,730 \times 360 \times 1.963} = 22.8 \text{ ft}$$

This length checks with the test unit length of 23 ft.

Step 12. Check for entrainment.

Number of vapor nozzles per eqn. 5.64

$$N_n = \frac{23}{5 \times 2} = 2.3 \text{ round up to } 3$$

Vapor per nozzle



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

$$W_n = \frac{43,300,000}{144 \times 3} = 100,231 \text{ lb}_m/\text{hr}$$

Entrainment limit, eq. 5.63

$$VL = 2290 \times 1.725 \left[\frac{5}{41 - 1.725} \right]^{.5} = 1409 \text{ lb}_m/\text{hr ft}^3$$

(Note dynes/cm = [lb_f/ft] / 6.86 × 10⁻⁵)

Therefore the vapor volume/nozzle = 100,231/1409 = 71.1 ft³. If the shell is 25 ft long then the cross section area for vapor above the liquid level is 71.1/8.33 = 8.537 ft². The shell diameter is then determined from tables of segmental areas; however, for first approximation assume a liquid level at the center line then

$$D_s = (2 \times 8.537 \times 4/\pi)^{0.5} = 4.66 \text{ ft}$$

This is a large shell compared to the bundle diameter; therefore, consider the use of entrainment separation devices.

5.10.2. In-Tube Thermosyphon - Example Problem

Size a vertical thermosyphon vaporizer to transfer 1,483,000 Btu/hr to an organic liquid with the following properties: boiling point @ 17 psia = 185.5°F, $c_{p\ell} = 0.45$, latent heat = 154.8 Btu/lb, $\mu_\ell = 0.96$ lb/ft. hr, $\mu_v = 0.0208$ lb/ft. hr, $k = 0.086$ Btu/hr ft. °F, and densities lb/ft³ liquid = 44.8, vapor = 0.181, $P_c = 593.9$ psia. Heating medium is steam at 217.4°F. Use 1-in. 12 BWG carbon steel tubes 8 ft. long. For this problem assumes no other fouling is present. This example is based on a test by Johnson (73). Boiling point elevation for 8 ft static head is 9°F. The heat source is steam condensing on the outside of the tubes with a coefficient of 1000.

Step 1.

Calculate R_o

$$R_w = \frac{(0.109/12)(1)}{(30)(.891)} = 0.00035$$

$$R_o = \frac{1}{1000} + 0.00034 = 0.00135$$

Step 2

Calculate the maximum limiting flux using eqn. 5.37

$$q_{\max} = 16066 \left[\frac{(.782/12)^2}{8} \right]^{.35} (593.9)^{.61} \left(\frac{17}{593.9} \right)^{.25} (1 - .0286) = 22,548 \text{ Btu/hr ft}^2$$



WOLVERINE TUBE HEAT TRANSFER DATA BOOK




Fig. 5.37 Fin Efficiency for Boiling on Fins



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

This is a high flux and would require a $22548 \times 0.00135 = 30.4$ temperature drop across the steam tube wall. As only $217.4 - 185.5 = 31.9^\circ\text{F}$ is available it is obvious the operation is well below the maximum.

Step 3. Determining a boiling flux

Calculate a nucleate boiling flux using Figure 5.33

Here

$$B = [0.00658(593.9)^{.69}(1.8)(17 / 593.9)^{.17}]^{3.33} = 0.1214 \quad (5.62)$$

hence

$$R_o B = 0.00135 \times 0.1214 = 0.00016$$

For $\Delta T = 31.9^\circ$ from the figure we should calculate

$$q = 44,000 \times 0.1214 = 5342 \text{ Btu/hr ft}^2$$

This flux represents only the nucleate boiling coefficient and this is a lower limit. To include a two-phase convective effect assume a 50% increase in the boiling side. Hence, from the above flux and ΔT get U (167.4), subtract the R_o (.00135) resistances to get the boiling coefficient (216.4) increase the nucleate coefficient by the assumed ratio (= 324.6), then recalculate the new overall coefficient (225.7) and heat flux (7200).

Step 4. Determining the recirculation rate.

$$\text{Vapor per tube} = 8 \times 0.2618 \times 7200 / 154.8 = 97.4 \text{ lb/hr}$$

Now one has to assume the fraction vaporized. We will short cut this trial and error by assuming the experimental value of 9%. Therefore, the feed rate/tube = $97.4 / .09 = 1082 \text{ lb/hr}$.

Step 5. Calculate basic values needed to check pressure drop, circulation rate, and preheat zone.

$$G_t = 1082 / (\pi \times (.782)^2 / [4 \times 1441]) = 324,404 \text{ lb/ft}^2 \text{ hr}$$

$$V = 324,404 / (3600 \times 44.8) = 2.01 \text{ ft/sec}$$

$$Re = .782 \times 324,404 / (12 \times .96) = 22,021$$

From friction factor charts $f = 0.0075$

Hence in the liquid zone the head loss per foot of tube is by eqn. 5.51

$$\Delta H = (4 \times .0075 \times 12 / .782) \times 2.01^2 / 64.4 = 0.029 \text{ ft/ft}$$

Using an average vaporization of $9/2 = 4.5\%$ we can calculate X_{tt} , (eqn. 5.29)

$$X_{tt} = \left(\frac{1 - .045}{0.045} \right) \left(\frac{0.181}{44.8} \right)^{0.57} \left(\frac{0.96}{0.0208} \right)^{0.11} = 1.398$$



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

Next get $\Phi_{\ell tt}^2$ (eqn. 5.55)

$$\Phi_{\ell tt}^2 = 1 + 20 / 1.398 + (1 / 1.398)^2 = 15.82$$

The two-phase AH based on average liquid content of 0.955 is

$$\Delta H = 15.82 \times .029 (0.955)^2 = 0.42 \text{ ft/ft}$$

The two-phase density due to slip is (eqn. 5.48 and 5.49)

$$R_v = 1 - 1 / \sqrt{15.82} = 0.749$$

$$\rho_{tp} = (.749 \times .181) + [(1 - .749) \times 44.8] = 11.38 \text{ lb/ft}^3$$

The boiling zone static head loss is

$$\Delta H = 11.38 / 44.8 = 0.254 \text{ ft/ft}$$

Using eqn. 5.50 for $P\Delta_m$

$$G_t = 324,404 / 3600 = 90.11 \text{ lb/ft}^2 \text{ sec}$$

$$\Delta P_m = \frac{(90.11)^2}{32.2} \left(\frac{(1 - .09)^2}{44.8 \times .251} + \frac{(.09)^2}{.181 \times .749} \right) = 33.64 \text{ lb/ft}^2 = 0.751 \text{ ft}$$

Heat transfer in preheat zone; eqn. 5.25

$$h = 0.023(22021)^{.8} \left(\frac{.45 \times .96}{.086} \right)^{1/3} \left(\frac{.086 \times 12 \times .782}{.782} \right) = 121.1 \text{ Btu/hr ft}^2 \text{ } ^\circ\text{F on outside area}$$

Therefore

$$U = 1 / (1 / 121.1 + .00135) = 104.1 \text{ Btu/hr ft}^2 \text{ } ^\circ\text{F}$$

Using a $\Delta T = 31^\circ\text{F}$ the temperature rise in preheat zone is

$$\frac{104.1 \times .2618 \times 31}{1012 \times .45} = 1.86 \text{ } ^\circ\text{F/ft}$$

Step 6. Estimating preheat and boiling lengths.

Assume preheat zone = 3 ft

Friction loss in preheat zone = $3 \times .029 = 0.087 \text{ ft}$



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

Effective submergence at this point = total head (8) – friction loss (.087) – preheat zone (3) = 4.91 ft liquid

which is equivalent to a boiling point elevation of

$$(4.91/8) \times 9 = 5.53 \text{ }^{\circ}\text{F}$$

Length required for this temperature rise is $5.53/1.74 = 3.18$ ft. Close enough.

Check on circulation and pressure drops

Available head = 8 ft liquid neglecting liquid line losses

Overall momentum loss = .751 ft

Friction losses

boiling zone $5 \times .42$	2.100
preheat zone	.087

Static heads

boiling zone $5 \times .254$	1.270
preheat zone	<u>3.000</u>
	7.21ft

Considering there is some losses in the liquid recirculating line the above agreement is close enough.

Step 7. Calculate heat transfer in boiling zone

From eqn. 5.8

$$h_{nbl} = 0.00658(593.9)^{.69}(7200)^{.7}[1.8(17 / 593.9)]^{.17}$$

$$= 266.2 \times .782 / 1 = 208.1 \text{ Btu/hr ft}^2 \text{ }^{\circ}\text{F on OD area}$$

From eqn. 5.28

$$F_{ch} = 2.35 \left(\frac{1}{1.398} + 0.213 \right)^{0.73} = 2.226$$

Determines from eqn. 5.31

$$Re_{tp} = 22,021 \times 2.226^{1.25} = 59,874$$

$$s = 1 / \{1 + [2.53(10^{-6}) \times (59,874)^{1.17}]\} = 0.504$$

From eqn. 5.27

$$h_{cb} = 121.1 \times 2.226 = 269.6 \text{ Btu/hr ft}^2 \text{ }^{\circ}\text{F on an outside area basis}$$

From eqn. 5.26



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

$$h_b = (.504)(208.1) + 268.6 = 374.5$$

Adding the steam and wall resistance to obtain U for the boiling section

$$U = 1 / [(1 / 374.5) + 0.00135] = 249$$

Step 8. Calculate average coefficient for tube and area

An average coefficient for the preheat and boiling zone is

$$U_{av} = (3 \times 104.1 + 5 \times 249.0) / 8 = 194.5 \text{ Btu/hr ft}^2 \text{ } ^\circ\text{F}$$

Required area = $1,483,000 / 194.5 \times 31.9 = 239 \text{ ft}^2$ vs. 201 ft^2 in the test vaporizer.

Thus, this simplified calculation came within 19% of predicting the test results which is acceptable. In design case after calculating the required area (239 ft^2) a safety factor should be added to allow for the error spread in all the involved equations. Also fouling should be considered and should be included in the term R_o term. We did not include fouling in this example since we were trying to compare the calculation method with data obtained in a clean vaporizer.

5.10.3. Boiling Outside Trufin Tubes - Example Problem

To illustrate the value of and methods of calculation for Trufin tubes in boiling, a comparison of the performance of a plain surface and finned surface tube will be made. The plain tube is 0.75 and o.d., 18 B.W.G. wall and 90/10 Cu-Ni. The Trufin is Wolverine Cat. No. 65-265049-53. This tube has a surface area of $0.640 \text{ ft}^2/\text{ft}$ with an A_o/A_i ratio of 4.61, a fin height of 0.057 and width of 0.012 inches. There are 26 fins per inch. The tubes are heated with steam having a coefficient of 2000. A pure hydrocarbon having a critical pressure of 489 psia will be boiled at 100 psia with an overall temperature difference of 10°F . The bundle factor, F_b , is 1.5 and the surface factor, F_s , for this temperature is 1.0 for the plain tube and 1.5 for the Trufin tube.

Evaluation of the Plain Tube Performance

1. Calculate R_o .
where R_o = wall resistance + tube-side resistance

$$R_{\text{wall}} = \frac{(.049 / 12)(.75)}{29(.652)} = .000162$$

$$h_{\text{wall}} = 6174$$

$$R_o = \frac{1}{6174} + \frac{.75}{2000(.652)} = .00074$$

2. Calculate the single tube boiling coefficient using eq. 5.32

$$h_{\text{nbl}} = (5.43)(10^{-8})(489)^{2.3} [1.8(100 / 489)^{0.17}]^{3.33} \Delta T^{2.3} = 0.24 \Delta T^{2.3}$$



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

assuming the maximum possible ΔT of 10°F

$$h_{nbl} = (0.24)(10)^{2.3} = 47.9$$

3. Calculate the bundle boiling coefficient, overall U , and the heat flux then check the assumed ΔT . Assume a natural convection coefficient, $h_{nv} = 40$, and using the bundle factor of 1.5 in eq. 5.22.

$$h_b = (47.9)(1.5) + 40 = 111.8$$

$$U_0 = 1 / (1 / 111.8 + .00074) = 103.2$$

the available boiling ΔT is then

$$\Delta T_b = 10 - (10)(.00074)(103.2) = 9.2^\circ\text{F}$$

This is not close enough to the assumed value of 10 so repeat steps 2 and 3.

- 2' Assume $\Delta T_b = 9.2$

$$h_{nbl} = (0.24)(9.2)^{2.33} = 42.25$$

- 3' $h_b = (42.25)(1.5) + 40 = 103.4$

$$U_0 = 1 / [(1 / 103.4) + .00074] = 96$$

4. Calculate available boiling ΔT .

$$\Delta T_b = 10 - (10)(.00074)(96) = 9.29^\circ\text{F}$$

$$q = U\Delta T = (96)(10) = 960 \text{ Btu/hr ft}^2 \text{ (outside area)}$$

Evaluation of the Trufin Tube Performance

1. Calculate R_o

The inside area basis will be used

$$R_{\text{wall}} = \frac{(.049 / 12)(.53)}{(29)(.579)} = 0.00013$$

$$R_o \text{ (wall + steam resistance)} = 0.00013 + 1/2000 = 0.00063$$

2. Calculate the boiling coefficient using eq. 5.32 with a surface factor of 1.5

$$h_{nbl} = (1.5)(0.24) \Delta T^{2.33} = 0.36 \Delta T^{2.33}$$

assume a boiling ΔT of 8°F

$$h_{nbl} = (0.36)(8)^{2.33} = 45.8$$



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

using eq. 5.22 with $F_b = 1.5$ and $h_c = 30$

$$h_b = (45.8)(1.5) + 30 = 98.7$$

3. Adjust for fin efficiency.

Figure 5.37 is used. This was derived for the case boiling liquids on fins where $h = b\Delta T^2$.

using the assumed ΔT of 8 and $h_b = 98.7$

$$b = 98.7 / (8)^2 = 1.542$$

the abscissa for fig 5.37 is then

$$\frac{.057}{12} \sqrt{\frac{(2)(1.542)}{(29)(0.018/12)}} \times 8 = .320$$

an efficiency of 87% is read and

$$h_b = (98.7)(.87) = 85.9 \text{ on an outside area basis}$$

On an inside area basis;

$$h_b (85.9)(4.61) = 396$$

$$U = 1 / (1/396 + .00063) = 317$$

$$q = U\Delta T = (317)(10) = 3170 \text{ Btu/hr ft}^2 \text{ (inside basis)}$$

Check assumed value of boiling ΔT of 8°F.

$$\Delta T (\text{wall} + \text{steam}) = (0.00063)(3170) = 2.0$$

$$\Delta T_{\text{boiling}} = 10 - 2 = 8^\circ\text{F}$$

This checks with assumed value. If not then, repeat steps 2 and 3 with a new value.

Comparison of Performance

Since the area per foot of the two tubes are different, comparison will be made on a per foot of length basis.

1. For plain tube

$$q/\text{foot} = (960)(.1963) = 188.5 \text{ Btu/hr-foot length}$$

2. For Trufin

$$q/\text{foot} = (3170)(.640/4.61) = 440.1 \text{ Btu/hr-foot length}$$

Therefore the performance ratio of Trufin to plain is: $440.1 / 188.5 = 2.3$



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

Table 5.1

Simple dimensional equation for nucleate pooling boiling heat transfer (after Borishanski)

Liquid	Pressure range atm.	A* from exp	A* Eqn 5.9	Critical pressure atm.	No. in Fig 5.18
Water	1 – 70	1.61	1.66	216.9	1
Water	1 – 196	1.58	1.66	216.9	2
Water	0.09 – 1	2.28	1.66	216.9	3
Water	1 – 72.5	1.76	1.66	216.9	4
Water	1 – 170	1.75	1.66	216.9	5
Water	1 – 5.25	2.26	1.66	216.9	6
Pentane	1 – 28.6	.429	.449	32.8	7
Heptane (80%)	0.45 – 14.8	.464	.381	25.9	8
n-heptane	0.45 – 14.8	.642	.381	25.9	9
Benzene	1 – 44.4	.417	.588	48.1	11
Benzene	0.9 – 20.7	.520	.583	48.1	--
Diphenyl	0.9 – 8	.441	.425	30.4	--
Methanol	0.08 – 1.39	(.272)	.815	78.0	13
Ethanol	1 – 20.7	.720	.701	62.6	10
Ethanol	1 – 59	1.019	.701	62.6	12
Butanol	0.17 – 1.38	(.173)	.547	43.8	14
R11	1 – 3	.768 [.681]	.539	42.9	--
R12	1 – 4.9	.956	.516	40.3	15
R12	6 – 40.5	1.37 [1.01]	.516	40.3	--
R13	2.8 – 10.5	.705	.496	37.9	--
R13B1	17 – 39	1.744 [.976]	.508	39.1	--
R22	0.4 – 2.15	[.941]	.586	48.4	--
R113	1 – 3	.488	.453	33.4	--
R115	8 – 31	1.49 [.934]	.425	30.6	--
RC318	3.6 – 27	1.23 [.984]	.394	27.3	--
Methylene chloride	1 – 4.5	(.752)	.677	59.6	--
Ammonia	1 – 8	1.54	1.039	110.8	--
Methane	1 – 42	1.06	.563	45.6	--

Values shown in round brackets () are uncertain.

Values shown in brackets [] relate to the use of Equations 5.11 for F(P).



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

NOMENCLATURE

A^*	Constant defined in equation 5.9.	dimensionless
A_s	Surface area.	ft ²
B	Constant defined in equation 5.62.	dimensionless
BR	Boiling range, dew point-bubble point.	°F
c_p	Specific heat, $c_{p\ell}$ for liquid and c_{pv} for vapor	Btu/lb _m °F
d	Tube diameter, d_o for outside and d_i for inside.	ft.
D_p	Diameter of tube bundle.	ft.
D_s	Shell diameter.	ft.
F_b	Tube bundle correction factor.	dimensionless
F_{cb}	Chen Factor.	dimensionless
F_m	Mixture correction factor.	dimensionless
f	Friction factor.	dimensionless
G	Mass velocity.	lb _m /ft ² hr
G_t	Mass velocity based on total flow.	lb _m /ft ² hr
G_{tmax}	Total mass velocity based on minimum cross flow area.	lb _m /ft ² hr
G_{mm}	Mass velocity at beginning of mist flow.	lb _m /ft ² hr
g	Gravitational constant.	ft/hr ²
g_c	Conversion constant.	lb _m ft/lb _f hr ²
H	Height.	ft
H_ℓ	Height of liquid zone.	ft
ΔH	Head loss per foot of tube.	ft/ft
h	Film heat transfer coefficient; h_b = boiling, h_c = convective, h_f film, h_ℓ = liquid, h_r = radiation, h_{cb} = convective boiling, h_{ft} = film total, h_{nb} = nucleate boiling, h_{nbl} = single tube nucleate boiling.	Btu/hr ft ² °F



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

K	Constant in equation 5.23.	dimensionless
k	Thermal conductivity.	Btu/hr ft ² °F
L	Length.	ft
L _c	Minimum unstable wave length.	ft
m	Exponent.	dimensionless
N	Number of tube rows.	dimensionless
N _n	Number of vapor nozzles.	dimensionless
Nu	Nusselt number.	dimensionless
P	Pressure.	lb _f /ft ²
P _c	Critical pressure.	lb _f /in ²
P _r	Reduced pressure = P/P _c .	dimensionless
Pr	Prandtl number.	dimensionless
P _{sat}	Saturation pressure at plane interface.	lb _f /ft ²
p _t	Transverse tube pitch.	ft
ΔP	Pressure drop; ΔP _T = total, ΔP _s = static, ΔP _m = momentum, ΔP _f = friction.	lb _f /ft ²
q	Heat flux; q _{max} = maximum, q _{mf} = minimum film, q _{nc} = natural convection, q _{cr} = critical.	Btu/hr ft ²
Re	Reynolds number.	dimensionless
R _l , R _v	Volume fraction of liquid, vapor.	dimensionless
R _o	Sum of thermal resistances other than the boiling resistance.	hr ft ² °F/Btu
r _c	Radius of bubble.	ft
s	Chen suppression factor.	
T	Temperature; T _s = steam, T _w = wall, T _{sat} = saturation.	°F
ΔT	Temperature difference; ΔT _b = tube wall-saturation, ΔT _c = critical, ΔT _o = tube wall-bulk liquid, ΔT _{min} = difference at minimum film boiling coefficient.	°F
V	Velocity.	ft/hr



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

V_{∞}	Velocity approaching tube.	ft/hr
VL	Vapor load.	lb _m /hr ft ³
X_{tt}	Martinelli parameter, equation 5.29.	
x	Weight fraction of vapor.	
y	Mole fraction low boiling component in liquid.	
GREEK		
β	Coefficient of thermal expansion.	1/°R
Γ	Flow rate per unit length.	lb _m /hr ft
λ	Latent heat; λ_e , λ' = effective latent heats see eqn. 5.17, 5.19.	Btu/lb _m
μ	Dynamic viscosity; μ_{ℓ} = liquid, μ_v = vapor	lb./ft hr
ρ	Density; ρ_{ℓ} = liquid, ρ_v = vapor, ρ_b = bulk average, ρ_{tp} = two-phase.	
σ	Surface tension.	lb _f /ft
v	Specific volume change liquid-vapor.	ft ³ /lb _m
Φ_b	Bundle maximum flux correction factor.	dimensionless
$\Phi_{\ell tt}^2$, $\Phi_{v tt}^2$	Martinelli two phase factors.	dimensionless



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

BIBLIOGRAPHY

1. Zuber, N., Hydrodynamic Aspects of Boiling Heat Transfer, doctoral dissertation, Univ. of California at Los Angeles, (1959).
2. Happel, O. and K. Stephan, Heat transfer from nucleate to the beginning of film boiling in binary mixtures. Paper B7.8 Heat Transfer 1974. Proc. 5th Int. Heat Transfer Conf., Vol. IV, pp. 340-344.
3. Drew, T. B. and A.C. Mueller, Boiling, Trans. Am. Inst. Chem. Engrs. 33, (1937)
4. Bell, K.J., The Leidenfrost phenomenon: a survey, Chem. Eng. Prog. Sym. Series Vol. 63, No. 79, pp. 73-82, (1967).
5. Rhodes, T.R. and K.J. Bell, The Leidenfrost phenomenon at pressures up to the critical., Heat Transfer-Toronto 1978, Proc. 6th. Int. Heat Transfer Conf., Vol. 1, pp. 251-255.
6. Hall, W.B., The stability of Leidenfrost drops., Heat Transfer-1974, Proc. 5th Int. Heat Transfer Conf., Vol. IV, pp. 125-129.
7. Gottfried, B.S., C.J. Lee, and K.J. Bell, The Leidenfrost phenomenon: Film boiling of liquid droplets on a flat plate, Int. J. Heat Mass Transfer, Vol. 9, 1167-1187, (1966).
8. Cole, R., Boiling Nucleation, in *Advances in Heat Transfer*, eds. J. P. Hartnett and T.F. Irvine, Vol. 10, pp. 86-164, Academy Press, (1974).
9. Rohsenow, W. M., *Handbook of Heat Transfer*, 2nd. Ed. by W. M. Rohsenow, J. P. Hartnett and E. N. Ganic, McGraw-Hill Book Co. To be published (1984).
10. Hahne, E. and U. Grigull, *Heat Transfer in Boiling*, Hemisphere Publishing Co., Washington, (1977).
11. Jakob, M., Mech. Eng. 58, 643, (1936).
12. Yilmaz, S. and J. W. Westwater, Effect of commercial enhanced surfaces on the boiling heat transfer curve, 20th Nat. Heat Transfer Conf. 1981, in Enhanced Nucleate Boiling.
13. Cichelli, M. T. and C. F. Bonilla, Trans. Am. Inst. Chem. Engrs. 41, 755, (1945).
14. Zuber, N., On the stability of boiling heat transfer, Trans. ASME Vol. 80, 711, (1958).
15. Mostinski, I. L., Application of the rule of corresponding states for the calculation of heat transfer and critical heat flux, Teploenergetika 4:66, 1963, English Abst., British Chem. Eng. 8:, No. 8, 580, (1963).
16. Nishikawa, K. and K. Miyabe, On the boiling-like phenomena at supercritical pressures., *Memoirs of Faculty of Engineering*, Kyushu University, Vol. 25, No. 1. Dec. 1965, pp. 1-25.
17. Berenson, P., Transition boiling heat transfer from a horizontal surface., Ph.D. Thesis, Massachusetts Institute of Technology; also M.I.T. Heat Transfer Lab. Report 17, March (1960).
18. Jordan, D. P., Film and transition boiling, *Adv. Heat Transfer*, Vol. 5, pp. 55-128, (1968).



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

19. Bergles, A. E. and W. M. Rohsenow, J. Heat Transfer, Trans. ASME, C86: 365, (1964).
20. Brown, W., Study of flow surface boiling, Sc.D. Thesis, Massachusetts Institute of Technology, Mech. Eng. Dept., Cambridge, Mass., Jan. (1967).
21. Bergles, A. E., J. G. Collier, J. M. Delhaye, G. F. Hewitt and F. Mayinger, *Two-Phase Flow and Heat Transfer in the Power and Process Industries*, Hemisphere Publishing Co., Washington, (1981).
22. Hetsroni, G., ed., *Handbook of Multiphase Systems*, Hemisphere Publishing Co., Washington, (1982).
23. Rohsenow, W. M., A method of correlating heat transfer data for surface boiling of liquids., Trans. ASME Vol. 74, pp. 969, (1952).
24. Forster, H. K. and N. Zuber, Dynamics of vapor bubble growth and boiling heat transfer., A.I.Ch.E.J., Vol. 1, No. 4, pp. 531-535, (1955).
25. Borishanski, V. M. Correlation of the effect of pressure on the critical heat flux and heat transfer rates using the theory of thermodynamic similarity, *Problems of Heat Transfer and Hydraulics at Two-Phase Media*, pp. 16-37, Published by Pergamon Press (1969).
26. Collier, J. G., *Heat Exchangers Thermal-Hydraulic Fundamentals and Design.*, eds. S. Kakac, A. E. Bergles and F. Mayinger, Hemisphere Publishing Corp., Washington, D. C. (1981).
27. Lienhard, J. H. and V. K. Dhir, Hydrodynamic prediction of peak pool boiling heat flux from finite bodies, J. Heat Transfer, Trans. ASME C95, pp. 152-158, (1973).
28. Berghmans, J., The minimum heat flux during film boiling, Paper PB-21, Heat Transfer-Toronto 1978, proc. 6th Int. Heat Transfer Conf., Vol. 1, pp. 233-237.
29. Berenson, P. J., Film boiling heat transfer from a horizontal surface., J. Heat Transfer Trans. ASME C83: pp. 351-358, (1961).
30. Bromley, L. A., Heat transfer in stable film boiling., Chem. Engng. Prog. Vol. 46, No. 5, pp. 221-227, (1961).
31. Abbott, M. D. and W. D. Comley, S. M. Thesis in Chemical Engineering, Massachusetts Institute of Technology, (1938).
32. Palen, J. W., Yarden, A. and J. Taborek, Characteristics of boiling outside large scale multitube bundles, CEP Sym. Series, 68: No. 118, pp. 50-61, (1972).
33. Leong, L. S. and K. Cornwall, Heat transfer coefficients in a reboiler tube bundle., The Chemical Engineer, No. 343, pp. 219-221, April (1979).
34. Palen, J. W., Shell and tube reboilers, Section 3.6 *Heat Exchanger Design Handbook*, Hemisphere Publishing Co. (1983).
35. Palen, J. W. and W. M. Small, A new way to design kettle and internal reboilers, Hydrocarbon Processing, 43: No. 11, pp. 199, (1964).



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

36. Chen, J. C., A correlation for boiling heat transfer to saturated fluids in convective flow, ASME paper 63-HT-34, 1963. Also Ind. Eng. Chem. Process Design and Development, 5: No. 3, pp. 322-329, (1966).
37. Fair, J. R., What you need to design thermosyphon reboilers, Petroleum Refiner, 39: No. 2, pp. 105, (1960).
38. Glickstein, M. R. and R. H. Whitesides, Forced convection nucleate and film boiling of several aliphatic hydrocarbons ASME paper 67-HT-7, 9th. Nat. Heat Transfer Conf. 1967, Seattle.
39. Blumenkrantz, A. and J. Taborek, Applications of stability analysis for design of natural circulation boiling systems and comparison with experimental data. AIChE Symp. Series 68, No. 118, (1971).
40. Lee, D. C., J. W. Dorsy, G. Moore, and F. D. Mayfield, Design data for thermosyphon reboilers, Chem Eng. Prog. Vol. 52, No. 4, p. 160, (1956).
41. Palen, J. W., C. C. Shih, A. Yarden, and J. Taborek, Performance limitations in a large scale thermosyphon reboiler., Proc. 5th. Int. Heat Transfer Conf. paper HE2.2, Vol. 5, pp. 204-208, 1974, Tokyo.
42. Stephan, K. Heat transfer with natural convection boiling in multicomponent mixture. *Heat Exchangers Thermal-Hydraulic Fundamentals and Design.*, eds. S. Kakac, A. E. Bergles and F. Mayinger, Hemisphere Publishing Co. Washington, D. C. (1981).
43. Thomas, J. R., Nucleate pool boiling of binary liquids - an analytical equation, Chem. Eng. Prog. Sym. Series Vol. 77, pp. 238-250, (1981).
44. Wright, R. D. and C. P. Colver, Saturated pool boiling burnout of ethane-ethylene mixtures, A.I.Ch.E. Preprint No. 24, 10th. Nat. Heat Transfer Conf., (1968).
45. Van Wijk, W. R., A. S. Vos and S. J. D. Van Strahlen, Heat transfer to boiling binary liquid mixtures, Chem. Eng. Sci. 5, pp. 68-80, (1956).
46. Carne, M., Some effects of test section geometry, in saturated pool boiling, on the critical heat flux for some organic liquids and liquid mixtures, Chem. Eng. Prog. Sym. Series 61, No. 59, pp. 281-289, (1965).
47. Ganic, E. N., On the heat transfer and fluid flow in falling film shell and tube evaporators, Heat Exchangers *Thermal-Hydraulic Fundamentals and Design*, S. Kakac, A. E. Bergles and F. Mayinger, eds. Hemisphere Publishing, Washington, (1983).
48. Seban, R. A., Transport to falling films, Heat Transfer, 6th. Int. Heat Transfer Conf. Vol. 6, pp. 417-428, 1978, Hemisphere Publishing, Washington.
49. Palen, J. W., J. Taborek and S. Yilmaz, Comments to the application of enhanced boiling surfaces in tube bundles, *Heat Exchangers Theory and Practice*, eds. J. Taborek, G. I'. Hewitt and N. Afgan, Hemisphere Publishing Co. Washington, D. C. (1983).
50. Yilmaz, S., J. J. Hwalek and J. W. Westwater, Pool boiling heat transfer performance for commercial enhanced tube surfaces, ASME paper 80-HT-41, 19th. Nat. Heat Transfer Conf. (1980).



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

51. Han, L. S. and S. G. Leftowitz, Constant cross section fin efficiencies for non-uniform surface heat transfer coefficients, ASME paper 60-WA-41, (1960).
52. Chen, S. and G. L. Zyskowski, Steady state heat conduction in a straight fin with variable film coefficient, ASME paper 63-HT-12, (1963).
53. Cumo, M., S. Lopez and G. C. Pinchera, Numerical calculation of extended surface efficiencies, CEP Sym. Series 61: No. 59 225, (1965).
54. Haley, K. W. and J. W. Westwater, Boiling heat transfer from single fins, Proc. 3rd. Int. Heat Transfer Conf., Chicago, 3:pp. 245-253, (1966).
55. Klein, G. J. and J. W. Westwater, Heat transfer from multiple spines to boiling liquids, AIChE, J., 17: pp. 1050-1056, (1971).
56. Ishihara, K., J. W. Palen and J. Taborek, Critical review of correlations for predicting two-phase pressure drop across tube banks, Heat Transfer Engineering, Vol. 1, No. 3, pp. 23-32, (1980).
57. Diehl, J. E., Calculate condenser pressure drop., Pet. Refiner, Vol. 36, No. 10, pp. 147-153, (1957).
58. Diehl, J. E. and C. H. Unruh, Two-phase pressure drop for horizontal cross-flow through tube banks., ASME paper 58-HT-20, (1958).
59. Grant, I. D. R. and I. Murray, Pressure drop in the shell-side of a segmentally baffled shell-and-tube heat exchanger with vertical two-phase flow., Ntl. Eng. Lab Rept. 470, (1972).
60. Grant, I. D. R. and I. Murray, Pressure drop on the shell-side of a segmentally baffled shell-and-tube heat exchanger with horizontal two-phase flow, Ntl. Eng. Lab. Rept. 560, (1974).
61. Fair, J. R. and A. Klip, Thermal design of horizontal-type reboilers, A. I.Ch. E. paper, presented at Spring meeting Anaheim, CA. (1982).
62. Grant, I. D. R. and D. Chisholm, Trans. ASME 101, 38, (1978).
63. Taborek, J., T. Aoki, R. B. Ritter, J. W. Palen and J. G. Knudsen, Fouling - the major unresolved problem in heat transfer, Chemical Engineering Progress Vol. 68, No. 2, pp 59-67, No. 7, pp 69-78, (1972).
64. Somerscales, E. F. C. and J. G. Knudsen, Eds. *Fouling of Heat Transfer Equipment*, Hemisphere, New York, (1981).
65. Epstein, N., Fundamentals of heat transfer surface fouling, *Low Reynolds Number Forced Convection in Channels and Bundles*, ASI proceedings, Ankara, 1981, S. Kakac, A. E. Bergles and R. k. Shah eds. Hemisphere, to be published (1983).
66. Taborek, J., G. F. Hewitt and N. Afgan, eds., *Heat Exchangers - Theory and Practice*, Hemisphere, New York, (1983).
67. Kakac, S., A. E. Bergles and F. Mayinger, eds., *Heat Exchangers Thermal-Hydraulic Fundamentals and Design*, Hemisphere, New York, (1981).



WOLVERINE TUBE HEAT TRANSFER DATA BOOK

68. Standards - Tubular Exchangers Manufacturers Association, TEMA 6th. edition 1978, New York.
69. Webber, W. O. Does fouling rule out using finned tubes in reboilers; *Pet. Refiner*, March, (1960).
70. Moore, J. A., Fin tubes foil fouling for scaling services, *Chemical Processing*.
71. Jacobs, J. K., Reboiler selection simplified., *Hydrocarbon Processing and Refiner* 40, No. 7, pp. 189-196, (1961).
72. Palen, J. W. and J. Taborek, Proposed method for design and optimization of refinery kettle reboilers, AIChE paper 13, 5th. Nat. Heat Transfer Conf., 1962, also *Chem. Eng. Prog.* 58, No. 7, 37, (1962).
73. Johnson, A. I., Circulation ratios and overall temperature driving forces for a vertical thermosyphon reboiler, AIChE preprint #4, Nat. Heat Transfer Conf., Louisville, 1955 or *Chem. Engr. Prog. Symposium series*, 52, No. 18, pp. 37-48, (1956).
74. Beecher, N., S.M. thesis in chemical engineering MIT 1948, as given in *Heat Transmission* by W. H. McAdams, 3rd ed., 1954*1 McGraw-Hill Book Co., New York.
75. McKee, H.R., and K.J. Bell, Forced convection boiling from a cylinder normal to the flow, *Chem. Eng. Symp. Series*, Vol. 65, No. 92, pp. 222-230 (1969).