


Vedlegg 16

Dimensjonering av dekke i Calculatis

system




global utilization ratio

66 %

ULS	29 %	ULS fire	0 %	SLS	66 %	SLS vibration	0 %	support	-1 %
-----	------	----------	-----	-----	------	---------------	-----	---------	------

section: CLT 300 L8s - 2



layer	thickness	orientation	material
1	40.0 mm	0°	C24 spruce
2	40.0 mm	0°	C24 spruce
3	30.0 mm	90°	C24 spruce
4	40.0 mm	0°	C24 spruce
5	40.0 mm	0°	C24 spruce
6	30.0 mm	90°	C24 spruce
7	40.0 mm	0°	C24 spruce
8	40.0 mm	0°	C24 spruce
t _{CLT}	300.0 mm		

material values

material	f _{m,k}	f _{t,0,k}	f _{t,90,k}	f _{c,0,k}	f _{c,90,k}	f _{v,k}	f _{r,k min}	E _{0,mean}	G _{mean}	G _{r,mean}
	[N/mm ²]									
C24 spruce	24.00	14.00	0.12	21.00	2.50	4.00	1.25	12,500.00	690.00	50.00

load

load case groups

	load case category	Typ	duration	Kmod	γ _{inf}	γ _{sup}	ψ ₀	ψ ₁	ψ ₂
LC2	dead load	G	permanet	0.6	1	1.35	1	1	1
LC1	live load cat. A: domestic, residential areas	Q	medium term	0.8	0	1.5	0.7	0.5	0.3

LC2:dead load

continous load

field	load at start
	[kN/m]
1	6.00

LC1:live load cat. A: domestic, residential areas

continous load

field	load at start
	[kN/m]
1	4.91


ULS combinations

	combination rule
LCO1	1.35/1.00 * LC2
LCO2	1.35/1.00 * LC2 + 1.50/0.00 * LC1

SLS characteristic combination	
	combination rule
LCO3	1.00/1.00 * LC2
LCO4	1.00/1.00 * LC2 + 1.00/0.00 * LC1

SLS quasi-permanent combination	
	combination rule
LCO5	1.00/1.00 * LC2
LCO6	1.00/1.00 * LC2 + 1.00/0.00 * 0.30 * LC1

Ultimate limit state (ULS) - design results



ULS flexural design


field	dist.	$f_{m,k}$	γ_m	k_{mod}	$k_{sys,y}$	$f_{m,y,d}$	$M_{y,d}$	$\sigma_{m,y,d}$	ratio	
	[m]	[N/mm ²]	[-]	[-]	[-]	[N/mm ²]	[kNm]	[N/mm ²]		
1	4.5	24.00	1.30	0.80	1.10	16.25	156.58	-4.64	29 %	LCO2

ULS shear analysis

field	dist.	$f_{v,k}$	γ_m	k_{mod}	$f_{v,d}$	V_d	$\tau_{v,d}$	ratio	
	[m]	[N/mm ²]	[-]	[-]	[N/mm ²]	[kN]	[N/mm ²]		
1	9.0	4.00	1.30	0.80	2.46	-69.59	0.13	5 %	LCO2

ULS rolling shear

field	dist.	$f_{r,k}$	γ_m	k_{mod}	$f_{r,d}$	V_d	$\tau_{r,d}$	ratio	
	[m]	[N/mm ²]	[-]	[-]	[N/mm ²]	[kN]	[N/mm ²]		
1	9.0	1.15	1.30	0.80	0.71	-69.59	0.12	17 %	LCO2



flexural stress analysis

$M_{y,d} =$	156.58 kNm	$f_{m,k} =$	24.00 N/mm ²
$N_{t,d} =$	0.00 kN	$\gamma_m =$	1.30 -
		$k_{mod} =$	0.80 -
		$k_{sys,y} =$	1.10 -
		$k_{nm} =$	1.00 -
		$k_f =$	1.00 -
$\sigma_{t,d} =$	0.00 N/mm ²	$f_{t,d} =$	8.62 N/mm ²
$\sigma_{m,y,d} =$	-4.64 N/mm ² <	$f_{m,y,d} =$	16.25 N/mm ² ✓

utilization ratio 29 %

shear stress analysis


$V_d =$	- kN 69.59	$f_{v,k} =$	4.00 N/mm ²
		$\gamma_m =$	1.30
		$k_{mod} =$	0.80
$\tau_{v,d} =$	0.13 N/mm ² <	$f_{v,d} =$	2.46 N/mm ² ✓


utilization ratio 5 %

rolling shear analysis

$V_d =$	-69.59 kN	$f_{r,k} =$	1.15 N/mm ²
		$\gamma_m =$	1.30 -
		$k_{mod} =$	0.80 -
$\tau_{r,d} =$	0.12 N/mm ² <	$f_{r,d} =$	0.71 N/mm ² ✓

utilization ratio 17 %





$w_{inst} = w[char]$

field	limit	w_{limit}	$w_{calc.}$	ratio
	[-]	[mm]	[mm]	
1	1/300	30.0	16.1	54 %

$w_{fin} = w[char] + w[q.p.]*k_{def}$

field	limit	w_{limit}	$w_{calc.}$	ratio
	[-]	[mm]	[mm]	
1	1/200	45.0	25.0	56 %

$w_{net,fin} = w[q.p.] + w[q.p.]*k_{def}$

field	limit	w_{limit}	$w_{calc.}$	ratio
	[-]	[mm]	[mm]	
1	1/300	30.0	19.9	66 %

support reaction

load case category	k_{mod}	A_v	B_v
		[kN]	
dead load	0.6	27.00	27.00
		27.00	27.00
live load cat. A: domestic, residential areas	0.8	22.09	22.09
		0.00	0.00

reference documents for this analysis

English title	description
EN 338	EN 338 - Structural timber — Strength classes
ETA-14/0349	European Technical Assessment ETA-14/0349 of 02.10.2014
Expertise Rolling shear - no edge gluing, H.J. Blass	Expertise on Rolling shear for CLT
EN 1995-1-2	EN 1995-1-2 - Eurocode 5 — Design of timber structures — Part 1-2: General — Structural fire design
EN 14080	EN 14080 - Timber Structures - Glued laminated timber and glued solid timber - Requirements
DIN EN 1995-1-1	EN 1995-1-1 - Eurocode 5: Design of timber structures - Part 1-1: General - Common rules and rules for buildings
DIN EN 1995-1-1 NA	EN 1995-1-1 - National Annex – Nationally determined parameters – Eurocode 5: Design of timber structures – Part 1-1: General — Common rules and rules for buildings
Technical expertise 122/2011/02: analysis of load bearing capacity and separation performance of CLT elements	Verification of the load bearing capacity and the insulation criterion of CLT structures with Stora Enso CLT
Technical expertise 2434/2012 - BB: failure time t_f of gypsum fire boards (GKF) according to ON B 3410	Expertise on failure time t_f of gypsum wall fire boards according to ON B3410 and gypsum wall boards type DF according to EN 520
EN 1990	EN 1990 - Eurocode — Basis of structural design
Fire safety in timber buildings - technical guideline for Europe	Fire safety in timber buildings - technical guideline for Europe; publishes by SP Technical Research Institute of Sweden
National specifications concerning ÖNORM EN 1995-1-2, national comments and national supplements, chapter 12	ÖNORM EN 1995-1-2 - National specifications concerning ÖNORM EN 1995-1-2, national comments and national supplements, chapter 12

reference documents for this analysis	
English title	description
DIN EN 1995-1-2_NA	DIN EN 1995-1-2 - Germany - National Annex - Eurocode 5: Design of timber structures — Part 1-2: General — Structural fire design — National specifications concerning DIN EN 1995-1-2, national comments and national supplements
Expertise Rolling shear, H.J. Blass ÖNORM EN 1995-1-1_NA, chapter 7.3	Expertise on rolling shear strength and rolling shear modulus of CLT panels ÖNORM EN 1995-1-1 - Austria - National Annex – Nationally determined parameters – Eurocode 5: Design of timber structures – Part 1-1: General-Common rules and rules for buildings; chapter 7.3

Disclaimer

The software was created to assist engineers in their daily business. The software is an engineering software that is dealing with a very complex matter of structural analysis and building physics analysis. Therefore, this software shall only be operated by skilled, experienced engineers, with a deep understanding of structural engineering and building physics related to timber structures. The user of the software is obliged to check all input values, no matter if they were given by the user or given by default by the software and all results for plausibility.

The use of the results of the software should not be relied upon as the basis for any decision or action. Any use of results of the software is only allowed, if the results have been verified and approved regarding completeness and correctness by a project structural/building physics engineer. The user has the possibility to make print-outs from the software. Any modification of those are not allowed.

Stora Enso Wood Products GmbH does not assume any warranty regarding the software. The software has been developed with utmost diligence, nevertheless Stora Enso Wood Products GmbH, neither expressly nor implicitly, provides any warranty in terms of accuracy, validity, timeliness and completeness of information and data created by the software. Stora Enso Wood Products GmbH does also not assume any warranty for the general usability of the software, its suitability for a special purpose or for the compatibility of the software with the ones of third party producers or providers.

Stora Enso Wood Products GmbH is only liable for damages caused by gross negligence or intent through Stora Enso Wood Products GmbH; the liability for slight negligence is excluded. This does not apply to personal injury. Under the aforementioned conditions Stora Enso Wood Products GmbH is as well not liable for operational failures or the loss of programs and/or data of the user's data processing system.

Applicable Law: These terms of use shall be governed by the laws of Austria excluding however any conflict of laws rules and any laws regarding the Convention of the International Sale of Goods (CISG).