


system**global utilization ratio**


86 %

ULS	86 %	ULS fire	27 %	SLS	12 %	SLS vibration	0 %	support	-1 %
-----	------	----------	------	-----	------	---------------	-----	---------	------

section: wooden beam 30/75

	section width	section height	area	I_y	I_z
	[cm]	[cm]	[mm ²]	[mm ⁴]	[mm ⁴]
	30	75	225,000	10,546,880,000	1,687,500,000

section fire: wooden beam 30/75

	section width	section height	area	ly	lz			
	[cm]	[cm]	[mm²]	[mm⁴]	[mm⁴]			
	30	75	225,000	10,546,880,000	1,687,500,000			
fire resistance class:R 0			time	0 min				
fire protection layering : no additional fire protection			k ₀	d ₀	d _{char,0,h}	d _{ef,h}	d _{char,0,v}	d _{ef,v}
			[-]	[mm]	[mm]	[mm]	[mm]	[mm]
			1	7	0.0	0.0	0.0	0.0

material values

material	$f_{m,k}$	$f_{t,0,k}$	$f_{t,90,k}$	$f_{c,0,k}$	$f_{c,90,k}$	$f_{v,k}$	$f_{r,k \text{ min}}$	$E_{0, \text{mean}}$	G_{mean}	$E_{0,5}$
	[N/mm ²]	[N/mm ²]	[N/mm ²]	[N/mm ²]	[N/mm ²]	[N/mm ²]	[N/mm ²]	[N/mm ²]	[N/mm ²]	[N/mm ²]
GL 32h	32.00	25.60	0.50	32.00	2.50	2.50	1.20	14,200.00	350.00	11,800.00

load**load case groups**

	load case category	Typ	duration	Kmod	γ_{inf}	γ_{sup}	Ψ_0	Ψ_1	Ψ_2
LC1	self weight CLT	G	permanet	0.6	1	1.35	1	1	1
LC2	self weight	G	permanet	0.6	1	1.35	1	1	1
LC3	live load cat. A: residential	Q	medium term	0.8	0	1.5	0.7	0.5	0.3

LC1: self weight CLT

continous load	
field	load at start
	[kN/m]
1	1.13

LC2:serlf weight

continous load	
field	load at start
	[kN/m]
1	3.70
1	0.90

point load		
field	distance from start	load at start
	[m]	[kN]
1	3.734	99.69

LC3:live load cat. A: residential

continous load	
field	load at start
	[kN/m]
1	5.85

point load		
field	distance from start	load at start
	[m]	[kN]
1	3.734	92.14

ULS combinations

	combination rule
LCO1	$1.12/1.00 * LC1 + 1.12/1.00 * LC2$
LCO2	$1.12/1.00 * LC1 + 1.12/1.00 * LC2 + 1.25/0.00 * LC3$

ULS combinations fire

	combination rule
LCO3	$1.00/1.00 * LC1 + 1.00/1.00 * LC2$
LCO4	$1.00/1.00 * LC1 + 1.00/1.00 * LC2 + 1.00/0.00 * 0.30 * LC3$


SLS characteristic combination

	combination rule
LCO5	$1.00/1.00 * LC1 + 1.00/1.00 * LC2$
LCO6	$1.00/1.00 * LC1 + 1.00/1.00 * LC2 + 1.00/0.00 * LC3$

SLS quasi-permanent combination

	combination rule
LCO7	$1.00/1.00 * LC1 + 1.00/1.00 * LC2$
LCO8	$1.00/1.00 * LC1 + 1.00/1.00 * LC2 + 1.00/0.00 * 0.30 * LC3$

Ultimate limit state (ULS) - design results



ULS flexural design

field	dist.	$f_{m,k}$	γ_m	k_{mod}	$k_{sys,z}$	k_{hm}	$f_{m,y,d}$	$M_{y,d}$	$\sigma_{m,y,d}$	ratio	
	[m]	[N/mm ²]	[-]	[-]	[-]	[-]	[N/mm ²]	[kNm]	[N/mm ²]		
1	3.65	32.00	1.25	0.80	1.00	1.00	20.48	172.84	6.15	30 %	LCO2

ULS shear analysis

field	dist.	$f_{v,k}$	γ_m	k_{mod}	$f_{v,d}$	V_d	$\tau_{v,d}$	ratio	
	[m]	[N/mm ²]	[-]	[-]	[N/mm ²]	[kN]	[N/mm ²]		
1	3.81	2.50	1.25	0.80	1.60	206.28	1.38	86 %	LCO2


flexural stress analysis

$M_{y,d} =$	172.84	kNm	$f_{m,k} =$	32.00	N/mm ²
$N_{t,d} =$	0.00	kN	$\gamma_m =$	1.25	-
			$k_{mod} =$	0.80	-
			$k_{sys,y} =$	1.00	-
			$k_{hm} =$	1.00	-
			$k_l =$	1.00	-
$\sigma_{t,d} =$	0.00	N/mm ²	$f_{t,d} =$	17.56	N/mm ²
$\sigma_{m,y,d} =$	6.15	N/mm ²	$f_{m,y,d} =$	20.48	N/mm ²
utilization ratio					30 %

shear stress analysis

$V_d =$	206.28	kN	$f_{v,k} =$	2.50	N/mm ²
			$\gamma_m =$	1.25	-
			$k_{mod} =$	0.80	-
$\tau_{v,d} =$	1.38	N/mm ²	$f_{v,d} =$	1.60	N/mm ²
utilization ratio					86 %

Ultimate limit state (ULS) fire design - results



ULS fire flexural design

field	dist.	$f_{m,k}$	γ_m	k_{mod}	$k_{sys,z}$	k_{fi}	$f_{m,y,d}$	$M_{y,d}$	$\sigma_{m,y,d}$	ratio	
	[m]	[N/mm ²]	[-]	[-]	[-]	[-]	[N/mm ²]	[kNm]	[N/mm ²]		
1	3.65	32.00	1.00	1.00	1.00	1.15	36.80	96.83	3.44	9 %	LCO4

ULS fire shear analysis

field	dist.	$f_{v,k}$	γ_m	k_{mod}	k_{fi}	$f_{v,d}$	V_d	$\tau_{v,d}$	ratio	
	[m]	[N/mm ²]	[-]	[-]	[-]	[N/mm ²]	[kN]	[N/mm ²]		
1	3.81	2.50	1.00	1.00	1.15	2.88	115.67	0.77	27 %	LCO4



flexural stress analysis fire

$M_{y,d} =$	96.83	kNm	$f_{m,k} =$	32.00	N/mm ²
$N_{t,d} =$	0.00	kN	$\gamma_m =$	1.00	-
			$k_{mod} =$	1.00	-
			$k_{sys,y} =$	1.00	-
			$k_{hm} =$	1.00	-
			$k_l =$	1.00	-
			$k_{fi} =$	1.15	-
$\sigma_{t,d} =$	0.00	N/mm ²	$f_{t,d} =$	31.55	N/mm ²
$\sigma_{m,y,d} =$	3.44	N/mm ²	$f_{m,y,d} =$	36.80	N/mm ²
utilization ratio					9 %

shear stress analysis fire

$V_d =$	115.67	kN	$f_{v,k} =$	2.50	N/mm ²
			$\gamma_m =$	1.00	-
			$k_{mod} =$	1.00	-
			$k_{fi} =$	1.15	-
$\tau_{v,d} =$	0.77	N/mm ²	$f_{v,d} =$	2.88	N/mm ²
utilization ratio					27 %

Service limit state design (SLS) - design results



$w_{inst} = w[char]$

field	limit	w_{limit}	$w_{calc.}$	ratio
	[-]	[mm]	[mm]	
1	1/300	15.2	1.8	12 %

$w_{fin} = w[char] + w[q.p.]*k_{def}$

field	limit	w_{limit}	$w_{calc.}$	ratio
	[-]	[mm]	[mm]	
1	1/150	30.4	2.5	8 %

$w_{net,fin} = w[q.p.] + w[q.p.]*k_{def}$

field	limit	w_{limit}	$w_{calc.}$	ratio
	[-]	[mm]	[mm]	
1	1/250	18.2	1.9	10 %

support reaction

load case category	k_{mod}	A_v	B_v
		[kN]	
self weight CLT	0.6	2.57	2.57
		2.57	2.57
serlf weight	0.6	28.59	92.08
		28.59	92.08
live load cat. A: residential	0.8	30.07	88.75
		0.00	0.00

Disclaimer

The software was created to assist engineers in their daily business. The software is an engineering software that is dealing with a very complex matter of structural analysis and building physics analysis. Therefore, this software shall only be operated by skilled, experienced engineers, with a deep understanding of structural engineering and building physics



related to timber structures. The user of the software is obliged to check all input values, no matter if they were given by the user or given by default by the software and all results for plausibility.

The use of the results of the software should not be relied upon as the basis for any decision or action. Any use of results of the software is only allowed, if the results have been verified and approved regarding completeness and correctness by a project structural/building physics engineer. The user has the possibility to make print-outs from the software. Any modification of those are not allowed.

Stora Enso Wood Products GmbH does not assume any warranty regarding the software. The software has been developed with utmost diligence, nevertheless Stora Enso Wood Products GmbH, neither expressly nor implicitly, provides any warranty in terms of accuracy, validity, timeliness and completeness of information and data created by the software. Stora Enso Wood Products GmbH does also not assume any warranty for the general usability of the software, its suitability for a special purpose or for the compatibility of the software with the ones of third party producers or providers.

Stora Enso Wood Products GmbH is only liable for damages caused by gross negligence or intent through Stora Enso Wood Products GmbH; the liability for slight negligence is excluded. This does not apply to personal injury. Under the aforementioned conditions Stora Enso Wood Products GmbH is as well not liable for operational failures or the loss of programs and/or data of the user's data processing system.

Applicable Law: These terms of use shall be governed by the laws of Austria excluding however any conflict of laws rules and any laws regarding the Convention of the International Sale of Goods (CISG).

