

Andrew Mabula

Optimal use of hydro resources in the Chiriquí Viejo Basin, Panama

Master's thesis in Hydropower Development

Supervisor: Oddbjørn Bruland

July 2019

Andrew Mabula

Optimal use of hydro resources in the Chiriquí Viejo Basin, Panama

Master's thesis in Hydropower Development
Supervisor: Oddbjørn Bruland
July 2019

Norwegian University of Science and Technology
Faculty of Engineering
Department of Civil and Environmental Engineering

 **NTNU**
Norwegian University of
Science and Technology

Abstract

The Chiriquí Viejo water basin is located in the Chiriquí province of Panama which shares borders with Costa Rica on the western borders of the country. It is characterized by an average altitude of 1100 mm and annual precipitation of 2476 mm which makes it suitable for hydropower production. The basin consists mainly of run-of-river schemes, with a daily regulation reservoir.

The study consists of 7 power plants with a generation capacity greater than 20 MW. Five of the powerplants are in operation; Monte Lirio (52 MW) with no upstream storage, El Alto (72 MW), Bajo de Mina (57 MW), Baitun (86 MW) and Bajo Frio (58 MW) and two power plants, Pando (33 MW) and Burica (65 MW), planned to be introduced to the system between 2019 and 2023. The main objective of the study is to find strategies for the use of water in the cascade and optimize the hydropower production.

A spreadsheet model and nMAG have been used in the study to simulate and optimize production. Operating the reservoirs at near full capacity increases production by 3.7% (37 GWh) annually with a reduction in operational time of 28% for El Alto, Bajo de Mina, Burica and Bajo Frio powerplants.

nMAG has been used to conduct simulations for the future, current system and climate change impact on production. The introduction of Pando and Burica to the system increases the production of the Chiriquí Viejo basin by 528 GWh annually. The Upstream regulation of Pando will result in increased production at Monte Lirio hydropower powerplant of 0.1% (0.4 GWh) and 0.2 GWh for both Bajo de Mina and Baitun hydropower plants with the production increase mostly in the rainy season.

Simulations based on climate change with the future setup show no significant impact on production. Inflow based on climate change studies from literature with a 12% reduction is still able to meet firm demand based on the strategy in nMAG.

Acknowledgement

I would like to sincerely thank Professor Oddbjørn Bruland for his guidance and supervision in this study, much would not have been achieved without his effort. I would like to thank my co-supervisor, Professor Knut Alfredsen for effortlessly availing time and support.

I would like to thank Hans Jacob Bull-Berg and the SN Power team in Panama that comprised of Ian Dillon and Jose Calvo for their consistent support, communication and assistance during the study.

Last but not the least, I would like to thank my mother Grace Mukuka Mabula and my family for their encouragement and support throughout the course of my study.

Table of Contents

1.0	Introduction	1
2.0	Study area	2
2.1	Chiriquí Viejo Catchment	2
2.2	Topography	3
2.3	Climate	3
2.4	Rainfall	3
2.5	Hydropower production	3
2.5.1	Pando and Monte Lirio hydropower plant	6
2.5.2	El Alto hydropower plant	6
2.5.3	Bajo de Mina hydropower plant	7
2.5.4	Baitun hydropower plant	7
2.5.5	Bajo Frio hydropower plant	8
2.5.6	Burica Hydro power plant	8
3.0	Literature review	9
3.1	Panama	9
3.2	Economy	9
3.3	Energy in Panama	9
3.4	The Electricity sector in Panama	10
3.4.1	Electricity market in Panama	13
3.4.2	Electricity prices	13
3.5	Optimization of hydropower systems	15
3.5.1	Vansimtap	16
3.5.2	Prodrisk	16
3.5.3	nMAG	17
3.5.4	Power plant	18
3.5.5	Energy market	19
3.5.6	Operational strategy	19
3.6	Run-of- river schemes and climate change	20
4.0	Data and data analysis	21
4.1	Hydrology data	21
4.1.1	El Alto Inflow	25
4.2	Runoff scaling	25

4.3	Generation and spot price data.....	26
4.4	Turbine efficiency curves	27
4.5	Head loss	27
5.0	Spreadsheet model.....	28
5.1	Model structure.....	28
5.1.1	Hydrology	28
5.1.2	Reservoir operation.....	29
5.1.3	Energy calculations.....	32
5.1.4	Energy market.....	33
5.1.5	Optimization and Results	33
5.2	System setup	34
5.3	Calibration and validation model	34
5.4	Simulation results and discussion	36
5.5	Optimization results and discussion.....	38
5.5.1	Production maximization	38
5.5.2	Revenue maximization.....	41
6.0	NMAG Model.....	45
6.2	Current production System.....	48
6.2.1	Simulation results and analysis.....	49
6.3	Future production system	52
6.3.1	Simulation results and analysis.....	53
6.4	Climate change impact on Production	54
7.0	Conclusion and recommendations	55
8.0	REFERENCES	56
9.0	APPENDIX.....	58

List of Figures

Figure 2.1 Chiriqui Viejo water basin	2
Figure 2.2: Annual energy production for Chiriquí Viejo 2011 – 2018	4
Figure 2.3: Hydropower plants in the Chiriquí Viejo watershed	5
Figure 3.1: Panama’s total primary energy supply, (IRENA, 2018)	10
Figure 3.2: Gross Electricity generation in Panama (IRENA, 2018).....	11
Figure 3.3: Panama Electricity generation by fuel source, 2016	11
Figure 3.4: Main Transmission system in Panama (ETESA, 2017).....	12
Figure 3.5: Marginal Costs vs International fuel costs and Hydrological contribution (TECSA, 2018)	14
Figure 3.6: Historical average electricity price (U\$ cents) (TECSA, 2018).....	14
Figure 3.7: Hydropower system simulation components ((Killingtveit, 1995)	17
Figure 4.1: Hydrological stations in Chiriquí Viejo Watershed	22
Figure 4.2: Annual Average flows for Paso Canoas and Pando (1957-2018).....	24
Figure 4.3: Accumulated Mass curve for Volcan (1957 – 2018)	24
Figure 4.4: Accumulated Mass curve for El alto inflow	25
Figure 4.5: Scaled inflow (EL Alto) vs Actual inflow (Paso Canoas).....	26
Figure 4.6 Daily average Spot Price Variation (USD/MWh)	26
Figure 4.7: Typical turbine efficiency curves.....	27
Figure 5.1: Spreadsheet simulation setup	34
Figure 5.2 Monthly Energy (MWh) comparison of simulations for zero pricing (USD/MWh).....	35
Figure 5.3 Scatter plot comparison for zero pricing simulations (MWh)	35
Figure 5.4: Total Generation: A is the simulated Energy (GWh) production. B. is the observed Energy production.....	36
Figure 5.5: Total Monthly Energy (GWh) for the El Alto, Bajo de Mina, Baitun and Bajo Frio and Monthly Average Spot Prices (USD/MWh).....	37
Figure 5.6 :Optimized Bajo Frio reservoir water balance	39
Figure 5.7: Annual Average Energy (GWh) production maximization	40
Figure 5.8: Optimized Bajo Frio reservoir water balance (strategy 1).....	42
Figure 5.9: Annual Average Energy (GWh) for revenue maximization	43
Figure 5.10: Optimized Bajo Frio reservoir water balance (strategy 2).....	44
Figure 6.1: EL Alto extended inflow (1957 -2018)	45
Figure 6.2: Reservoir guide curve for El Alto.....	46
Figure 6.3: Simulated vs Observed Energy (MWh) for Monte Lirio, A. Based on El Alto inflow, B., 35% El Alto and 65% Volcan, C Volcan.	47
Figure 6.4: NMAG schematic representation of current system	48
Figure 6.5: Total Energy (GWh) Monte Lirio, El Alto, Bajo de Mina, Baitun and Bajo Frio	49
Figure 6.6: total Annual Energy (GWh) difference of Observed from Simulated Energy	50
Figure 6.7: El Alto Average Daily Simulated vs Observed Production (MW)	51
Figure 6.8: NMAG schematic representation of Future system	52
Figure 6.9: Monte Lirio difference in production between current and future system (MWh).....	53

List of Tables

Table 2.1: Hydropower Plants > 20 MW in Chiriquí Viejo watershed	4
Table 2.2: Pando and Monte Lirio powerplant characteristics	6
Table 2.3: El Alto powerplant characteristics	6
Table 2.4: Bajo de Mina powerplant characteristics.....	7
Table 2.5: Baitun powerplant characteristics	7
Table 2.6: Bajo Frio powerplant characteristics.....	8
Table 2.7: Burica powerplant characteristics.....	8
Table 4.1: Characteristics of gauging stations in Chiriquí Viejo watershed	21
Table 5.1: Simulation Results for the period 2016 - 2018	36
Table 5.2: Optimal price difference and reservoir regulation criteria variables.....	38
Table 5.3: Reservoir Peaking hours.....	39
Table 5.4: Optimization Results for the period 2016 - 2018.....	40
Table 5.5: Optimal price difference and reservoir regulation criteria variables (Strategy 1).....	41
Table 5.6: Optimization Results for the period 2016 – 2018 (strategy 1)	42
Table 5.7: Optimal price difference and reservoir regulation criteria variables (Strategy 1).....	43
Table 5.8: Optimization Results for the period 2016 – 2018 (strategy 1)	44
Table 6.1: Simulated vs Observed Total Annual Energy (MWh)	49
Table 6.2: Annual Average Energy (GWh).....	50
Table 6.3: Annual Average Energy (GWh) - Current vs Future Production System	53
Table 6.4: Impact of Climate change on Future production	54

Acronym and Abbreviations

ANAM Autoridad Nacional del Ambiente de Panamá

ARB Automatic Reservoir Balancing

ASEP Autoridad Nacional de los Servicios Públicos

CND Central National Dispatch

ETESA Empresa de Transmision Electrica S.A

FIC Fountain Intertrade Cooperation

GDP Gross Domestic Product

masl Mean above sea level

RGC Reservoir Guide Curve

RWL Reservoir Water Level

SINTEF Stiftelsen for Industriell og Teknisk Forskning

1.0 Introduction

Hydropower in the Panamanian electricity sector accounts for 51 %, shared between small and large hydro schemes with small hydro accounting for 9% of the total share (Wood, 2018). Most of the water for hydropower production is found in the western Province of Chiriquí. The Province has its highest hydropower potential in the Chiriquí Viejo water basin which has an average altitude of 1100 masl and a mean annual precipitation of 2476 mm making it suitable for hydropower development (Diego, 2008).

The Panamanian government approved a National Energy Plan, in March 2016, for the period 2015 to 2050 aimed at diversifying and advancing the energy sector and decarbonization. The plan was to increase renewable energy with a strategy of 7 % by 2020 and 13% in 2030 which has facilitated for investment opportunities in the renewable sector (IRENA, 2018). These factors attracted development of hydropower in Chiriquí Viejo and foreign investment in Panama by SN Power.

SN Power is owned by Norfund an investment fund for developing countries and Statkraft a state-owned leading power company, entered a joint venture in 2011 with a Panamanian company, Credicorp Group and formed the Fountain Intertrade Corporation (FIC). The purpose of this investment vehicle was to develop and operate the Bajo Frio powerplant in the Chiriquí Viejo water basin. The Bajo Frio powerplant is a runoff the river hydro scheme with an installed capacity of 58 MW.

In 2012, the two companies entered another joint venture to develop Hidro Burica a 63 MW run-of-river scheme, downstream of Bajo Frio. However, operation of the Bajo Frio has not met the expectations of SN Power which intends to increase its investment in the basin. It is the purpose of this study to find strategies for the use of water in the cascade and optimize the hydropower production.

2.0 Study area

2.1 Chiriquí Viejo Catchment

The Chiriquí Viejo water basin is between the coordinates 8° 15' and 9° 00' N and 82° 30' and 82° 55' W. It is located in the western pacific region of Panama and lies on the pacific slope. The total catchment of the basin is 1376 km² with most of the western divide shared with the border of Costa Rica. The Chiriquí Viejo is the main river having a length of 161 m (ANAM, 2016). It runs in the western direction from in the north part and changes direction southwards towards the outlet into the Pacific Ocean.




Figure 2.1 Chiriqui Viejo water basin

2.2 Topography

The western part of Panama is characterized by a central spine of mountains that form a continental divide halfway through the country giving it higher elevation than the eastern side characterized by hills and swamps.

The Chiriquí Viejo has the highest peak in Panama with an elevation of 3 474 masl at Volcán Barú in the north-eastern part. The average altitude of the basin is 1 100 m asl (Diego, 2008).

2.3 Climate

Panama is generally classified as a tropical climate characterized by a dry and rainy season. The dry season commences in January up until April with the months of March and April being the hottest. The rainy season commences in May and prevails until December and is characterized by heavy downpours usually in the evening and early hours of the night. Using climate classification by Köppen-Geiger, 2006 Chiriquí Viejo basin can be classified as tropical monsoon.

The temperature and relative humidity are uniformly high with diurnal temperature ranging between 24 and 29 °C with an average humidity of 80%. However, high altitudes like Volcan have a lower temperature range between 13 and 21 °C throughout the year (Cimate-data.org, 2019)

2.4 Rainfall

The Mean annual precipitation in the basin is 2 476 mm with a range between 1000 and 3000 mm which may go up to a maximum of 6000 mm (Cimate-data.org, 2019)

2.5 Hydropower production

The Chiriquí river currently has six hydroelectric powerplants with a total capacity of 330 MW. The total energy production has been increasing since 2011 from 69 GWh in to 1428 GWh in 2018, figure2.2.




Figure 2.2: Annual energy production for Chiriquí Viejo 2011 – 2018

The table 2.3 and figure 2.4 show the status and location of the power plants considered for the study. All the power plants have been designed to be operated as run-of-river hydro schemes with an upstream pondage, except Monte Lirio, to meet diurnal variation of the demand as well as meeting a firm capacity during the peak period.

Table 2.1: Hydropower Plants > 20 MW in Chiriquí Viejo watershed

No.	HPP	Company	Installed Capacity (MW)	Status	Completion
1	Pando	EISA	33	Development	2019
2	Monte Lirio	EISA	52	Operation	2014
3	El Alto	PPA	72	Operation	2014
4	Bajo de Mina	IDEAL	57	Operation	2012
5	Baitun	IDEAL	86	Operation	2012
6	Bajo Frio	FHPC	58	Operation	2016
7	Hidro Burica	HBSA	65	Development	2023




Figure 2.3: Hydropower plants in the Chiriquí Viejo watershed

2.5.1 Pando and Monte Lirio hydropower plant

Pando and Monte Lirio are two power plants located 8°48'11.3"N 82°44'38.1"W and 8°46'08.1"N 82°49'19.2"W, respectively. Monte Lirio is in operation while Pando is scheduled to be complete in 2019 and the two will be operated in a cascade setup generating a total capacity of 84.25 MW.

Monte Lirio's operation depends on the outflows discharged downstream of Pando and additional river flow. The head pond level is 974 m which is the tailwater of Pando. The rated turbine flow for each is 7 m³/s and has a head of 274 m providing a tailwater level of 673 m. The hydraulic set comprises of an intake and a 7.9 km long tunnel with a surge tank and a 2.8 km long penstock feeding three generators.(CMD, 2018)

Table 2.2: Pando and Monte Lirio powerplant characteristics

		PANDO	MONTE LIRIO
Rated Output	MW	32.6	51.65
Rated Turbine Q	m ³ /s	14.5	21
Rated Head	m	252.5	274

2.5.2 El Alto hydropower plant

The power plant is located just downstream of the mouth of the river Candela 8°43'40.8"N 82°50'10.2"W. It has a capacity of 72 MW comprising of 3 vertical-shaft Francis turbines and an upstream reservoir of 3.3 million cubic meters. The hydraulic system consists of a headrace tunnel 4.2 m in diameter coated with steel and a surge tank. (CMD, 2014b)

Table 2.3: El Alto powerplant characteristics

EL ALTO		
Rated Output	MW	72
Rated Turbine Q	m ³ /s	60
Rated Head	m	126

2.5.3 Bajo de Mina hydropower plant

The Bajo de Mina power plant has a capacity of 56.8 MW located 8°40'59.5"N 82°49'30.6"W. The powerhouse is fitted with two Francis turbines. A storage pondage with a capacity of 0.87 million cubic meters is provided upstream of the powerplant.

The hydraulic setup comprises of 5.4 km long power tunnel with a surge and a 290 m long surface penstock bifurcating into two pressure pipes to a surface powerhouse.(CMD, 2014a)

Table 2.4: Bajo de Mina powerplant characteristics

BAJO DE MINA		
Rated Output	MW	56.8
Rated Turbine Q	m ³ /s	56.5
Rated Head	m	112.2

2.5.4 Baitun hydropower plant

The power plant is located 8°36'51.3"N 82°47'36.0"W and has a capacity of 85.6 MW with two vertical Francis turbines. The hydraulic system comprises of 5.9 m tunnel with a 340 m long penstock having a diameter of 5.1 m.(CMD, 2014a)

Table 2.5: Baitun powerplant characteristics

BAITUN		
Rated Output	MW	85.6
Rated Turbine Q	m ³ /s	75.0
Rated Head	m	129.3

2.5.5 Bajo Frio hydropower plant

The Bajo Frio power plant is located 8°34'47.0"N 82°47'34.5"W. It has a total installed capacity of 58 MW which is shared between two power houses, La Potra and Salsipuedes each having 28 MW in capacity with La potra having an additional 2.10 MW generating from ecological flow.

An additional 2.10 MW is generated from an auxiliary unit using ecological flow. The plant has three Kaplan turbines with a rated discharge of 100 m³/s. The river at this location has an average annual inflow of 11.8 m³/s. the hydraulic setup comprises of an intake structure, a 5.1 km long tunnel with a surge tank and a 2 km long penstock with a bifurcation to a surface powerhouse. Salsipuedes is downstream of La potra connected by a 2 km canal which runs to a forebay. It has a capacity of 28 MW with a head of 31.19 m..(CMD, 2011)

Table 2.6: Bajo Frio powerplant characteristics

		LA POTRA	LA POTRA (Aux.)	SALSIPUEDES
Rated Output	MW	27.77	2.10	27.77
Rated Turbine Q	m ³ /s	100		100
Rated Head	m	31.19	41.00	31.19

2.5.6 Burica Hydro power plant

The powerplant is in the development phase will be located 8°32'25.7"N 82°50'09.6"W. the planned capacity is 65 MW with 2 Francis turbines.

Table 2.7: Burica powerplant characteristics

BURICA		
Rated Output	MW	65
Rated Head	m	71

3.0 Literature review

3.1 Panama

Panama is a country in the southern part of Central America which borders Colombia on the east and Costa Rica on the West of the country and located between the north latitude 7- and 10-degrees and the west longitude 77- and 83-degrees. It has a total area of 75,420 with a population of four million. The official language in Panama is Spanish (CIA, 2019).

3.2 Economy

There is no central bank in Panama. The Balboa is the country's currency, equivalent to the United states dollar, which is used as the legal tender. Panama relies on the services industry which accounts for more than 75% of the gross domestic product (GDP), with 10% of the GDP being generated from the Panama Canal (Woods, 2009).

3.3 Energy in Panama

The Panamanian energy sector relies on fuel and has a high dependency on its import. It's energy demand is represented by four sectors which include Commercial, Public, Industry, Residential and transport. Commercial and Public and residential sectors are the highest consumers of electricity while transport and industry mainly consume oil and oil products. The electricity consumption since 2010 has maintained an annual average growth rate of 6.2% with the commercial and Public sector accounting for 15 % of the total energy consumption (IRENA, 2018)




Figure 3.1: Panama's total primary energy supply, (IRENA, 2018)

3.4 The Electricity sector in Panama

Electricity in Panama was provided by the private sector until 1961 when the state-owned Institute of Hydraulic Resources and Electrification (IRHE) was created which later nationalized private companies. Before 1997, the Institute operated as vertically integrated electricity company until it was unbundled into generation, transmission and distribution units of with the government maintaining ownership of the transmission line while partially privatizing generation and distribution. (IRENA, 2018)

The electricity market in 2017 comprised of a total of 60 generation companies, three self-generators, one transmission company, three distribution companies and twenty-two large consumers on the market. (TECSA, 2018). The both the capacity and energy mix have been growing in quantity and type to include wind and solar energy which were introduced in 2013. This can be seen in the gross electricity production statics of the period 2000 to 2016 in Figure 3.2.




Figure 3.2: Gross Electricity generation in Panama (IRENA, 2018)

The 2017 statistics indicate hydropower maintaining the largest source of energy in the sector with an installed capacity of 1 715 MW which accounts for 51% of the total installed capacity, thermal energy with an installed capacity of 1 239 MW and an addition of wind capacity of 270 MW and solar energy of 118 MW (TECSA, 2018). Figure 3.3 presents a summary of the total capacity of electricity generation by fuel source.




Figure 3.3: Panama Electricity generation by fuel source, 2016

Panama is demarcated into three concession Zones which are each supplied by a distribution company. Empresa de Dstribucion Electrica Chiriquí, S.A. (EDECHI) which supplies the western zone, Empresa de Distribucion Electrica Metro Oestra, S.A. (EDEMET) supplies the central zone and Elektra Norste, S.A. (ENSA) which supplies the eastern zone.

Transmission of electricity is done by Empresa de Transision Electrica S.A (ETESA). Figure 3.4 shows the main transmission grid. In addition, there are interconnectors to Colombia and Costa Rica.



Figure 3.4: Main Transmission system in Panama (ETESA, 2017)

3.4.1 Electricity market in Panama

The privatization and change of the Panamanian energy sector in 1998, lead to the creation of a wholesale market. The wholesale market comprises of a contract market and occasional market. In the contract market, medium- and long-term energy and/or power transactions are agreed between the market agents for prices of energy and power.

The occasional market provides an opportunity for hourly energy and power transactions considering the surplus and deficiencies that arise as a result of the dispatch, contractual commitments and the reality of the demand and supply (ASEP, 2019).

3.4.2 Electricity prices

Consumer prices in Panama are considered stable since distribution companies are obliged to contract 100% of the energy that they forecast. Peak demand in panama is usually experienced during the day due to the use of air conditioning systems.

The spot price on Panamanian Electricity market is heavily influenced by oil prices. When oil prices are low, thermal powerplants sell their energy on the spot market influencing a lower spot price as the marginal cost reduces. Figure 3.5 shows the relationship between marginal cost, oil prices and hydropower contribution.




Figure 3.5: Marginal Costs vs International fuel costs and Hydrological contribution (TECSA, 2018)

Generally, the price of electricity in Panama has ranged between 15 to 20 U\$ cents/kWh as shown in the historical average electricity price in figure 3.6.




Figure 3.6: Historical average electricity price (U\$ cents) (TECSA, 2018)

3.5 Optimization of hydropower systems

Optimization is the maximization or minimization of a function to find the best result possible under given circumstances (Astolfi, 2006).

In hydropower systems, optimization of reservoir operations is a process that involves the allocation of resources, development of streamflow regulation strategies and operating rules as well as real-time release decision making which are set within the guidelines of the operating rules. Optimization models are used to determine values for a set of decision variables by maximizing or minimizing the objective functions subject to constraints (Wurbs, 1993).

The objective function and its constraints can be represented mathematically as linear or non-linear functions of the decision variable depending on the complexity of the system. Wurbs (1993) categorized objective functions into three main groups;

- Economic benefits and costs
- Water availability and reliability
- Hydroelectric power generation

The decision variables can be release rates while constraints include storage capacities, diversion or stream flow requirements and mass balances.

Literature with regards to optimization models and application to reservoir operations is extensive. Reservoir system studies are unique, and selection of the model depends on a number of considerations which include the characteristics of the application, analysis capabilities provided by alternative models and the background and preferences of the analysis (Wurbs, 1993). The following chapters provide an overview of optimization and simulation models; Vansimtap (EMPS) and prodrisk (commercial) and nMAG (open source) which have been developed in Norway.

3.5.1 Vansimtap

The vansimtap is a hydropower and reservoir operation simulation model which was developed by SINTEF. It has a two-step optimization and simulation solution of strategy evaluation and simulation of operational decisions. The strategy evaluation computes incremental water value based on the water value method for each market area by utilizing a combination of Stochastic dynamic programming (SDP) and heuristic approach for treating the interconnection between areas while the simulation conducts generation decisions based on the incremental values. (Warland et al., 2016).

The water value method is based on dynamic programming which evaluates future inflow conditions and the power market to estimate an economic value of water in a reservoir. Simulation in Vansimtap is based on modules which can be combined in series or parallel as a description of the physical structure of the model (Killingtveit, 1995).

The model is suited for long term scheduling which is aimed at evaluating the seasonal and multi/annual reservoirs. The seasonal model can be connected to a short-term production optimization (SHOP) for short-term planning of one to two weeks. The main input data is inflow time series, firm power demand and the spot-market.

3.5.2 Prodrisk

Prodrisk is a SINTEF model which is used for long and mid-term scheduling for a general detailed hydro representation. It is based on stochastic dual dynamic programming (SDDP) and uses a time resolution of one week and can be divided into load blocks of hourly resolution.

The model consists of a backward recursion and forward simulation where weekly decision problems are solved for each price, combination of the state for the previous time step, and combination of inflow. (Warland et al., 2016). Prodrisk uses a similar market and detailed hydro module as vansimtap which means they can both solve the same scheduling problem.

3.5.3 nMAG

nMAG is a simulation model for multiple reservoir hydropower production systems which was developed by Hydrotechnical Laboratory. Simulations in nMAG are based on the water balance equation in which the program runs an iterative procedure to determine a reservoir volume in each time step (Killingtveit, 1999).

The model uses modules or nodes to represent the various components of the power system represented in in figure 3.7. The modules are connected by links defining the movement of water in the production system.




Figure 3.7: Hydropower system simulation components ((Killingtveit, 1995)

nMAG consists of 4 module types that comprise of the Reservoir, Power plants, Interbasin transfers and control points.

3.5.4 Power plant

nMAG calculates the power and energy using the equation below.

$$\text{Energy: } E = Q(t) * 3600 * dt * EEKV \text{ (KWh)}$$

$$\text{Equivalent Energy: } EEKV = \eta * \rho * g * H_n / (1000 * 3600) \text{ (KWh/m}^3\text{)}$$

$$\text{Power: } P = E / dt \text{ (KW)}$$

Where $Q(t)$ is the discharge through the turbine during the time-step dt (m^3/s). dt is the length in hours of the one time-step. η total efficiency. ρ density of water (1000 kg/m^3). G gravity constant (9.81 m/s^2). H_n net head of water (m)

nMAG provides a more detailed description of the power plant with an option for optional data comprising of;

- Nominal head (m)
- Intake level (masl)
- Tailwater level (masl)
- Head loss coefficient (s^2/m^5)
- Total power plant efficiency

This is relevant only for power plants that operate with varying head or large variations of the maximum and minimum discharge. This means that the efficiency curve will not be constant and will therefore depend on the optimal data provided.

3.5.5 Energy market

nMAG has a simplified market with a constant price, different demand curves will be used to observe their effect on production. The demand curve distributes the firm energy over a period of time. nMAG provides three options for firm power distribution which consist of;

- Constant Firm Power,
- Daily load and
- Variable firm power

The Constant firm power distributes the energy equally over the period used for the simulation either day or week. The daily load specifies directly a percentage for each day with a simulation period of 365 days. For a varied seasonal distribution, the Variable firm power provides a distribution for a range of days in the simulation period.

3.5.6 Operational strategy

The operational strategy is key in optimizing the water resources. nMAG offers three operational strategies;

- Automatic reservoir balancing
- Reservoir release specification and
- Reservoir guide curve

Using the Automatic reservoir balancing, nMAG selects a water level that will optimize the output of the production. This is suited for small reservoirs where it can be a challenge to specify guide curves. As the name of the strategy specifies, there is no need for input to run it.

The reservoir release specification is used to specify average planned releases from the reservoir in terms of the volumetric flow rate with an annual distribution in percent.

The reservoir guide curve strategy is used to specify the amount of water the reservoir can contain at a time step throughout the year for economical use of the water. For this strategy, nMAG first assumes unconditional firm power demand. It then compares the deviation between actual

reservoir volume with the reservoir guide curve and decides whether a curtailment is needed, for a negative deviation, or to produce dump power for a positive deviation (Killingtveit, 1999).

3.6 Run-of-river schemes and climate change

Run-of-river hydropower schemes do not have large reservoirs for water storage as a result they generate much less energy than hydroelectric dams. These schemes can be used to provide baseload requirements and also respond to meet peak demand (Lindstrom, 2012).

During dry periods the production can reduce significantly due to depleted water levels which in turn has an impact on the plant capacity factor. It is therefore expected to have low production in the dry season. However, in the rainy season, the capacity factor increases due to high flow and this essential makes them suitable to contribute to base load in a mixed energy market.

One major impact on these schemes is that of climate change. During dry periods this significantly reduces the capacity factor of powerplants which directly impacts on revenue.

Climate change is considered as a phenomenon that affects the distant future. Studies on climate change in Central America show a reduction of future water resources. One such study conducted by Maricarmen (2016), shows an increase of 1°C in temperature and a decrease in rain and water resources for most of the countries in Central America. The decrease in water resources has been estimated on average as 12% for the period between 2020-2039 and 16% between 2040-2059.

4.0 Data and data analysis

The purpose of this chapter is to present the data provided and data analyses.

4.1 Hydrology data

The amount of water flowing in a river is essential for evaluating the water resource potential of a catchment. The quality of data determines the reliability of results in water resources evaluation. The Chiriquí Viejo basin has 4 hydrological stations used for volumetric flow rate monitoring. The stations are monitored by ETESA's hydrometeorology management. Table 4.1 shows the characteristics and data availability of the stations.

Table 4.1: Characteristics of gauging stations in Chiriquí Viejo watershed

Number	River	Location	Drain Area (Km ²)	Elevation (m)	Years Active	Days missing
102-01-01	CHIRIQUI VIEJO	VOLCAN	108	1533	1957 - 2019	406
102-01-02	CHIRIQUI VIEJO	PASO CANOA	788	85	1957 - 2018	1242
102-01-03	CHIRIQUI VIEJO	BAITUN	720	380	1957 - 2016	2213
102-02-01	CANDELA	RIO SERENO	56.8	870	1980 - 1998	204




Figure 4.1: Hydrological stations in Chiriquí Viejo Watershed

Candela gauging station has records of up to 1998 while Baitun, upstream of Bajo Frio ends in 2016. Volcan and Paso Canoas have data available up to 2019 and 2018, respectively, however Paso Canoas has no data for 2013 and 2014 and missing 508 data points between 2012 and 2018.

Different methods have been applied to fill the data pending on the severity of the data set. For single point missing data an average of the previous and adjacent value has been applied based on the equation below.

$$Q_m = (Q_{m-1} * f_i/f_{i-1} + Q_{m+1} * f_i/f_{i+1}) * 0.5$$

Where Q_m is the missing daily value
 Q_{m-1} is the previous day value
 Q_{m+1} is the adjacent value
 f_i is the distribution factor

for values greater than a month the filling has done by using the average of the time series for that particular month.

$$Q_m = Q_{m+1} * f_i/f_{i-1}$$

Where Q_m is the missing monthly value
 Q_m is the missing monthly value

There is an annual variation of 1500 million cubic meters between the lowest and highest annual average inflow for Paso Canoas and 220 million cubic meters for Volcan. Volcan inflows are approximately 10 % of Paso Canoas which is relative its location in the catchment.

Figure 4.4 shows the daily distribution of the inflow at Volcan and Paso Canoa. The daily distribution is similar to the annual distribution in which Volcan has an almost flat curve compared to Paso Canoa.




Figure 4.2: Annual Average flows for Paso Canoas and Pando (1957-2018)

It is essential to check the consistency of data as there can be changes in the operation of a gauging station due to changes in river sediment, physical temperament of measuring instruments and other factors that can cause erroneous data which can affect discharge computations. An accumulative Mass Curve has been used to check the consistency of data. Using visual inspection, Figure 4.3 shows no significant variation to indicate a shift in the discharge curve.




Figure 4.3: Accumulated Mass curve for Volcan (1957 – 2018)

4.1.1 El Alto Inflow

Hourly inflow has been provided by Hydro Caisan S.A. which runs the EL Alto power plant from 2014 to 2018. A cumulative plot shows seasonal undulations but no significant bend to indicate a shift in the Hydrograph.




Figure 4.4: Accumulated Mass curve for El alto inflow

4.2 Runoff scaling

Not every section of the river or stream can be measured. Gauging stations are located such that they can record the river flow based on a specific purpose. Scaling is a method used to transfer the flow from a point with observed data to a point of study. The scaling equation below has been used for scaling.

$$Q_s / (A_s * F_s) = Q_{obs} / (A_{obs} * F_{obs})$$

Where Q is the runoff

A is the Area

F is the mean annual runoff

Figure 4.5 shows the scaled El Alto inflow against the actual Pas Canoas flows




Figure 4.5: Scaled inflow (EL Alto) vs Actual inflow (Paso Canoas)

4.3 Generation and spot price data

Hourly generation data and spot prices has been provided by CND for the five power plants considered in the study. The data has a period from 2014 to 2018. Figure 4.6 illustrates the average daily average spot price for each year.




Figure 4.6 Daily average Spot Price Variation (USD/MWh)

4.4 Turbine efficiency curves

Most of the plants have a Francis turbine installed. Efficiencies have not been provided except for a Hill turbine for the Bajo Frio powerplants. A typical turbine efficiency curve based on literature (Vinnogg, 2003) has been used, figure 4.7.




Figure 4.7: Typical turbine efficiency curves

4.5 Head loss

In most cases, the head loss has not been provided. The alternative has been to estimate using the Manning's equations, which also used in nMAG, and data obtained from literature (CDM, 2011, 2014, 2018) to estimate the coefficient.

$$hl = kf * Q^2$$

Where kf is the head loss coefficient calculated as

$$kf = \frac{L}{n^2 * A^2 * R^3}$$

where A and L are the area and length of the conveying structure, i.e. pipe, tunnel. n the manning's number and R the hydraulic radius.

5.0 Spreadsheet model

One limitation of the study was accessibility of commercial programs. A spreadsheet model was therefore developed using Microsoft excel program to optimize hourly production and find strategies for production. The aim is to conduct simulations, test different reservoir strategies and to optimize production. The following chapters describe the model structure, simulation and optimization the reservoirs powerplants in the Cascade.

5.1 Model structure

The production system setup is such that each reservoir has inflow and releases from the reservoirs are used for energy production. Excess water in the reservoir is considered as spill. The reservoir is connected to a power plant that has a turbine.

The model comprises a number of spreadsheets which produce a specific output by utilizing different parameters, functions, including inflow, outflow, reservoir, Production, firm distribution, price, Optimizer and Results spreadsheets.

Four powerplants have been used in the model to simulate, strategize and optimize their reservoirs. Monte Lirio has no storage and is not included in the model. There are 4 modules which are described under the subsections of Hydrology, Reservoir operation, Production, Energy market, Optimization and Results modules.

5.1.1 Hydrology

Inflow

Inflow for all the power stations is based on hourly inflow from El Alto. The inflow for the downstream powerplants is computed by the summation of the total outflow of the upstream powerplant releases and local inflow to that power plant. Local inflow is computed by scaling of El Alto inflow using the equation presented in chapter 4.2.

$$Q_{in.} = Q_{out.} + Q_{local}$$

Where $Q_{out.}$ is the total water released from the upstream power plant and $Q_{local.}$ the inflow from the local catchment

Outflow

The total outflow is evaluated by using a mass balance of the production releases, the environmental flow and the spill.

$$Q_{out.} = Q_{turb.} + Q_{spill} + Q_{env.}$$

Where $Q_{out.}$ is the total water released to the downstream power plant. $Q_{prod.}$ the turbine releases. Q_{spill} the water spelt and $Q_{env.}$ Representing environmental releases.

5.1.2 Reservoir operation

The purpose of this module is to conduct simulation of the reservoirs using mass balancing of the inflows, outflows and storage fluctuations. The Continuity equation presented below has been used for each reservoir and in each time step to conduct a reservoir water balance.

$$S(t) = S(t-1) + Q_{in.}(t) - Q_{turb.}(t) - Q_{spill}(t) - Q_{env.}(t)$$

$S(t)$ the volume stored in the current time step. $S(t-1)$ the volume of water in the previous time step. $Q_{in.}(t)$ is the volume of water flowing into the reservoir in the current time step. $Q_{turb.}(t)$ the volume of water released through the turbines in the current time step. $Q_{spill}(t)$ the volume of water spill in the current time step and $Q_{env.}(t)$ which accounts for environmental flows.

In addition to the continuity equation, several functions and have been developed represented by non-equation relationships, that specify the limits and conditions for water release.

Reservoir storage

A boundary condition has been set for the reservoir to operate between the minimum and maximum reservoir storage which allows for spilling when at maximum and filling at minimum storage. The condition operates as follows;

If $(S(t-1) + X(t)) \geq S_{max}$. Spill; otherwise store water

$X(t)$ which specifies the gain or loss of water in that timestep computed by

$$X(t) = Q_{in}(t) - Q_{spill}(t) - Q_{env}(t)$$

$S(t)$ the volume stored in the current time step. $S(t-1)$ the volume of water in the previous time step. $Q_{spill}(t)$ the volume of water spill in the current time step and $Q_{env}(t)$ which accounts for environmental flows.

Reservoir runtime

The reservoir run time is a series of functions and conditions used to check if the amount of water in the reservoir is enough to run at full capacity. Two functions have been used to operate this criterion. The first function is used to compute the ratio of total outflow which includes the turbine capacity at full production and restrictions against the water available in storage in the previous time step and returns a value to either operate at full capacity or not.

If $(\text{storage}(t-1)/(\text{Turbine}(t) + \text{Env. } Q(t)) \geq 1$ return 1 if TRUE, 0 if FALSE

Minimum HPP runtime

The second function checks if the water available in storage for the previous time step can be used to operate at maximum production for a specific number of hours designated as the minimum runtime. If the power plant can only operate at full capacity when the minimum runtime of say, two hours, is specified then this function will check if this condition is fulfilled and allows the next two or more timesteps to operate at full capacity.

If $(\text{reservoir runtime} \geq \text{min runtime})$ return $>\text{min runtime}$, otherwise return 0

Regulation function

The regulation function is used to decide the amount of water that can be released to the power plant. The function operates by checking;

$$\text{if } (Q_{\text{in./firm}} + Q_{\text{env.}}) \geq S(t-1)$$

where $Q_{\text{in./firm}}(t)$ is the volume of water, the greater between the inflow to the reservoir or the firm capacity in the current time step. $Q_{\text{env.}}(t)$ the environmental flow in the current time step and $S(t-1)$ the volume of water in the previous time step

which if met checks whether the powerplant can run on full capacity from the minimum runtime. If not met the power plant can run on the maximum of firm and river inflow.

Production Capacity function

The variable of optimizing production is the amount of turbine releases in each planning period. The optimization in this study is based on the criteria of reservoir regulation where the most water is stored and allocated to a time of value, the time of value in this case is when either the spot price is either high or the reservoir storage is high.

An objective function defining the amount of release has been treated with weighting factors that depend on the reservoir and historical spot prices. The purpose of this function is to decide whether to allocate releases to the power plant or to store the water. The function is tested with different weights to determine the optimal release that can be achieved in the simulation period.

Water release have been set as a function of two variables, the reservoir filling criteria and the spot price difference. The two variables are used as the weighting factor to determine the optimal releases. The reservoir filling criteria determines how the reservoir will be operated by specifying the minimum reservoir operating capacity. The spot price difference is used to control releases depending on the difference in spot price of the current and next prices. The decision is met by using an OR function that releases water to the power plant if one of the two conditions is met as follows

$$\text{If } \text{OR}(S(t-1)/S_{\text{max.}} \geq R, P(t-1)/P_{\text{av.}}(24) \geq P) \text{ Release, Otherwise store}$$

Where $S(t-1)$ the volume (mill. m^3) of water in the previous time step. (R) reservoir filling criteria defining specifying the reservoir operating zone for the powerplant. $P(t-1)$ (USD/MWh) is the spot price in the current time step. $P_{av.(24)}$ average spot price (USD/MWh) for the next 24 hours and (P) spot price difference variable defining the ratio between the spot price in a time step against the average for the proceeding 24 hours which is used to decide if the average spot price is higher in the next time steps and decides whether or not to produce.

5.1.3 Energy calculations

Energy production

The production module is used to compute the energy generated from the releases from the reservoir module. The water released to the powerplant is first checked if it meets the minimum and maximum production capacity which when satisfied is used to compute the energy using the energy equation.

$$P = \rho g Q H \eta$$

Where ρ is the density of water (Kg/m^3), g is the acceleration due to gravity (m/s^2), Q is the water release to the turbines (m^3/s), H is the net head (m) of water and η is the total efficiency.

The net head is the summation of the gross head and the total head losses with the total head loss evaluated using the manning's equation.

$$hl = kf * Q^2$$

Where kf is the head loss coefficient calculated as

$$kf = \frac{L}{n^2 * A^2 * R^{\frac{4}{3}}}$$

where A and L are the area and length of the conveying structure, i.e. pipe, tunnel. n the manning's number and R the hydraulic radius.

5.1.4 Energy market

The energy market module consists of the firm power distribution and historical spot price inputs. The daily firm distribution curve is based on the average production distribution for the four plants in the cascade and redistributed hourly with an adjusted form curve

The spot price module comprises of the historical spot prices and another series of the averaged 24-hour spot prices from the next 24 hours

5.1.5 Optimization and Results

A macro has been used to run different sets of price difference and reservoir filling criteria. For each price difference, the macros test a range of the reservoir criteria and outputs the total production (GWh), average daily gross revenue (USD/day) which is the product of the energy and spot price over the simulation period, operation hours (%) and spill (%).

5.2 System setup

The simulation setup has been done for the four power plants as shown in figure 5.1. Inflows from El Alto have been used from 2016 to 2018 while turbine efficiency is based on the typical turbine curves, chapter 4.4.




Figure 5.1: Spreadsheet simulation setup

5.3 Calibration and validation model

The setup for the simulation is based on hourly inflow from El alto and a runtime of two hours. The main parameters adjusted are the reservoir filling criteria and the maximum power (MW). The filling criteria for all the reservoir has been set to start at 10% for all the reservoir. The calculated head loss coefficients have been adjusted to meet the maximum hourly observed energy.

The Panamanian market has zero spot prices. There is however no correlation between the zero prices and actual energy production as power plants are still producing during these hours. Two simulations have been tested to see the effects of zero pricing on production. Simulations have been tested on EL Alto power plant. Simulation one has a function that restricts the release of water when prices are zero while simulation two allows for firm production during zero pricing. Figure 5.2 shows the results of the two simulations.




Figure 5.2 Monthly Energy (MWh) comparison of simulations for zero pricing (USD/MWh)

The simulation with zero pricing, simulation one, gives a lower production at the end of the years 2016 and 2017. However, it gives a closer distribution between the May and September of 2017. Using correlation comparison between the simulated and observed, figure 5.3,




Figure 5.3 Scatter plot comparison for zero pricing simulations (MWh)

Simulation two gives a better correlation with the observed and performs better for the years 2016 and 2018. Therefore, the setup producing simulation two results has been adopted.

5.4 Simulation results and discussion

Running the initial setup produces a total generation of 100 GWh of the four power stations over the entire simulation period. The strategy generates a higher gross revenue of 9.4 million USD which is 5% more than the observed with a lower average power plant operation time of 4% when compared to the observed.

Table 5.1: Simulation Results for the period 2016 - 2018

	TOTAL GENERATION (GWH)		AV. SPILL (%)	AV. OPERATIONAL HOURS (%)		AV. GROSS REVENUE (MILL. USD)	
	Simulated	Observed	Simulated	Simulated	Observed	Simulated	Observed
EL ALTO	778	756	9.0	78	88	43.59	43.29
BAJO DE MINA	709	686	14.0	79	84	41.57	39.21
BAITUN	1074	1063	11.2	78	79	63.36	60.44
BAJO FRIO	679	636	15.7	82	81	40.76	36.93
TOTAL	3 240	3 140	12	79	83	189	180

The distribution of production for the power plants is similar with Bajo Frio producing 1% less which is taken up by Baitun, Figure 5.4




Figure 5.4: Total Generation: A is the simulated Energy (GWh) production. B. is the observed Energy production

Figure 5.5 shows the total monthly Energy production for the cascade.




Figure 5.5: Total Monthly Energy (GWh) for the El Alto, Bajo de Mina, Baitun and Bajo Frio and Monthly Average Spot Prices (USD/MWh)

Based on the 3-year simulation the initial model setup generates an average annual energy of 45 GWh, 4.3 % more than the observed production and a gross annual average of 6.4%.

5.5 Optimization results and discussion

Two optimization criteria of optimization have been tested to study the system. The first criteria is to maximize the production for the specified simulation period. The second criteria is to maximize the computed average daily revenue which has been used as the main criteria for optimization. The purpose is to, both, analyses the system response as well as the influence of the weighting factors on the reservoir and production based on the model's operation detailed in the previous sections.

5.5.1 Production maximization

Optimization of production gives a range of operation of the reservoirs in the cascade between 60 and 80% of the total volume. The weighting factor representing the price difference ranges between 1.2 and 1.8.

Table 5.2: Optimal price difference and reservoir regulation criteria variables

	RUN TIME	PRICE DIFF	RES FILLING
	(hrs)	(%)	(%)
EL ALTO	2	1.3	0.6
BAJO DE MINA	2	1.5	0.5
BAITUN	2	1.2	0.6
BAJO FRIO	2	1.8	0.8

The Bajo Frio powerplants produces the highest variable combination with a reservoir filling criterion of 0.8 and a price difference of 1.80, table 5.2. The reservoir must be kept high to reduce losses with frequent releases even at lower prices to maximize production as can be seen in figure 5.6 were the reservoir is being kept above 0.8 million cubic meters with the plant running several start/stop generation sequences.




Figure 5.6 :Optimized Bajo Frio reservoir water balance

Bajo de Mina also uses a high price difference variable, this trend is seen for small reservoirs with a lower peaking capacity. Baitun with a larger reservoir and peaking capacity produces the least price difference. table 5.3

Table 5.3: Reservoir Peaking hours

	CAPACITY (M3/S)	RESERVOIR VOLUME (MILL. M3)	PEAKING CAPACITY (HRS)
EL ALTO	60	1.1	5
BAJO DE MINA	56.5	0.87	4
BAITUN	75	2.48	9
LA POTRA	100	1.5	4

The operation time reduces on average by 31% when compared to the observed production in table 5.1 with a total increased production of 154 GWh for the entire simulation period.

Table 5.4: Optimization Results for the period 2016 - 2018

	TOTAL GENERATION (GWH)		AV. SPILL (%)	AV. OPERATIONAL HOURS (%)		AV. GROSS REVENUE (MILL. USD)	
	Simulated	Observed	Simulated	Simulated	Observed	Simulated	Observed
EL ALTO	784	756	9.6	48	88	45.93	43.29
BAJO DE MINA	710	686	15.0	54	84	43.61	39.21
BAITUN	1115	1063	12.6	53	79	70.01	60.44
BAJO FRIO	686	636	14.6	53	81	43.04	36.93
TOTAL	3 294	3 140	13	52	83	203	180

Figure 5.7 shows the annual average generation for the based on the optimized production.




Figure 5.7: Annual Average Energy (GWh) production maximization

In summary, using the production maximization increases the annual average production by 47 GWh which is 4.5 % higher than the observed and with an increased revenue of 12% for the simulation period.

5.5.2 Revenue maximization

Two strategies have been used for revenue optimization. The initial simulation setup is based on operating the power plant with a firm strategy and surplus which has been used for the first strategy. The second strategy is based on the assumption that the power plant will only operate at full capacity.

Strategy 1

Table 5.13 shows the variables for revenue optimization. The price difference variable decreases while the reservoir filling criteria reduces when compared to the production maximization.

Table 5.5: Optimal price difference and reservoir regulation criteria variables (Strategy 1)

	RUN TIME	PRICE DIFF	RES FILLING
	hrs	No.	No.
EL ALTO	2	1.1	0.9
BAJO DE MINA	2	1.1	0.7
BAITUN	2	1.0	0.9
LA POTRA	2	1.1	0.8

Bajo Frio and Bajo de Mina use a lower reservoir filling variable. The reservoir at Bajo Frio can be observed to be more stable than the one in figure 5.8 with longer production releases and less intermittent peaking.




Figure 5.8: Optimized Bajo Frio reservoir water balance (strategy 1)

The total generation is 115 GWh more than the observed, Table 5.6.

Table 5.6: Optimization Results for the period 2016 – 2018 (strategy 1)

	TOTAL GENERATION (GWH)		AV. SPILL (%)	AV. OPERATIONAL HOURS (%)		AV. GROSS REVENUE (MILL. USD)	
	Simulated	Observed	Simulated	Simulated	Observed	Simulated	Observed
EL ALTO	773	756	10.5	58	88	48.00	43.29
BAJO DE MINA	708	686	15.0	54	84	45.80	39.21
BAITUN	1105	1063	13.2	54	79	72.29	60.44
BAJO FRIO	669	636	14.6	54	81	44.20	36.93
TOTAL	3,255	3,140	13	55	83	210	179.87

The Energy production and revenue of the cascade increases by 3.7 %, and 17%. Figure 5.5 shows the annual average generation based on the optimized production. The total average energy increases by 37 GWh.




Figure 5.9: Annual Average Energy (GWh) for revenue maximization

Strategy 2

Table 5.7 presents the optimization variables from the second strategy. The values produced are the same as strategy one.

Table 5.7: Optimal price difference and reservoir regulation criteria variables (Strategy 1)

	RUN TIME	PRICE DIFF	RES FILLING
	hrs	No.	No.
EL ALTO	2	1.1	0.9
BAJO DE MINA	2	1.1	0.7
BAITUN	2	1.0	0.9
LA POTRA	2	1.1	0.8




Figure 5.10: Optimized Bajo Frio reservoir water balance (strategy 2)

The reservoir during the same period is showing more peaks compared to strategy one. However, the reservoir volume is kept more stable than strategy two.

The total annual energy is 115 GWh higher than the observed which is the same as strategy two.

Table 5.8: Optimization Results for the period 2016 – 2018 (strategy 1)

	TOTAL GENERATION (GWH)		SPILL (%)	OPERATIONAL HOURS (%)		GROSS REVENUE (MILL. USD)	
	Simulated	Observed	Simulated	Simulated	Observed	Simulated	Observed
EL ALTO	775	756	10.7	46	88	47.47	43.29
BAJO DE MINA	706	686	15.5	52	84	45.22	39.21
BAITUN	1105	1063	13.3	51	79	72.09	60.44
BAJO FRIO	669	636	14.8	52	81	44.06	36.93
LA POTRA	338	315	14.8	52	81	22.20	18.24
SALSIPUEDES	331	320		52	81	21.86	18.69
	3,255	3,140	14	50	83	209	179.87

However, strategy 2 produces 3.6% annually and a revenue of 16 % which is near to but lower than strategy one. The optimal strategy is to operate the cascade using strategy one.

6.0 NMAG Model

The purpose of this section is to review and study the entire powerplant system, compare the simulated production of the current and future setup and the impact of climate change on the production. A simulation for the entire production system has been run based on inflow and average demand distribution for the period 2016 to 2018 with the designed firm power demand.

6.1 nMAG system setup

The following section presents some of the considerations made for setting up the cascade in nMAG

6.1.1 El Alto Inflow

nMAG scales inflow based on the average annual runoff for a given time series. A time series of not less than 30 years is recommended for average annual inflow. The inflow provided by the powerplant companies is based on a historical time series. Since Inflow at El Alto is available from 2014, the time series was extended by scaling using Paso Canoas time series as explained in chapter 4.2. figure xx Shows the extended time series.




Figure 6.1: EL Alto extended inflow (1957 -2018)

6.1.2 Monte Lirio inflow

nMAG conducts water balance computations and transfers outflows to the next station. The inflow used at an upstream station will significantly affect the receiving station. Monte Lirio has no reservoir, the production is based on the inflow. The scaling of its inflow in is based on the hydrology from Volcan and El alto. The Using only the Volcan gauging station produces a near flat distribution between the dry and rainy season. El Alto has a better distribution that is similar to the actual production but produces a lower energy production in the dry season. Different weighting factors have been used to find the combination that gives a suitable distribution.




Figure 6.2: Reservoir guide curve for El Alto

A combination of the two stations has been used to adjust the inflow using weighting factors of the two stations. A combination of 35% of flows from El Alto and 65% from Volcan gives a suitable distribution which is tested against two other cases.




Figure 6.3: Simulated vs Observed Energy (MWh) for Monte Lirio, A. Based on El Alto inflow, B., 35% El Alto and 65% Volcan, C Volcan.

El Alto inflows are found to give a better correlation with the observed daily energy and have been used in the simulations. The rest of the power plants have been scaled in nMAG using El Alto inflow.

6.1.3 Firm Energy and distribution

The firm energy of the entire system is based on an allocated Firm power for each plant. Generally, all the power plants have a plant factor between the range of 0.40 and 0.50 except for Paso Ancho which is as high as 0.75. A firm distribution has been used based on the average of the 3 years used in the simulation.

6.1.4 Operational strategy

The operation strategy used is the automatic balance strategy which is recommended for small reservoirs in nMAG. The strategy is to produce the most energy from the available water.

6.2 Current production System

Figure 6.5 shows the nMAG setup of the current production system. La Potra auxiliary is used for generating energy from environmental flows. However, generation for this power plant is not include, since the generation data was not provided.




Figure 6.4: N MAG schematic representation of current system

An annual firm energy of 1157 GWh has been used in the simulation.

6.2.1 Simulation results and analysis

Figure 6.5 shows the total monthly simulated results for the 5 power plants. The production strategy in nMAG generates 8.7% (345 GWh) more energy compared to the observed for the simulation period 2016 – 2018.

Table 6.1: Simulated vs Observed Total Annual Energy (MWh)

	SIMULATED	OBSERVED	DIFFERENCE
2016	1,244	1,205	39
2017	1,646	1,400	247
2018	1,427	1,367	60
TOTAL	4,317	3,971	346




Figure 6.5: Total Energy (GWh) Monte Lirio, El Alto, Bajo de Mina, Baitun and Bajo Frio

The trend is similar to that generated from the spreadsheet model where 2017 is producing more Energy compared to the other two years. The months of May to September 2017 show a deviation from the observed data as shown in figure 6.6 with 2017 giving the highest deviation.




Figure 6.6: total Annual Energy (GWh) difference of Observed from Simulated Energy

Table 6.2 shows the annual average generation of the powerplants.

Table 6.2: Annual Average Energy (GWh)

	AVERAGE ANNUAL ENERGY (GWH)	
	Simulated	Observed
MONTE LIRIO	291	277
EL ALTO	276	252
BAJO DE MINA	244	228
BAITUN	384	354
BAJO FRIO	230	212
TOTAL	1425	1324

EL Alto power plant has been used to compare the daily production as it has the actual inflow. nMAG is constantly generating for some months with high inflow in all the years which gives a much higher annual average energy of 101 GWh (8%) more than the observed.




Figure 6.7: El Alto Average Daily Simulated vs Observed Production (MW)

6.3 Future production system

The future production system will include Pando and Burica which have been added to the current system setup in nMAG. Figure 6.8 shows the layout of the powerplants in the future.




Figure 6.8: N MAG schematic representation of Future system

The future system has been set with the same firm distribution as the current setup but with a firm Energy allocation of 1656 GWh.

6.3.1 Simulation results and analysis

The Annual average production of the Chiriquí Viejo basin increases by 528 GWh annually based on these power plants in the study. The introduction of a regulation at Pando power plant upstream of Monte Lirio increases production at Monte Lirio by 0.4 GWh (0.1%) and 0.2 GWh for both Bajo de Mina and Baitun.

Table 6.3: Annual Average Energy (GWh) - Current vs Future Production System

ANNUAL AVERAGE (GWH)			
	Current	Future	Difference
PANDO		231.1	
MONTE LIRIO	290.8	291.2	0.40
EL ALTO	275.8	275.8	-
BAJO DE MINA	244.2	244.3	0.10
BAITUN	384.1	384.2	0.10
BAJO FRIO	230.2	230.2	-
BURICA		296.6	

Comparing the difference in production of Monte Lirio based on the Current and Future setup shows increased production in the rainy season. Since there will be regulation taking place at Pando, the effect of storage increases production to Monte Lirio based on the strategy in nMAG.




Figure 6.9: Monte Lirio difference in production between current and future system (MWh)

6.4 Climate change impact on Production

nMAG has been used to conduct simulations of production based on these estimates with the future setup created in chapter 6.3. The simulation is based on the year 2039 with a 12% reduction of inflow and assuming all the power plants will be in operation after 40 years.

The 12% reduction in inflow reduction does not significantly change the future production as shown in table 6.4. Therefore, using a strategy of maximizing production will be able to meet the demand unless otherwise affected by changes in consumption needs and energy regulation.

Table 6.4: Impact of Climate change on Future production

	ANNUAL AVERAGE (GWH)	
	Current	Future (climate)
PANDO	231.1	231.1
MONTE LIRIO	291.2	291.2
EL ALTO	275.8	275.8
BAJO DE MINA	244.3	244.3
BAITUN	384.2	384.2
BAJO FRIO	230.2	230.2
BURICA	296.6	296.6

7.0 Conclusion and recommendations

A spreadsheet model and nMAG have been used to simulate and optimize production in the Chiriquí Viejo basin. The optimal reservoir operation is found to be between 50% and 90% of reservoir capacity on average for the cascade. The Annual average energy for four power plants with storages is increased by 3.7% (37 GWh) with reduced operational time of 28% when revenue is optimized.

Using the production strategy in nMAG generates high annual average production as it generates as much as possible with the water available giving an increased annual average energy of 101 GWh which is 8% more than the observed. The generation for the four power plants with storage in nMAG produces 88 GWh more of the actual annual average energy which is twice the amount generated in the spreadsheet.

The spreadsheet model is seen to improve the daily generation distribution in the months nMAG is producing at maximum throughout a period, the model takes into consideration factors of pricing, hourly demand, and reservoir filling considerations to determine production releases. However, both models are simplified and based on linearity using production models with dynamic modelling capabilities and advanced optimizers can provide for a better optimal production and economic benefit.

Climate change simulations in chapter 6.4 show no significant influence on the production. The strategy in nMAG is capable of utilizing the reduced inflow and meet firm demand.

8.0 REFERENCES


- ANGUIZOLA, G., GORDON, B., L., MILLET, R., L.,. 2019. *Panama* [Online]. Encyclopædia Britannica. Available: <https://www.britannica.com/place/Panama> [Accessed 20/01/2019 2019].
- ASEP. 2019. *Wholesale electricity market* [Online]. Available: https://www.asep.gob.pa/?page_id=12911 [Accessed 8/3/2019 2019].
- ASTOLFI, A. 2006. OPTIMIZATION An Introduction.
- CIA. 2019. *Central America: Panama* [Online]. Available: https://www.cia.gov/library/publications/the-world-factbook/geos/print_pm.html [Accessed 29/1/2019 2019].
- CIMATE-DATA.ORG. 2019. *Climate Chiriquí Viejo* [Online]. AM Onlin Projects. Available: <https://en.climate-data.org/north-america/panama/chiriqui/chiriqui-viejo-775425/> [Accessed 20/01/2019 2019].
- CMD. 2011. *Bajo Frio Hydropower Project* [Online]. Available: <https://cdm.unfccc.int/Projects/DB/DNV-CUK1332935505.83/view> [Accessed 03/03/2019 2019].
- CMD. 2014a. *Baitun Hydroelectric Project* [Online]. Available: <https://cdm.unfccc.int/Projects/DB/DNV-CUK1366783821.49/view> [Accessed 03/03/2019].
- CMD. 2014b. *EL Alto Hydroelectric Project* [Online]. Available: <https://cdm.unfccc.int/Projects/Validation/DB/VS6L3RU79K6LVWO9WHJFQ1JWERZ/ZFD/view.html> [Accessed 03/03/2019 2019].
- CMD. 2018. *Pando and Monte Lirio Hydroelectric Plants* [Online]. Available: <https://cdm.unfccc.int/Projects/DB/LRQA%20Ltd1476356607.67/view> [Accessed 03/03/2019 2019].
- DIEGO, A., GONZALEZ JAEN 2008. Resumen tecnico analisis regional de crecidas maximas de panama period 1971 - 2006.
- ELECTRIC POWER DEVELOPMENT CO., L., NIPPON KOEI CO., LTD. 2004. *Study of Hydropower Optimization in Sri Lanka* [Online]. Tokyo, Japan. Available: http://open_jicareport.jica.go.jp/pdf/11750650.pdf [Accessed 4/4/2019 FIna report summary].
- ETESA. 2019. Available: http://www.hidromet.com.pa/open_data.php?id=1020102&t_est=S&clase_dato=1&periodicidad=3&sensor=CAUDAL [Accessed 03/02/2019 2019].

- IRENA 2018. *Renewables Readiness Assessment: Panama*, Abu Dhabi, International Renewable Energy Agency.
- KACZMAREK, Z., KINDLER, J., 1982. The Operation of multiple reservoir systems. *IIASA collaborative paper*.
- KILLINGTVEIT, Å. 1999. *nMAG A computer program for hydropower and reservoir operation simulation*.
- KILLINGTVEIT, Å., SÆLTHUN, N., R., 1995. *Hydrology*, N-7034 Trondheim, Norwegian institute of Technology, Division of Hydraulic Engineering.
- LINDSTROM, A., GRANIT, J., WEINBERG, J. 2012. Large-Scale water storage in the water, energy and food nexus: Perspectives on benefits, risks and best practices. *SIWI*, Paper 21, Stockholm.
- MARICARMEN, E., GRUNWALDT, A., PAREDES R, A., RODRIGUEZ-FLORES, E., 2016. Vulnerability to climate change of hydroelectric production systems in central america and their adaptation options. *Climate change sector and Energ*, 7 - 10.
- SHENGLIAN, G., XIANG, L., PAN, L. & FUQIANG, G. 2009. Optimal Operation of Cascade Hydropower Plants.
- TECSA 2018. Panama Electric Market Update, Key Regulations and Outlook for future Power Generation Projects 2018-2032.
- VINNOGG, A., ELSTAD, I., 2003. Mechanical Equipment. *Hydropower Development*. N-7034 Trondheim: Norwegian University of Science and Technology, Department of Hydraulic and Environmental Engineering.
- WARLAND, G., HENDEN, A. L. & MO, B. 2016. Use of Parallel Processing in Applications for Hydro Power Scheduling – Current Status and Future Challenges.
- WOOD, A., VISCIDI, L., FARGO, A., 2018. LNG IN THE AMERICAS. How commercial, Technological and Policy Trends are shaping regional Trade. *The Dialogue*, 12-14.
- WOODS, S. 2009. *Panama*, Bradt Travel Guides.
- WURBS, R. A. 1993. Reservoir-System Simulation and Optimization Models. *Journal of Water Resources Planning and Management*, 119, 2637.

9.0 APPENDIX

Appendix I

Systematic layout of hydropower plants in Chiriqui viejo



APPENDIX II

Daily Summary Of El Alto Inflow (m3/s)

year	month	day											
		1	2	3	4	5	6	7	8	9	10	11	12
2016	1	16.8	11.7	11.9	11.8	16.3	30.5	29.2	17.9	35.2	27.0	55.9	96.9
2016	2	15.6	11.6	11.6	11.7	15.7	47.8	23.3	21.3	30.1	33.5	50.8	84.4
2016	3	16.5	11.5	11.2	10.4	20.2	60.9	21.6	20.2	27.6	33.7	43.8	64.7
2016	4	18.4	11.5	10.2	9.4	16.5	46.9	20.9	20.3	27.0	30.6	38.3	74.0
2016	5	16.9	11.5	11.2	9.8	14.6	29.9	24.4	19.2	28.4	32.1	34.8	91.4
2016	6	15.8	11.2	11.8	9.4	14.3	30.6	19.9	18.2	25.6	42.0	47.1	56.2
2016	7	15.7	11.4	11.1	9.1	17.8	28.4	20.5	19.7	27.6	44.6	43.0	48.9
2016	8	15.6	10.6	11.2	9.1	16.3	45.1	51.8	19.6	25.3	54.7	37.4	51.3
2016	9	15.6	11.1	10.6	8.9	15.8	51.4	19.4	20.1	26.7	75.7	34.9	49.3
2016	10	14.6	24.5	10.6	8.8	14.8	41.0	21.5	18.8	31.8	84.6	32.5	50.0
2016	11	14.3	41.2	10.1	9.3	13.2	39.2	24.1	20.1	29.9	79.0	31.4	49.9
2016	12	14.2	30.3	10.2	8.8	12.6	34.4	28.3	23.4	48.3	66.0	31.5	47.3
2016	13	13.8	19.0	9.4	8.7	12.1	30.1	21.7	23.4	68.5	67.4	30.8	40.1
2016	14	13.9	15.3	11.3	8.9	12.3	37.1	23.2	27.9	40.0	49.5	35.8	37.6
2016	15	13.6	13.9	9.9	9.4	12.7	38.5	26.5	24.6	39.5	46.4	38.7	35.9
2016	16	13.4	13.2	9.7	9.8	11.4	45.7	24.4	21.9	39.1	48.7	44.2	35.5
2016	17	13.2	12.7	9.5	10.5	14.0	38.9	23.7	20.6	35.1	47.1	107.5	40.6
2016	18	12.9	12.7	10.1	9.8	12.6	38.6	29.4	21.0	30.7	44.2	88.3	33.7
2016	19	12.6	29.6	9.5	10.8	12.5	36.9	29.4	22.7	29.0	39.2	123.1	31.2
2016	20	12.5	18.0	9.6	12.1	11.6	30.5	23.6	27.2	29.0	36.7	106.2	32.3
2016	21	14.0	15.1	9.6	10.8	11.0	31.7	21.9	27.4	32.6	39.5	103.5	31.7
2016	22	13.5	13.6	10.5	12.1	12.3	35.1	21.1	26.5	33.1	38.2	89.7	29.5
2016	23	12.8	12.8	10.2	12.3	11.9	35.9	23.9	24.7	28.0	34.5	107.2	28.8
2016	24	13.2	13.2	9.7	11.5	12.3	29.3	21.9	21.4	27.0	31.7	116.8	27.7
2016	25	18.9	12.0	9.5	11.1	14.1	27.0	19.7	23.0	38.6	30.0	110.5	26.7
2016	26	14.8	11.9	9.6	13.0	19.8	26.7	18.5	35.7	33.4	32.5	102.0	26.0
2016	27	13.0	14.8	9.3	16.6	20.0	24.7	18.6	34.3	34.0	34.6	95.7	46.9
2016	28	12.7	13.3	9.9	15.9	27.2	23.4	24.7	28.5	31.3	33.7	97.9	49.2
2016	29	12.1	12.4	10.3	19.4	29.0	22.8	22.0	41.0	28.0	35.7	101.9	28.4
2016	30	11.9		10.6	17.5	22.6	21.4	20.3	42.2	26.3	56.8	101.1	25.4
2016	31	11.8		10.2		30.3		19.0	38.7		62.5		23.9
2017	1	23.5	14.9	11.5	10.2	12.6	54.0	54.8	42.3	36.1	110.4	34.7	38.1
2017	2	23.9	15.5	11.8	12.3	21.6	43.0	40.2	32.1	31.2	99.8	34.8	36.6
2017	3	22.7	14.1	11.8	11.5	21.1	37.5	40.0	30.1	39.1	92.8	32.9	33.7
2017	4	21.9	13.5	15.0	12.9	31.2	36.2	39.7	32.0	32.7	108.8	32.8	33.6
2017	5	20.1	15.2	13.5	11.3	43.8	41.5	52.1	29.2	32.6	174.3	31.6	32.9
2017	6	19.9	15.2	20.1	10.4	43.0	42.2	40.7	30.5	30.3	139.4	32.6	32.6
2017	7	18.9	14.4	18.2	10.9	55.9	38.8	34.1	40.5	30.6	130.3	30.5	30.8
2017	8	19.2	14.4	15.6	11.0	38.2	52.0	32.5	37.0	36.8	119.0	31.8	29.7
2017	9	72.6	13.4	13.3	11.0	63.0	77.4	32.9	46.1	36.3	108.2	29.0	33.2

2017	10	34.6	13.4	13.2	10.2	35.9	71.2	36.8	58.9	35.2	84.8	28.7	86.3
2017	11	29.3	13.8	13.5	10.8	36.1	43.2	60.9	46.1	33.0	55.5	34.2	110.4
2017	12	24.7	13.3	14.3	10.8	34.4	39.3	76.8	42.0	37.7	53.6	34.0	107.3
2017	13	24.2	13.9	12.0	10.4	29.7	54.5	58.8	44.2	31.6	46.0	34.9	77.1
2017	14	35.9	14.1	11.7	10.9	27.8	71.1	47.5	50.8	30.9	43.5	33.6	47.4
2017	15	27.4	13.8	11.8	10.2	24.3	57.2	33.6	37.1	42.4	41.1	42.9	37.3
2017	16	23.7	14.9	12.3	10.9	27.6	90.0	30.5	35.2	43.5	36.7	63.0	34.5
2017	17	21.9	16.4	10.9	13.6	29.8	71.6	30.5	33.7	71.2	33.6	48.5	32.3
2017	18	19.8	14.7	11.4	14.0	43.3	67.6	30.9	52.7	82.8	39.2	37.4	29.6
2017	19	19.6	14.3	11.6	16.7	58.4	59.4	28.3	54.1	71.7	32.2	40.4	28.9
2017	20	18.2	13.4	10.9	17.2	67.0	44.9	26.3	65.6	93.5	34.6	42.3	29.9
2017	21	17.5	13.7	10.1	13.4	44.6	47.0	27.0	72.6	89.1	39.8	72.8	32.8
2017	22	17.4	14.1	12.8	11.9	36.6	41.9	27.2	53.5	94.6	39.3	89.9	27.2
2017	23	16.7	12.6	11.6	12.9	43.8	37.6	26.7	39.8	104.4	48.2	111.1	30.8
2017	24	15.9	12.2	12.3	13.2	33.5	34.9	24.8	37.6	103.9	55.5	75.7	32.2
2017	25	16.1	15.8	13.3	16.4	38.5	38.6	25.6	40.2	112.2	83.7	56.9	30.7
2017	26	15.5	14.1	11.9	17.2	38.8	39.8	27.0	35.6	102.6	48.0	51.0	28.8
2017	27	14.9	12.5	11.4	13.9	39.3	52.2	26.9	34.5	99.3	45.4	45.7	25.0
2017	28	14.8	12.0	11.4	11.9	54.8	76.4	28.3	37.3	105.4	39.2	44.4	24.7
2017	29	14.8		11.2	11.4	59.7	61.6	36.7	38.6	106.6	39.3	44.4	24.2
2017	30	14.1		10.8	11.8	88.6	61.1	48.2	49.3	114.5	42.3	42.2	26.4
2017	31	14.4		11.5		79.4		69.5	49.7		37.1		31.4
2018	1	36.4	26.6	14.8	12.6	15.4	32.9	42.6	39.4	28.9	56.6	41.4	22.2
2018	2	25.9	24.8	15.2	12.3	16.5	38.0	42.4	67.0	25.8	60.7	41.9	22.6
2018	3	27.6	20.6	15.1	12.1	14.2	40.7	36.7	60.8	22.2	50.7	37.1	24.3
2018	4	28.2	21.5	14.7	14.3	14.6	36.5	34.3	44.4	22.7	61.8	75.8	23.1
2018	5	39.8	19.2	14.1	12.5	15.1	32.5	31.8	38.3	29.0	109.0	77.4	21.1
2018	6	37.3	19.4	14.3	15.3	14.7	30.1	38.6	35.8	41.1	127.7	53.4	21.1
2018	7	61.4	18.6	13.7	16.6	15.6	33.1	35.7	35.7	44.6	82.5	46.4	22.6
2018	8	61.8	17.7	13.7	16.9	15.5	29.1	32.6	31.5	48.0	60.1	40.5	20.5
2018	9	34.2	17.8	14.1	15.2	14.3	28.9	29.8	30.4	62.9	51.4	40.5	19.5
2018	10	31.1	18.1	15.0	14.8	14.6	27.7	29.8	31.7	54.0	46.3	38.0	18.9
2018	11	29.0	17.7	14.0	21.0	14.5	26.5	27.8	29.0	42.9	57.7	34.9	19.0
2018	12	26.9	16.6	13.2	17.1	14.5	29.9	25.8	27.2	39.2	71.5	35.2	18.2
2018	13	25.4	21.3	14.3	19.2	27.7	27.9	26.3	26.1	39.1	67.1	33.3	17.9
2018	14	26.9	17.6	13.9	16.5	24.3	29.7	36.9	26.5	34.0	74.0	33.7	17.8
2018	15	40.5	18.5	13.1	17.0	20.0	52.4	43.4	26.1	42.3	83.3	36.0	17.1
2018	16	35.2	19.0	13.1	15.1	24.2	57.7	40.7	26.2	42.7	72.1	34.1	17.9
2018	17	27.3	19.1	12.7	14.0	27.4	65.1	35.3	24.6	38.0	78.8	29.5	17.0
2018	18	26.6	18.5	12.9	14.2	36.1	49.8	32.0	23.5	31.9	116.7	31.1	16.4
2018	19	26.9	17.8	12.2	12.4	40.9	45.9	30.1	23.4	31.1	101.4	29.5	17.1
2018	20	35.5	16.7	12.8	12.3	38.3	50.6	29.7	21.4	29.6	88.3	33.8	17.2
2018	21	31.6	18.9	12.6	12.6	41.2	48.1	29.3	21.1	36.7	81.1	35.5	16.1
2018	22	30.1	19.0	11.4	12.7	40.8	40.6	27.3	22.2	29.7	89.3	32.1	17.8
2018	23	26.9	18.6	12.3	12.4	41.6	45.6	28.2	21.0	30.6	75.8	29.0	19.4
2018	24	24.7	17.8	12.4	13.2	36.9	67.2	24.2	21.6	38.8	60.5	27.8	17.1

2018	25	24.7	17.9	12.7	13.7	33.3	42.5	27.9	20.9	38.3	69.4	25.3	17.3
2018	26	23.6	16.5	11.9	13.1	59.1	41.7	27.6	22.8	39.8	56.9	25.6	15.8
2018	27	22.5	16.0	11.4	15.6	56.0	38.6	36.4	22.7	44.8	51.1	24.3	16.0
2018	28	21.1	15.7	11.4	16.3	40.0	56.0	33.2	24.0	56.2	49.1	24.1	15.8
2018	29	20.2		11.4	19.4	43.7	67.8	32.8	27.0	52.1	51.6	24.8	15.2
2018	30	21.0		11.5	17.3	41.8	49.9	33.7	24.1	56.8	45.7	23.6	14.6
2018	31	26.2		13.6		36.0		28.7	22.4		39.2		15.1


APPENDIX III

Monthly Summary of Generation (Mwh)

Year	Month	Monte Lirio	El Alto	Bajo de Mina	Baitun	La Potra	Salsipuedes
2016	1	15964	9497	8512	11659	2864	3022
2016	2	16586	9711	8397	10427	2409	2534
2016	3	10502	6127	5358	6586	1672	1774
2016	4	11453	6523	5573	8052	2130	2247
2016	5	17297	11003	9402	14911	4616	4963
2016	6	25861	26227	23434	39280	11886	12382
2016	7	24828	16655	15396	26204	8248	8853
2016	8	21215	18662	16947	27937	9030	9650
2016	9	25434	23870	22396	37144	10956	11654
2016	10	32490	33661	30876	48504	14482	14842
2016	11	26744	33752	32907	51974	14695	14961
2016	12	28366	30127	27493	40976	11860	12253
2017	1	21273	15922	13930	19633	5012	5360
2017	2	14499	8334	6417	8732	2272	2379
2017	3	13552	8155	7149	9263	2456	2516
2017	4	13889	7565	6593	9998	2976	3051
2017	5	29016	27358	24119	37721	11543	11745
2017	6	29959	33165	29080	46041	15082	12531
2017	7	24013	23521	22174	34170	10142	10051
2017	8	25842	28645	26426	42212	12621	12885
2017	9	20706	27765	25776	40430	11758	11874
2017	10	23568	36937	31265	52214	14535	14931
2017	11	32555	30672	27938	46422	14545	15047
2017	12	28553	25693	22932	33181	9054	9521
2018	1	27281	21911	19414	25829	6621	6823
2018	2	20501	11579	10287	13418	3356	3387
2018	3	15139	8047	7120	8999	2242	2291
2018	4	15981	9221	8355	12661	3828	3777
2018	5	20764	20386	18333	28383	8501	8805
2018	6	30980	29581	27661	39509	13548	13972
2018	7	31188	24426	22908	37827	11608	11967
2018	8	24499	21365	19936	32704	10710	11066
2018	9	28779	28107	26134	42735	13380	13858
2018	10	33637	44091	39517	61270	17970	15903
2018	11	29826	25053	24171	38381	11321	11741
2018	12	19905	12511	11240	17598	5433	5690

APPENDIX III

Monthly Summary of Spot prices (USD/MWh)



APPENDIX IV

Optimization Macro

Sub test()

Application.ScreenUpdating = False

n = 1

For pdif = 0.5 To 0.8 Step 0.1

Sheets("reservoir").Cells(5, 6) = pdif

For fil = 0.5 To 1 Step 0.1

Sheets("reservoir").Cells(5, 8) = fil

n = n + 1

Sheets("OPTIM").Cells(n, 1) = pdif

Sheets("OPTIM").Cells(n, 2) = fil

Sheets("OPTIM").Cells(n, 3) = Sheets("reservoir").Cells(2, 17)

Sheets("OPTIM").Cells(n, 4) = Sheets("reservoir").Cells(4, 19)

Sheets("OPTIM").Cells(n, 5) = Sheets("reservoir").Cells(4, 17)

Next fil


Next pdif

End Sub


APPENDIX IV

SPREADSHEET SIMULATION RESULTS

EL ALTO DAILY SIMULATION (MW)



EL ALTO MONTHLY SIMULATION (GWh)



EL ALTO INITIAL SIMULATION

	Annual Energy (GWh)		Gross Revenue (mill USD)	
	Simulated	Observed	Simulated	Observed
2016	226	226	12.11	12.43
2017	292	274	13.64	13.24
2018	260	256	17.84	17.62


EL ALTO PRODUCTION MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	229	226	12.91	12.43
2017	292	274	14.59	13.24
2018	262	256	18.44	17.62


EL ALTO REVENUE MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	227	226	13.50	12.43
2017	289	274	15.35	13.24
2018	258	256	19.17	17.62

BAJO DE MINA DAILY SIMULATION (MW)



BAJO DE MINA MONTHLY SIMULATION (GWh)



BAJO DE MINA INITIAL SIMULATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	207	207	11.53	11.20
2017	261	244	13.01	11.84
2018	241	235	17.04	16.17


BAJO DE MINA PRODUCTION MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	209	207	12.28	11.20
2017	260	244	13.91	11.84
2018	241	235	17.41	16.17


BAJO DE MINA REVENUE MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Observed	Simulated	Observed	Simulated
2016	208	207	12.93	11.20
2017	259	244	14.56	11.84
2018	241	235	18.31	16.17

BAITUN DAILY SIMULATION (MW)



BAITUN MONTHLY SIMULATION (GWh)



BAITUN INITIAL SIMULATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	323	324	18.15	17.56
2017	416	380	20.87	18.28
2018	379	359	26.97	24.59


BAITUN PRODUCTION MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	326	324	19.62	17.56
2017	411	380	22.64	18.28
2018	378	359	27.75	24.59


BAITUN REVENUE MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Observed	Simulated	Observed	Simulated
2016	323	324	20.33	17.56
2017	407	380	23.18	18.28
2018	374	359	28.79	24.59

LA POTRA DAILY SIMULATION (MW)



LA POTRA MONTHLY SIMULATION (GWh)



LA POTRA INITIAL SIMULATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	95	95	5.42	5.18
2017	123	112	6.27	5.46
2018	112	109	8.06	7.59


LA POTRA PRODUCTION MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	100	95	6.01	5.18
2017	124	112	6.85	5.46
2018	116	109	8.51	7.59


LA POTRA REVENUE MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Observed	Simulated	Observed	Simulated
2016	99	95	6.30	5.18
2017	124	112	7.15	5.46
2018	115	109	8.90	7.59

SALSIPUEDES DAILY SIMULATION (MW)



SALSIPUEDES MONTHLY SIMULATION (GWh)



LA POTRA INITIAL SIMULATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	99	99	5.64	5.44
2017	125	112	6.45	5.55
2018	115	109	8.33	7.69

SALSIPUEDES PRODUCTION MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Simulated	Observed	Simulated	Observed
2016	97	99	5.85	5.44
2017	121	112	6.66	5.55
2018	113	109	8.28	7.69


SALSIPUEDES REVENUE MAXIMIZATION

	Annual Energy (GWh)		Gross Revenue(mill USD)	
	Observed	Simulated	Observed	Simulated
2016	97	99	6.20	5.44
2017	121	112	7.01	5.55
2018	113	109	8.72	7.69


APPENDIX IV

NMAG SIMULATIONS


MONTE LIRIO MONTHLY ENERGY SIMULATION




EL ALTO MONTHLY ENERGY SIMULATION




BAJO DE MINA MONTHLY ENERGY SIMULATION



BAITUN MONTHLY ENERGY SIMULATION



LA POTRA MONTHLY ENERGY SIMULATION



SALSIPUEDES MONTHLY ENERGY SIMULATION

