

## AMEV attestation for certified BACnet devices

### 1. The following BACnet device is certified as per DIN EN ISO 16484-5:

Supplier	Honeywell GmbH		
Product name	CentraLine EAGLE		
Product model number	CLEA2014B22, CLEA2014B02, CLEA2026B21, CLEA2026B01, CLEA2000B21, CLEA2000B01, CLEA2000B31, CLEA2014B32, CLEA2026B31		
Standard device profile	B-BC	BACnet protocol vers. / rev.	1.12
Firmware revision	12-00-04		

Data Link Layer options	<input checked="" type="checkbox"/> BACnet IP (Annex J)	<input type="checkbox"/> BACnet over LonTalk
	<input checked="" type="checkbox"/> BACnet MS/TP master	<input type="checkbox"/> BACnet MS/TP slave
	<input checked="" type="checkbox"/> MS/TP baud rates: 9600, 38400, 57600, 76800, 115200	
	<input type="checkbox"/> .....	
Static device binding	<input type="checkbox"/> Yes (for MS/TP only)	
Network options	<input checked="" type="checkbox"/> BBMD	<input checked="" type="checkbox"/> Reg. by foreign device
	<input type="checkbox"/> Router, medium: BACnet/IP	
Character sets	<input checked="" type="checkbox"/> UTF-8	<input checked="" type="checkbox"/> ANSI X3.4
Reporting options	<input checked="" type="checkbox"/> Intrinsic reporting	<input checked="" type="checkbox"/> Algorithmic reporting

### 2. The device supports BACnet functions as per AMEV profile:

<input checked="" type="checkbox"/> AMEV profile AS-A (Automation station, base version)	As of: v.1.1 21.08.2012
<input type="checkbox"/> AMEV profile AS-B (Automation station, extended version)	As of: .....
<input type="checkbox"/> AMEV profile .....	As of: .....

### 3. Basis for AMEV attestation:

<input checked="" type="checkbox"/> Test report of test lab MBS dated 07.02.2014 number VG 2013_7800
<input checked="" type="checkbox"/> AMEV recommendation BACnet v.1.1 As of: 21.08.2012 (see <a href="http://www.amev-online.de">www.amev-online.de</a> )

### 4. The AMEV attestation is only valid in combination with the certificate:

<input checked="" type="checkbox"/> Certificate number BAC-0104 (see <a href="http://www.big-eu.org/conformance/eu/index.php">http://www.big-eu.org/conformance/eu/index.php</a> )
--

Stuttgart, 21.03.2014

  
.....  
(AMEV chairman BACnet)

  
.....  
(BACnet certification body)

**WSP Cert**  
Dr.-Ing. Harald Bitter &  
Dr.-Ing. Frank Bitter PartG.  
Kapuzinerweg 7  
D-70374 Stuttgart  
Telefon +49 711 953922-0  
Telefax +49 711 953922-66