

Sindre Haakenstad
Victoria Omholt

Central Heating System Design Constant Versus Dynamic Flow


Bachelor's thesis in Product and System Design

Supervisor: Lars Petter Bryne

Co-supervisor: Terje Ottersen & Runar Fiske

May 2023

NTNU
Norwegian University of Science and Technology
Faculty of Engineering
Department of Ocean Operations and Civil Engineering



Sindre Haakenstad
Victoria Omholt

Central Heating System Design Constant Versus Dynamic Flow

Bachelor's thesis in Product and System Design
Supervisor: Lars Petter Bryne
Co-supervisor: Terje Ottersen & Runar Fiske
May 2023

Norwegian University of Science and Technology
Faculty of Engineering
Department of Ocean Operations and Civil Engineering



1 Sammendrag

Sentralvarmesystemet ombord et servicefartøy er et system som henter overskuddsvarme fra motorene samt produserer varme i en oljefyrt kjel og leverer den til ulike forbrukere. I denne oppgaven utforskes potensialet for å energioptimalisere et slikt system ved å bytte fra konstant volumstrøm til et som kan styres dynamisk etter behovet til forbrukerne. I oppgaven er det lagt stor vekt på numeriske beregninger for effekten av volumstrøm, pumpetrykk og frekvensstyring.

Ved å bytte til et dynamisk system er det mulig å spare energi i pumpesystemet, som vil føre til lavere drivstofforbruk og lavere miljøgassutslipp. To forskjellige løsninger har blitt sammenlignet og vurdert. Den første løsningen var å justere volumstrømmen til hver forbruker ved hjelp av dynamiske ventiler, samt å frekvensstyre pumpen slik at pumpekurven treffer systemkurven i det optimale driftspunktet. Den andre løsningen var kun justering av volumstrømmen til hver forbruker uten frekvensstyring av pumpen. Som forventet var det den første løsningen som hadde de største besparelsene basert på utregningene i denne oppgaven.

Til tross for effekten av frekvensstyring var det løsningen med å justere volumstrømmen som ble arbeidet videre med, da denne løsningen også har store besparelser. Dette er et enklere system med få forandringer sammenlignet med det originale systemet. Det ble konkludert med at ved å bytte til systemet ved justering av volumstrøm potensielt kan spare 70 % av energiforbruket til hovedpumpen som tilsvarer rundt 100 000 kr per år i drivstoffkostnader. Denne investeringen har en beregnet avkastning på investering på 2,1 år.

Besvarelsen består av en hovedrapport der teori, metode, resultater og konklusjoner er presentert. Samt nødvendige systemdokumenter som P&ID, abstract of function, systembeskrivelse, armaturliste og brukermanual som er produsert av gruppen. Beregningene gjort i denne oppgaven er også vedlagt.

2 Abstract

The central heating system on board a service operative vessel is a system that extracts excess heat from the engines and produces heat in an oil fired boiler and delivers it to various consumers. This project explores the potential for energy optimization of such a system by switching from constant flow, to a flow that can be dynamically controlled according to the needs of the consumers. The project has great emphasis on numerical calculations for the effects of flow restriction, pump pressure and frequency control.

By switching to a dynamic system, it is possible to save energy in the pumping system, which will lead to lower fuel consumption and lower environmental gas emissions. Two different solutions have been compared and evaluated. The first solution was to adjust the flow to each consumer using dynamic valves, as well as frequency control on the pump so that the pump curve hits the system curve at the optimal operating point. The second solution was only adjusting the flow to each consumer without frequency control of the pump. As expected, it turned out that the first solution had the largest savings based on the calculations in this project.

Despite the effect of frequency control, solution one was developed further, as this solution also has significant savings. This is a simpler solution with few changes compared to the original system, thus bringing the development costs down. It was concluded that switching to this system by adjusting the flow has the potential to save $\sim 70\%$ of the energy consumption of the main pump, which corresponds to $\sim 100\,000$ NOK per year in fuel costs. This investment has a calculated return on investment of 2.1 years.

This submission consists of a main report where theory, methodology, results and conclusions are presented. Necessary system documents such as P&ID, abstract of function, system description, valve list and user manual created by the group are included. The calculations performed in this project are also attached.

3 Project Description

MASA2900 BACHELOROPPGAVE

Institutt for havromsoperasjoner og byggteknikk



Hovedprosjekt

for

Sindre Kildal Haakenstad og Victoria Omholt

Produkt- og systemdesign

Vårsemester 2023

Tittel:

Central Heating System Design

Varmegjenvinning og reduksjon av strømforbruk ombord er avgjørende for å designe Zero Emission skip. Central Heating System er et varmedistribusjonssystem som henter overskuddsvarme fra varmekilder som HT kjølesystem og som distribuerer varmen til ferskvannsproduksjon, tank heating, til air handling uniter til oppvarming av innredning/accommodation ombord. Systemet er i mange fartøy det viktigste varmegjenvinningsystemet og dermed avgjørende å designe best mulig tilpasset hvert enkelt fartøy. Systemet kjøres ofte som et constant flow system der sirkulasjonspumpen(e) kjører kontinuerlig. Systemet kan designes som et dynamisk system for å optimalisere/reducere strømforbruket til systemet. Lite er gjort for å synliggjøre faktisk sparepotensiale ved å endre systemet til dynamisk system.

Kandidatene skal i denne oppgaven:

1. Sette seg godt inn i funksjonene til ett av VARDs SOV vessel central heating system design, og kartlegge forskjellene, fordelene og ulempene ved konstant vs. dynamisk flow system.
2. Basert på det valgte fartøyet foreslå hvordan systemet kan designes for å være mest mulig energi- og kostnadseffektivt. Å tallfeste sparepotensialet (energi, CO₂ og Nox utslipp) er også viktig.
3. Utvikle et konsept (f.eks. regneark eller andre verktøy) for valg av konstant eller dynamisk flow system, som kan brukes som utgangspunkt for diskusjon med rederier om design-prinsipp.
4. I den grad det er tid til det, studere og analysere konsekvensene av å bytte fra tradisjonelt drivstoff til alternative drivstoff som metanol og hydrogen.

Veileder ved NTNU i Ålesund er Lars P. Bryne, og kontaktpersoner/ faglig veiledere ved Vard AS er Terje Ottersen og Runar Fiske.

Besvarelsen redigeres som en teknisk rapport, med et sammendrag både på norsk og engelsk, konklusjon, litteraturliste, innholdsfortegnelse etc. Ved utarbeidelsen av teksten skal kandidaten legge vekt på å gjøre teksten oversiktlig og velskrevet. Med henblikk på lesning av besvarelsen er det viktig at de nødvendige henvisninger for korresponderende steder i tekst, tabeller og figurer anføres på begge steder. Ved bedømmelsen legges det stor vekt på at resultatene er grundig bearbeidet, at de oppstilles tabellarisk og/eller grafisk på en oversiktlig måte og diskuteres utførlig.

4 Preface

It would not have been possible to complete this project without contributions from several people. A huge thank you to Lars Petter Bryne our supervisor at NTNU for both this project and through our bachelor education. The whole machinery department at Vard Design & Engineering should be acknowledged for answering questions and letting us use the offices during this time. We would like to especially thank Andreas Vartdal for his guidance throughout the process. The yard visit to Søvika on a similar vessel was very helpful for our understanding of the system.

Additionally, we would like to express our gratitude to Frese for their guidance and introduction to pressure independent valves for our system. Allweiler also deserves a thank you for arranging a crash course in pump theory.

Contents

1	Sammendrag	1
2	Abstract	2
3	Project Description	3
4	Preface	4
5	Table of Symbols	9
6	Introduction	10
7	Understanding the System	11
7.1	Sections and Branching	12
7.2	Heat Recovery Units	12
7.3	Pumping System	13
7.4	The Pipes	14
7.4.1	Heat Loss in the Piping System	14
7.5	Central Heating Fluid	17
7.6	The Consumers	17
7.6.1	Accommodation - AHU1	17
7.6.2	Wheelhouse - AHU2	18
7.6.3	Galley - AHU3	18
7.6.4	Bilge Water Separator	18
7.6.5	Urea Tank	19
7.6.6	Bilge Settling Tank	19
7.6.7	Freshwater Evaporator	19
7.7	Calculating Pressure Drop	21
7.7.1	Roughness, Bends, and Reducers	22
7.8	Valves	23
7.8.1	Butterfly Valve	23
7.8.2	Check Valve	24

7.8.3	Dynamic Regulating Valve	25
7.8.4	Ball Valve	26
7.8.5	Self-Acting Temperature Control Valve	27
7.8.6	Three-Way Motor Operated Valve	27
7.9	Heat Versus Flow Relation	28
7.10	The Three Modes	29
7.10.1	Active Consumers	29
7.10.2	Distribution Spent in Each Mode	30
8	Optimization of the System	31
8.1	System and Pump Characteristics	31
8.2	Finding a Suitable Pump	34
8.3	Effect of Frequency Control and Flow Restriction	34
8.4	Assumptions About Operating Conditions	37
8.5	Heat Balance	39
8.6	Alternatives for a Dynamic Central Heating System	39
8.6.1	Frequency Control and Flow Restriction	39
8.6.2	Flow Restriction	40
8.7	Calculating the Potential for Energy Saving	41
8.7.1	Power Consumptions Using Flow Restriction	44
8.7.2	Power Consumption Using Flow Restriction and Frequency Control	47
8.7.3	Electrical Load Calculations	50
8.7.4	Potential Fuel Savings	51
8.7.5	Potential Emissions Savings	51
9	Concept for a Dynamic System	54
9.1	Choice of Pump System	54
9.2	Choice of Valves	55
9.2.1	Pressure Independent Actuator Controlled Valves	55
9.2.2	Bleed Valve	55
9.3	Performance during Worst-Case Scenario	56
9.4	Conclusions of the Total Savings	58
9.5	System Documents	59

9.6	Eco Design	60
9.7	How Can This Work be Used in Future Projects	60
9.7.1	User Tests	61
10	Economic Analysis	62
10.1	Purchase Cost	62
10.2	Return on Investment	63
11	Possibilities for the Use of Alternative Fuels	64
12	Conclusion	65
13	Future Work	66
13.1	Belimo Energy Valves	66
13.2	User Interface	66
13.3	Verifying the Calculations	66
13.4	Further Improvements of the Pumping System	67
13.5	Alternative Fuels	67
13.6	Exploring how the Calculations Scale	67
A	Attachments	74
A.1	Pump Calculation User Manual	75
A.2	P&ID	84
A.3	System Description	85
A.4	Abstract of function	88
A.5	Armature list	91
A.6	Pipe Dimensions and Heat Losses	92
A.7	SF Pressure Drop Calculation	101
A.8	Power Consumption During Cold Conditions	109
A.9	Power Consumption During Middle Conditions	114
A.10	Power Consumption During Warm Conditions	119
A.11	Power Consumption Summary	125
A.12	Power Consumption During Worst Case Scenario	127
A.13	Weather Data at Grimsby	131
A.14	Weather Data at Hornsea	135

A.15 Data Sheet Grundfos pump 139
A.16 Data Sheet Allweiler pump 145

5 Table of Symbols

Symbol	Description	Units
$\frac{dU}{dt}$	Rate of change in internal energy	W
k	Combined heat loss coefficient	$W/m^2 \cdot K$
A_O	Outside area of the pipe	m^2
T	Temperature	Celsius
r	Radius	m
d	Diameter	m
h	Convection coefficient of fluid/gas	$W/m^2 \cdot k$
λ	Conduction coefficient of material	$W/m \cdot k$
Q	Volume flow	m^3/h
k_v	Flow coefficient	m^3/h
k_{vs}	Flow coefficient with a valve at a given position	m^3/h
SG	Specific gravity	1
p	Pressure	bar = 10^5 Pa
H	Pressure (Head of water column)	m = 0.098bar
q	Heat	W
ρ	Density	kg/m^3
μ	Dynamic viscosity	$Pa \cdot s$
f	Frequency	Hz
C	Change in frequency	1
η	Efficiency	1
$H(Q)$	Head as a function of the flow	m = 0.098bar
$H(Q, C)$	Head as a function of the flow and change in frequency	m = 0.098bar
$\eta(Q)$	Efficiency as a function of the flow	1
V	Volume	m^3
m	Mass	kg

6 Introduction

In the past few years, there has been a drastic shift towards moving to greener energy solutions and energy optimization, this is now also affecting the maritime industry. In this project, the possibility of energy optimizing a central heating system onboard a service operative vessel will therefore be explored. The specific vessel and associated shipping company cannot be revealed because of competitive advantages, however, the vessel is used for maintenance on offshore wind farms. By optimizing the central heating system, it is not only possible to lower the carbon footprint of the vessel, but this could also have a large economic advantage as a result of lower fuel consumption. These advantages will probably also be more evident in the future with stronger regulations in greenhouse gas emissions and higher fuel prices.

The system that is in use today mainly uses excess heat from the engines to provide heat to various consumers on the vessel. This is excess heat that would otherwise be wasted to the environment. The main issue in the pumping system, as of now, is the central heating pumps. The pumps are set to have a constant flow to deliver heat to each consumer. To control the distributed heat, there are mainly two solutions in place. Bypassing the consumer with a temperature-controlled three-way valves, or closing the flow to a consumer with a manual valve. This is wasteful since the pumps would have to deliver an unnecessary amount of flow even when the demand for heat is low, which leads to increased power consumption, higher fuel consumption, and greenhouse gas emissions. There is a possibility to optimize the system by designing a system that uses dynamic flow to deliver what's necessary to each consumer.

This project is a collaboration with Vard Design & Engineering. Vard is a ship-building company with headquarters located in Ålesund along with shipyards in Sunnmøre and several other places in the world. Vard provides engineering and high-end design services to the global maritime industry.

7 Understanding the System

This central heating system is on board a Service Operative Vessel, also known as a SOV. It is a heat-exchanging system that uses excess heat from the four engines and an external oil-fired hot water boiler to deliver heat to seven different consumers in the system. As of now, the system is utilizing a constant flow system to deliver heat around the piping system, which is optimized for a steady-state condition, where all the consumers are in use. This configuration is not ideal during most working conditions, which can lead to increased pressure, flow and power consumption from the pumps if not adjusted. This can be prevented by frequency control of the pump to decrease the flow, however the flow in the system would also have to be controlled by throttling to ensure the flow to each consumer as desired.




Figure 7.1: P&ID of the central heating system

7.1 Sections and Branching

To have a better overview and control of the central heating system, it was decided to divide the system into a main piping system with branches and then divide them further into sections. The pipeline from the main pump through air handling unit one, the heat recovery system and the oil-fired boiler was chosen as the main pipeline. This is because the majority of the flow delivered from the central heating pump takes this path. The division of the sections is done between pipes with different flows, pipe diameters, or wherever it is natural to divide the sections. The details of the section and branching system are illustrated in figure 7.1.

7.2 Heat Recovery Units

The heat recovery system extracts excess heat from the jacket water of the engines by going through a closed heat recovery unit. The heat recovery units from the four engines are connected in series. Two of them are designed to receive a maximum of 592 kW of heat, while the other two will receive a maximum of 594 kW of heat, this is when the engines are running at full capacity. This configuration has some limitations, firstly the heat exchange is proportional to the difference in temperature between the jacket water from the engines and the fluid in the heating system. Since the heat recovery system is connected in series, the temperature of the central heating fluid will increase as it travels through each heat recovery system, this makes each recovery system less effective.

The heat recovery system could theoretically be improved by connecting the units in parallel, which will increase the temperature difference between the liquid from the central heating system and the coolant from the engines. This configuration has a fatal flaw. If any of the units are shut off, the unit would have to be bypassed, thus making the heat recovery significantly less efficient. Vard is therefore now using the series configuration as a standard. This is also partly because when the engines are running, there is usually more than enough heat coming from the engines, to heat the fluid in the central heating system.

7.3 Pumping System

The central heating system has three pumps, where there are two main pumps and one pump to deliver flow to the freshwater evaporator. These would have to maintain the desired flow and pressure difference, in addition to overcoming the pressure drop from friction, bends, contractions, enlargers, and valves. These pumps have frequency control, but in this case, the frequency is set to the maximal operating point, meaning that the frequency is adjusted so that the pump curve intersects the system curve when all the consumers are in use.

The two main pumps are Grundfos CR32 centrifugal pumps as shown in figure 7.2 and are connected in parallel. Pumps connected in parallel is illustrated in figure 7.3. During normal conditions, only one of the main pumps is in use, and the second one is used as a backup pump in case of failure. In these conditions, the active pump delivers a flow of $36.2 \text{ m}^3/\text{h}$ with a differential pressure of around 3 bar, depending on the working conditions. The pump that is in use is alternated between the two main pumps, in order to distribute the wear between the pumps.



Figure 7.2: Grundfos CR32 Centrifugal Pump

[1]



Figure 7.3: Main pumps connected in parallel on another SOV

This system has dedicated a pump to deliver water to the freshwater evaporator. It is an Allweiler centrifugal pump and is set to deliver a flow of $66.2 \text{ m}^3/\text{h}$. The reason this branch has a separate pump is likely to minimize the working range of the main pump. If this branch is closed, this would not significantly affect the central heating pump.

7.4 The Pipes

The central heating system contains both different sizes and sort of pipes. Most of the pipes in this system are DN80. These are mainly steel pipes but with some Prestabo tubes, which are pipes consisting of exterior galvanized steel, that makes them more suitable for exposure to high temperatures.

7.4.1 Heat Loss in the Piping System

To determine the heat required from the heat recovery system and the oil-fired boiler, the heat loss in the pipes has to be calculated. This was done by considering the heat transfer for each section with the following formula 7.1 and 7.2 [2].

$$q_{loss} = \frac{dU}{dt} = \sum k \cdot A_O \cdot (T_i - T_o) \quad (7.1)$$

Where k can be found with the formula for the overall heat transfer coefficient for round pipes with insulation. The thickness of the steel pipes, and of the insulation, are standardized by Vard and can be found in their Pipe Insulation Standard [3]. The values for calculation is illustrated in figure 7.4

$$k = \frac{1}{\frac{r_2}{r_0 \cdot h_i} + \frac{r_2 \cdot \ln \frac{r_1}{r_0}}{\lambda_1} + \frac{r_2 \cdot \ln \frac{r_2}{r_1}}{\lambda_2} + \frac{1}{h_o}} \quad (7.2)$$




Figure 7.4: Illustration of the constants for calculating the heat-loss in a pipe [4].

By assigning a value of $k \cdot A_o$ to each section, it would be possible to calculate the heat loss to the cold and hot fluid sides. This was done with a simplification that the temperature of the fluid is constant for the hot and cold sides, even if the fluid is losing thermal energy along the path. This is a good enough assumption since this value would have such a large uncertainty, and calculating an accurate heat loss value would be too comprehensive for this project. The heat loss was therefore calculated with a constant fluid temperature of $60^\circ C$ and $80^\circ C$ for the cold and hot sides respectively and a constant outside temperature of $15^\circ C$. That yields the following formula for the heat loss in the pipes.

$$q_{loss} = \frac{dU}{dt} = \Delta T_{hot} \sum_{hot} k \cdot A_O + \Delta T_{cold} \sum_{cold} k \cdot A_O \quad (7.3)$$

These values were calculated using the Excel sheet shown in attachment A.6. A summary of the heat-loss in each branch can be found in table 7.1. This gave a total heat loss in the pipes of 4.96 kW at the given conditions.

	$A_o \cdot k[w/k]$	Outside temperature [°C]	Delta T [K]	Heat loss [W]
Main pipeline				
Cold side	15.53	15	45	699
Hot side	23.78	15	65	1546
Branch 1				
Cold side	1.55	15	45	70
Hot side	4.88	15	65	317
Branch 2				
Cold side	1.56	15	45	70
Hot side	1.56	15	65	101
Branch 3				
Cold side	1.34	15	45	60
Hot side	1.34	15	65	87
Branch 4				
Cold side	10.71	15	45	482
Hot side	9.28	15	65	603
AHU 2				
Cold side	3.90	15	45	176
Hot side	3.90	15	65	254
AHU 3				
Cold side	4.47	15	45	201
Hot side	4.47	15	65	290

Table 7.1: Heat loss in branches and sections

7.5 Central Heating Fluid

The fluid in the Central Heating System is a mixture of water and 6% coolant AL, which is an organic corrosion inhibitor. This prevents corrosion in the pipes. The reason this fluid is used instead of other liquids with better thermodynamic properties is likely because of the non-toxicity of this water mixture and also the cost efficiency.

In terms of mechanical properties, they were considered the same as freshwater. Since the concentration of Cooltreat AL is so low, it would not affect the properties significantly. The parameters for this fluid are therefore chosen as follows: density $\rho = 998.2 \text{ kg/m}^3$, dynamic viscosity $\mu = 1.0016 \cdot 10^{-3} \cdot \text{Pa} \cdot \text{s}$, and specific gravity (SG) = 1.

7.6 The Consumers

This central heating system has seven consumers. These are essentially where the system delivers its heat. All the consumers are connected in parallel, which is optimal for the same reason as with the heat recovery system. By connecting them in parallel, the system will be able to deliver the most heat, because of the temperature difference between the fluid and the environment.

7.6.1 Accommodation - AHU1

The majority of the flow from the main pumping system is used for accommodation. This is hereby referred to as Air Handling Unit One (AHU1). AHU1 is set to receive $21.5 \text{ m}^3/\text{h}$ of flow and 489,5 kW of heat during maximum working conditions. AHU1 is set to deliver heat at full capacity when the outside temperature is at -20°C , and it is set to shut off at temperatures above 12°C . This is the main air handling unit, and it delivers heat to the majority of the environment onboard. This unit is located at the D-Deck, which means that it is located with an elevation of 15.4 m above the main pumps. This is the consumer with the highest elevation, meaning that the differential pressure over this consumer will probably be low.

7.6.2 Wheelhouse - AHU2

The wheelhouse Air Handling Unit, hereby referred to as AHU2 is connected in parallel as a branch in the main piping system. It is set to receive a flow of $1.94 \text{ m}^3/\text{h}$ and deliver 44 kW of heat during maximum working conditions. AHU2 works at maximum capacity when the outside temperature is at $-20 \text{ }^\circ\text{C}$, and it shuts off at $20 \text{ }^\circ\text{C}$. AHU2 delivers heat to the wheelhouse. This AHU is separate from the rest of the system, likely because this makes it possible to control the air conditioning in the wheelhouse separate from the rest of the system, as well as defogging on the windshields. During extreme conditions, it would also be possible to run the air conditioning in the wheelhouse, without the rest of the system. This AHU is also located on the D-deck, which means that it has an elevation of 15.4 m similar to AHU1.

7.6.3 Galley - AHU3

The Galley Air Handling Unit, hereby referred to as AHU3, is also connected in parallel to the main piping system, similar to AHU2. It is set to receive a flow of $3.96 \text{ m}^3/\text{h}$, and deliver a heat of 90 kW at the maximum working point. AHU3 runs at full capacity when the outside temperature is at $20 \text{ }^\circ\text{C}$ and shuts off when the outside temperature is $12 \text{ }^\circ\text{C}$. The purpose of AHU3 is to deliver heat to the galley, and it works with the same temperature conditions as the AHU1.

7.6.4 Bilge Water Separator

Bilge Water Separator, hereby referred to as BWS, is connected as a branch to the main pipe system. It is set to receive a flow of $5.5 \text{ m}^3/\text{h}$. A BWS separates oil and water mixtures. AlfaLaval is the supplier of this BWS and the model is called PureBilge. This is a fully automated centrifugal oily water separation system that cleans oily water onboard vessels at sea [5]. It makes oily water safe for discharge overboard by effectively removing marine oil pollution. In order to meet international regulations for release into the sea, it is important that bilge water is treated to reduce oil content levels [**PureBilage**]. This BWS is approved by International Maritime Organization (IMO).




Figure 7.5: Illustration of Bilge Water Separator [6]

7.6.5 Urea Tank

Urea is a usual chemical commodity used in different products. In this case, urea is used to reduce Nitrogen Oxides (NO_X) emissions from vessels. Normally, NO_X reduction urea is delivered as a pre-mixed solution with 60 % deionized water and 40 % of urea. The urea tank is regulated by a self-acting temperature control valve.

7.6.6 Bilge Settling Tank

A deep tank in the engine room is used to pre-clean fuel oils by gravity. A liquid mixture in the settling tank clears slowly as a heavier liquid and solids sink to the bottom under the influence of gravity.

7.6.7 Freshwater Evaporator

The freshwater evaporator is the most demanding consumer in the system. This component is designed to have a flow of $66.3 \text{ m}^3/\text{h}$ from the central heating, and it requires an external pump to deliver the required flow. During full operation the evaporator has a capacity of producing 25.1 m^3 of fresh water per day. The evaporator is an Aqua Blue C100-HW86-108 freshwater generator from AlfaLava. The freshwater generator works by lowering the pressure of seawater while being heated by the central heating system. The seawater then undergoes partial evaporation, which will generate a mixture of vapor and

brine. This mixture is then separated, which will generate a vapor from freshwater. This vapor is then cooled, which condenses the vapor. The fresh water is then mineralized and then transported to a fresh water tank, where it is now drinkable. [7].




Figure 7.6: Aqua Blue C100-HW86-108 freshwater generator from AlfaLaval

The vessel has two methods for producing fresh water: a reverse osmosis system, and evaporation using heat from the central heating system to evaporate fresh water. The reverse osmosis system is not using heat from the central heating system, however, the water that is generated is of lesser quality than water produced with evaporation. It is therefore safe to assume that the water that is meant for human consumption is produced in the evaporator, and the water used for technical purposes is produced using the reverse osmosis method. By using experience values from Marinfloc on freshwater consumption for service vessels, it is possible to estimate the runtime for the freshwater generator.

Specification	Value
Capacity m^3/day	25.1
Demand $m^3/person/day$	0.195
Personel	89
Total demand per day m^2/day	17.355
Runtime %	69 %
Runtime h, min/day	~16h, 30min

Table 7.2: Values for freshwater generation for service vessels [8].




Figure 7.7: Daily water production

7.7 Calculating Pressure Drop

In order to determine losses in the existing system, the pressure drops the pumps would have to overcome has to be calculated. The pressure drops were mainly calculated using SF Pressure Drop software made by Rolls-Royce. However, some calculations had to be done manually or were found in product specifications from the suppliers. The results of the pressure calculations can be found in the pressure calculation attachment. The pump would have to be dimensioned to overcome the path that offers the most severe pressure drop, which in this case is the path through AHU1. This can be found in the calculation summary in the attachment A.7. The column comparison compares the results from the pressure calculation to find the path that offers the largest pressure drop, as shown in figure 7.8

Branch	Cumulative Pressure drop (bar)	Flow m3/h
Main Pipeline	2.88	21.5
Branch 1	0.13	5.5
Branch 2	0.61	1.8
Branch 3	0.29	1.5
Branch 4	1.51	66.2
Branch 5	0.94	1.94
Branch 6	0.60	3.96

One or more of the Nodes has a more severe Pressure drop than the main pipeline

Column Comparison	
Branch 1	
Inlet Column	6
Outlet Column	40
Pressure through main pipe (bar)	1.35
Pressure through branching pipe (bar)	0.13
Pressure through the main pipe has the most severe pressure drop	
Branch 2	
Inlet Column	6
Outlet Column	44
Pressure through main pipe (bar)	1.40
Pressure through branching pipe (bar)	0.61
Pressure through the main pipe has the most severe pressure drop	
Branch 3	
Inlet Column	6
Outlet Column	46
Pressure through main pipe (bar)	1.41
Pressure through branching pipe (bar)	0.29
Pressure through the main pipe has the most severe pressure drop	
Branch 4	
Inlet Column	62
Outlet Column	48
Pressure through main pipe (bar)	1.50
Pressure through branching pipe (bar)	1.51
Pressure through the branching pipe has the most severe pressure drop	
Branch 5	
Inlet Column	16
Outlet Column	30
Pressure through main pipe (bar)	1.13
Pressure through branching pipe (bar)	0.94
Pressure through the main pipe has the most severe pressure drop	
Branch 6	
Inlet Column	14
Outlet Column	33
Pressure through main pipe (bar)	1.18
Pressure through branching pipe (bar)	0.60
Pressure through the main pipe has the most severe pressure drop	

Caution, outlet node is before inlet node

Figure 7.8: Pressure drop overview

7.7.1 Roughness, Bends, and Reducers

The SF Pressure Drop software was used to calculate the pressure drop caused by the roughness of the pipes, the bends in the pipes, and changes in pipe diameter.

To determine the necessary parameters for SF Pressure Drop, the 3D-model of the piping system was analyzed in Navisworks Freedom 2023. The parameters that had to be determined in the 3D-model were: the lengths of each piping section, the bending angle in each bend and the angle of each contraction/enlargement. These were measured using the measuring tool in Navisworks. This method of determining these parameters is not entirely accurate, however, because of the significant uncertainty of such a calculation. The result of the pressure calculation would have to be cross-checked with real data, regardless of the accuracy of the calculations.

The roughness of the pipes was chosen to be 0.2 mm, which is referred to as “Steel after long operation cleaned” in SF Pressure Drop’s pipe library. The prestabo tubes have a roughness of 0.15 mm, according to Viegea, the supplier. The bending radius of all bends was set to be 1.5 times the internal diameter of the pipes ($r_{bending} = 1.5 \cdot d_{Pipe}$), which is specified in the P&ID.

A.2

7.8 Valves

During normal working conditions, the system runs through several valves. These valves also cause some pressure drop, even if they are fully open.

7.8.1 Butterfly Valve

The valves can be found in sections 7, 8, 9, 12, and 15, and branches 1, 2, 3, and 4 as well as the AHU branches. The valves are manually operated butterfly valves from Brødrene Dahl. These valves have a relatively large pressure drop due to the closing mechanism shown in figure 7.9. To calculate the pressure drop in these valves, the supplier was contacted, and they were able to provide a table of K_v values. The K_v value is found experimentally by testing which flow gives a pressure drop of one bar.



Figure 7.9: Lug butterfly valve [9].

The K_v values can be found in figure 7.10. As shown, this value has units m^3/h at 1 bar. If we assume that the increase in pressure is proportional to the square of the fluid flow, the pressure can be calculated by the formula 7.4. SG was set to 1, which is the specific gravity of water.

Kv Values-Valve Sizing Coefficients (m³ /h@1bar) DN50 to DN1500

Size mm	10°	20°	30°	40°	50°	60°	70°	80°	90° Full Open
50	0.1	4.3	10.3	20.6	38.6	54.8	77.1	107.1	115.7
65	0.2	6.9	17.1	31.7	55.7	84.0	123.4	174.8	188.5
80	0.3	10.3	18.9	33.4	60.0	99.4	156.8	235.6	258.8
100	0.4	14.6	30.8	66.8	119.1	197.1	311.9	467.9	514.1
125	0.7	24.9	52.3	114.0	203.1	335.9	531.3	796.9	875.7
150	1.7	38.6	81.4	175.7	313.6	518.4	820.9	1231.4	1353.0
200	2.6	76.3	161.1	349.6	623.0	1030.0	1630.7	2445.6	2687.2
250	3.4	129.4	274.2	594.7	1060.0	1754.1	2776.3	4163.7	4575.8
300	4.3	200.5	424.2	918.6	1637.5	2709.5	4288.8	6432.7	7069.4
350	5.1	289.6	612.7	1327.3	2365.9	3914.3	6195.4	9292.2	10211.7
400	6.9	397.6	842.3	1825.2	3253.6	5383.0	8519.3	12778.9	14042.8
450	9.4	527.0	1115.7	2418.2	4308.5	7129.4	11283.6	16925.4	18599.0
500	12.0	677.8	1434.4	3108.8	5539.8	9167.1	14508.1	21761.8	23914.3
600	18.9	1047.1	2216.8	4802.9	8559.6	14162.8	22413.9	33621.3	36946.0
700	30.8	1553.6	3118.3	5686.4	8569.0	12809.8	19510.7	29904.0	42416.5
800	38.6	2045.4	4105.4	7485.9	11814.9	17663.2	26902.3	41231.4	58483.3
900	51.4	2588.7	5195.4	9473.0	14952.0	22353.0	34045.4	52180.8	74014.6
1000	72.0	3584.4	7193.7	13116.5	20701.8	30990.6	47201.4	72343.6	102613.5
1050	299.9	3509.0	7746.4	14659.8	23264.8	37395.0	60411.3	91593.8	100685.5
1200	389.9	4597.3	10145.7	19194.5	26221.1	43873.2	79091.7	119965.7	131962.3
1500	681.8	8076.9	17577.4	33851.1	45187.3	78391.5	136920.4	206191.1	228872.1

Kv=(1/1.167)*Cv

Figure 7.10: k_v values of butterfly valves provided by Brødrene Dahl

$$\Delta p = \left(\frac{Q}{K_v}\right)^2 \cdot SG \tag{7.4}$$

7.8.2 Check Valve

In this system, there is one check valve, also called a non-return closable valve. The valve is placed after the freshwater circulation pump. A check valve lets the flow go one way, but if the flow reverses, the valve will close to protect the freshwater circulation pump.



Figure 7.11: Non-return closable valve

[10]

7.8.3 Dynamic Regulating Valve

This system also has a number of dynamic valves. These valves are type Frese Sigma Compact and can be found in every branch of the system. These valves have a piston that automatically adjusts so that the flow is constant, given by a pre-setting on the valve, as long as the pressure difference is within the specified range. If the pressure difference is not within the range, the valve will either be fully open or closed and cannot control the flow, in this case, the valve will not serve its purpose. The system curve for a system using these valves is shown illustratively in figure 7.12. This means that the central heating pump would have to overcome the pressure drop from the lower value in the range. The pumps should ideally deliver a pressure difference slightly above, but close to the lower bound. This is because a greater pressure difference in the valve would result in throttling of the system, and the pumps would have an unnecessarily high power consumption.




Figure 7.12: Illustration of a system curve using a dynamic regulating valve



Figure 7.13: Frese Sigma Compact flanged dynamic valve & Frese Sigma Compact dynamic valve with pre-set

[11][12]

7.8.4 Ball Valve

This central heating system is also using ball valves for pipes with a nominal diameter of 30 mm or below. The inner workings of this mechanism are shown in figure 7.14, and it works by turning a hollow ball to limit the flow. During normal working conditions, these valves are either fully open or fully closed. Because there is nothing restricting the flow when the valve is fully open, and when the valve is closed there is no flow. There is effectively no drop in pressure from these valves.




Figure 7.14: Ball valve mechanism [13]

7.8.5 Self-Acting Temperature Control Valve

This system includes two self-acting temperature control valves. The type is Danfoss AVTB, and it is a direct-acting thermostatic temperature controller used to regulate the water temperature in a variety of applications. The valve closes at a rising temperature. These two valves are placed on the urea tank and bilge settling tank. By using these kinds of valves it may reduce heat loss, which in turn may reduce fuel consumption and CO_2 emissions, considering the energy efficiency.



Figure 7.15: Self-acting control valve[14]

7.8.6 Three-Way Motor Operated Valve

The branches connecting the air handling units to the main system also have three-way motor-operated valves. These valves are of the type Oventrop three-way regulating valves. These valves have a sensor connected to their respective air handling unit, and their purpose is to regulate the flow through the AHUs by bypassing the fluid in parallel such that the flow through the heat exchanger is as desired. Their pressure drop can be calculated by the k_{vs} -value which is specified in figure 7.17. These valves are essentially what control the heating of the AHU's since they are the only active components that control the flow to these consumers. The pressure drop and flow from the central heating pump would be determined by the intersection between the system curve and the pump curve. This is what makes the exciting system so inefficient. Since the valve bypasses the excess flow, the central heating pump would have to deliver more flow than necessary, which also results in a higher pressure drop, which raises power consumption.



Figure 7.16: Oventropp 3-way valve

Tekniske data					
NRF	Varenummer	DN	k_{vs} -verdi	Δp_{max} stengetrykk i kPa for 2-veis og shuntventil	Δp_{max} stengetrykk i kPa for fordelerventil
N/A	311130875	15	1,0	1210	600
N/A	311130865	15	1,6	1210	600
N/A	311130845	15	2,5	1210	600
N/A	311130866	20	4,0	920	450
N/A	311130846	20	6,3	920	450
N/A	311130847	25	10,0	500	250
N/A	311130848	32	16,0	350	170
N/A	311130849	40	25,0	150	70
N/A	311130850	50	35,0	70	30
N/A	311130851	65	63,0	560	280
N/A	311130852	80	100,0	360	180
N/A	311130853	100	160,0	220	1100
N/A	311130854	125	220,0	130	600
N/A	311130855	150	320,0	80	400

Figure 7.17: k_{vs} -values for Oventrop three-way valves

7.9 Heat Versus Flow Relation

The heat distributed to each unit is governed by the change in internal energy of the fluid, this can be calculated using formula 7.5. If we assume the temperature difference through the unit is a constant 20°C the only variable would be the flow Q . The results from this formula are similar to the specified value in the system drawing. This shows that the delivered heat is proportional to the flow through a consumer, as long as the fluid reaches the necessary temperature difference 7.6.

$$q = \frac{dU}{dt} = C_p \cdot \rho \cdot Q \cdot \Delta T \quad (7.5)$$

$$q \propto Q \quad (7.6)$$

7.10 The Three Modes

In order to optimize the central heating system, it is important to find the optimal pump. Based on three selected modes, harbor mode, transit mode and dynamic positioning mode, it is possible to determine the amount of heat distributed to each unit and the required flow. With these results, it is possible to find the amount of heat that is required, the flow through the central heating pump and the pressure drop that the pump has to overcome. The number of hours in each mode depends on where the vessel will be operating and the weather conditions.

Harbor Mode

When the vessel is docked, the central heating system is in harbor mode.

Transit Mode

When the vessel is in transit from port to a mission, the central heating system is in transit mode.

Dynamic Positioning Mode

When the vessel is on a maintenance mission, the offshore gangway is in operation, and the central heating system is in dynamic positioning mode. In this mode, the vessel uses side thrusters to stabilize with as little movement as possible, to ensure the safety of the maintenance personnel.

7.10.1 Active Consumers

Because the bilge water separator requires momentum when in use, it is only used in transit mode. As for the settling tank, this is only heated before the bilge water separator and is also used in transit mode. However, these consumers are not frequently used. After contacting the shipping company, it turned out that the BWS is in use for approximately between two and three hours per month. The bilge settling tank is in use for approximately 48 hours per month. As for urea, heating is not in use. Since these consumers are so infrequently in use, it does not make sense to optimize the system for their use. A summary of active consumers in each mode can be found in table 7.4.

In all three modes, the AHUs are usually active. The capacity they are running on is dependent on the weather conditions. The freshwater evaporator runs whenever there is a demand for freshwater, and there is enough heat that can be extracted from the engines.

7.10.2 Distribution Spent in Each Mode

To estimate the distribution between the time the vessel would be in each mode, data from a similar vessel owned by the same shipping company was used. The shipping company estimated that this vessel would go to shore approximately every 14 days and spend 15 % of its operating time at harbor. The vessel spends approximately between five and six hours in transit each way to the wind field, making it 10–12 hours per 14 days. The rest of the time would be spent in dynamic positioning mode. Details in the time distribution spent in each mode can be found in the table 7.3.

	Harbor	Transit	Dynamic positioning
Distribution	15 %	3.5 %	81.5 %

Table 7.3: Hourly distribution in each mode

Active Consumers	Harbor	Transit	Dynamic Positioning
AHU1	Usually active	Usually active	Usually active
AHU2	Usually active	Usually active	Usually active
AHU3	Usually active	Usually active	Usually active
Freshwater Evaporator	Not active	Usually active	Usually active
Bilage Water Separator	Usually not active	Usually not active	Usually not active
Bilage Settling Tank	Usually not active	Usually not active	Usually not active
Urea Tank	Usually not active	Usually not active	Usually not active

Table 7.4: The consumers and when they are active in each mode

8 Optimization of the System

With a thorough understanding of how the existing central heating system works, it is possible to discuss how the system can be designed to improve its efficiency. The following section provides information on solutions to improve the system, as well as assumptions that were made to compare the results of different solutions.

8.1 System and Pump Characteristics

Pump Curve

A pump curve is a graphic representation of the performance of a pump as shown in figure 8.1. It provides information on several elements of a pump's performance and helps select the most suitable one. The pump curve varies from pump to pump, and the variation depends on factors like electrical power and the size and shape of the impeller.

System Curve

The system curve shows the pressure loss in the system as a function of the flow, and it is known as the system curve. This curve is given by the system in which the pump is to operate. It is a combination of static pressure head and dynamic pressure head. The specific duty point is the cross between the system curve and the pump curve. It is important to stay as close to the duty point as possible, because oversizing and undersizing a pump may have performance consequences.




Figure 8.1: Pump curve

QH Curve

The QH curve shows the head that a pump is able to perform at a given flow. The head is measured in meters and one of the advantages is that the QH curve is unaffected by the fluid's density. Low flow results in a high head, and high flow results in a low head. Flow is the rate at which water travels throughout a hydraulic system, while the head denotes the heights at which the pump can elevate a water column.

Shaft Power P2

The shaft power P2 curve illustrates the relationship between the power consumption of the shaft and the flow through the pump. The power consumption determines the size of the electrical installations which must supply the pump with power. Power consumption depends on the density of the fluid. The P2 curve increases as the flow increases.

NPSH Curve

Net Positive Suction Head or NPSH denotes the minimum absolute pressure that must be present on the suction side of a pump to avoid cavitation. Cavitation is when small

steam bubbles appear in the pump due to pressure being too low. This can cause damage to the pump. To determine if a pump can operate safely in a system, the NPSH must be known for the largest flow and the evaporation pressure at the given temperature.

The NPSH curve is mainly used when pumping water in a non-closed system. In a closed system such as this, the drop in pressure from elevation will be canceled by the descent of the water column. Since this is not a depressurized system, the NPSH value would never be anywhere near the critical value. This would therefore not be considered.

Shaft Efficiency

Efficiency is the ratio between supplied hydraulic power and power consumed. The efficiency depends on the pump's duty point, underlining the importance of selecting a pump that fits the flow requirement, to ensure that the pump is always working in the most efficient flow range. The supplied power is always larger than the hydraulic power, due to losses in motor and pump components. That is why the efficiency of a complete pump unit is lower than the efficiency of just the pump. The system border for the shaft efficiency is illustrated in figure 8.2. Since the provided efficiency curve is in terms of shaft power, there had to be an assumption about the efficiency of the motor. The efficiency was chosen to be constant at 0.9, this was estimated by comparing results from shaft power and overall power, and it was relatively constant around 0.9. This efficiency is perhaps a little higher than in reality, however, choosing a high efficiency for the motor would be conservative because this would result in a lower potential for energy saving.




Figure 8.2: Illustration of the system border for the shaft efficiency

8.2 Finding a Suitable Pump

There is a lot to consider when choosing a pump. The system has major variations in flow, ranging from $0.5 \text{ m}^3/h$ to $36 \text{ m}^3/h$. The pump must be able to deliver a differential pressure of 3 bar. A few suggestions for a pump were presented after contact with Allweiler, which is one of Vard's pump suppliers. The first suggestion was two pumps connected in parallel with two equal pumps, This would increase the flow range, but it would not affect the differential pressure. For further information about these pumps, see attachment A.16. The Allweiler pump did not comply with the requirements. Grundfos, another pump supplier, was contacted to find a better solution. After receiving the data sheet and suggestion for a pump, it turns out that the efficiency was too low when the flow is $0.5 \text{ m}^3/h$. They therefore suggested a system consisting of four pumps connected in parallel, with one as a backup, see attachment A.15. With this setup, it is possible to run one or two of the pumps when the demand is low, and run all three during full operation. This ensures an acceptable efficiency at both high and low flows.

8.3 Effect of Frequency Control and Flow Restriction

In order to optimize the system, it is necessary to analyze the effect of frequency control of the pump and restricting the flow in the system. Frequency control is done by changing the frequency of the AC voltage that delivers power to the pump, which changes the speed of the pump motor. The result of the frequency control is to move the pump curve towards or away from the origin, which is illustrated in figure 8.3. By changing the frequency of the pump, it would be possible to move the pump curve such that it would intersect the system curve at the optimal point. This could have the potential for a large power saving in the central heating pump, mainly because of the strange property of Frese dynamic valves. These valves throttle or bypass the system such that the flow in the pipes remains constant as long as the pressure is within the working range of the valves. This would mean that if not accounted for, the valves have to throttle the system to maintain the desired flow, and the pump would have an unnecessary power consumption. Flow restriction can be performed using actuator-controlled pressure-independent valves. These valves throttle the system to ensure that the flow is as desired.




Figure 8.3: The effect of frequency control

To determine what the power-saving potential could be, it would be helpful to estimate the pump curve as a function of the flow and the frequency. This would make it possible to perform calculations with the mathematical function. This was done by using a numerical curve fitting program to estimate a polynomial for the pump curves provided by Allweiler and Grundfos. Firstly, the end points and a middle point at the curve of a constant frequency were considered to estimate a function $H(Q)$. The effects of frequency control also had to be investigated. This was done with an assumption the flow Q and the head H is proportional to a function of the change in frequency C .

$$H(Q, C) = H(Q \cdot f(C)) \cdot g(C) \quad (8.1)$$

The range of the function is also a function of the change in frequency C .

$$Q \in [0, h(C)] \quad (8.2)$$

Where:

$$C = \frac{f_{new}}{f_{Original}} \quad (8.3)$$

With these assumptions, it is possible to estimate these relationships by comparing them to pump curves at different frequencies. That gave the following relationships, which were used to estimate the curve at varying frequencies.

$$H(Q, C) = H\left(Q \frac{1}{C}\right) \cdot C^2 \quad (8.4)$$

Where the range of the function is the original range Q_{max} times C .

$$Q \in [0, Q_{max} \cdot C] \quad (8.5)$$

The power consumption of the pump, at a certain point, is given by the following equation.

$$P = \frac{\rho \cdot g \cdot H \cdot Q}{\eta} \quad (8.6)$$

Meaning that the efficiency η has to be considered. This was done similarly to the pump curve, by estimating a polynomial for the efficiency $\eta(Q)$. All the estimated polynomials were second-degree polynomials, the estimation would be more accurate with a higher degree polynomial, however, the estimation would only be as accurate as the accuracy of the graph reading. Therefore, a second-degree polynomial is sufficient. With this information, the polynomials were estimated as shown in table 8.1 and 8.2.

	NB32-125/01 Parallel	NB32-125/01	NB32-160/02
$H(Q)$	$33.5 + 0.01675Q - 0.00317Q^2$	$33.5 + 0.118Q - 0.0174Q^2$	$34 + 0.2474Q - 0.0115Q^2$
$H(Q, C)$	$(33.5 + 0.01675\frac{Q}{C} - 0.00317\frac{Q^2}{C^2})C^2$	$(33.5 + 0.118\frac{Q}{C} - 0.0174\frac{Q^2}{C^2})C^2$	$(34 + 0.2474\frac{Q}{C} - 0.0115\frac{Q^2}{C^2})C^2$
$\eta(Q)$	$0.0271Q - 0.0003Q^2$	$0.0535Q - 0.0012Q^2$	$0.0481Q - 0.0008Q^2$

Table 8.1: The polynomial used to estimate the pump and efficiency curves at varying flows and frequencies

	Grundfos Hydro Multi-E 4 Single	Grundfos Hydro Multi-E 4 Parallel
$H(Q)$	$43.8 + 0.8Q - 0.1321Q^2$	$44.59 + 0.1256Q - 0.0116Q^2$
$H(Q, C)$	$(43.8 + 0.8\frac{Q}{C} - 0.1321\frac{Q^2}{C^2})C^2$	$(44.59 + 0.1256\frac{Q}{C} - 0.0116\frac{Q^2}{C^2})C^2$
$\eta(Q)$	$0.1361Q - 0.0072Q^2$	$0.0376Q - 0.00054Q^2$

Table 8.2: The polynomial used to estimate the pump and efficiency curves at varying flows and frequencies

With the efficiency curve for the two pump setups in parallel, it is also possible to calculate when it would be beneficial to run several pumps in parallel versus just running one pump. Having several pumps in parallel would be beneficial when the efficiency curve is higher than for just one pump. By solving for the flow, it would be beneficial to run two pumps when the flow is above $29 \text{ m}^3/h$ for the NB 32 125/01. For the Grundfos Hydro Multi-E 4 it would be beneficial to run two pumps at flows above $14 \text{ m}^3/h$ and three pumps at flow above $27 \text{ m}^3/h$.

8.4 Assumptions About Operating Conditions

To estimate the potential to reduce power consumption, some assumptions about the operating conditions had to be made. Since this is a project about one SOV in general and not for a specific location, a detailed analysis of the weather conditions that the vessel will operate in was considered too time-consuming for this project. The assumptions about operating conditions were therefore based on data from one location where the vessel could operate. The chosen location that was analyzed was Grimsby, England, where the vessel could be used in the Hornsea 2 wind farm. Which is currently the largest offshore wind farm in the world [15].

As a simplification, it was decided to divide the operating conditions into three segments: cold weather, middle weather and warm weather. Weather data from Visual Crossing was analyzed to estimate operating temperatures at Grimsby and at sea. For the cold and warm conditions, the temperatures at the 25 % and 75 % quartiles were used. The humidity was chosen to be constant at an average of 81 %. Although this estimate might not give an accurate picture of the operating conditions, this would give a good enough estimate as long as these assumptions are used in the calculations of the existing system as well as a dynamic system. To estimate the distribution of cold, middle and warm days, it was decided to consider all days with an average temperature below the midpoint between middle and cold as cold days. Likewise, for the warm days, every day above the midpoint between cold and warm days was considered warm days. With these assumptions, the following conditions were considered. The details of the weather analyses can be found in the attachments A.13

Grimsby	Cold conditions	Middle conditions	Warm conditions
Temperature °C	6.4	10	14.4
Distribution throughout year	37%	24%	39%

Table 8.3: Temperatures at Grimsby




Figure 8.4: Distribution of average daily temperatures at Grimsby [16]

At sea	Cold conditions	Middle conditions	Warm conditions
Temperature °C	7.4	10.5	14
Distribution throughout year	37%	24%	39%

Table 8.4: Temperatures at sea outside of Grimsby




Figure 8.5: Distribution of average daily temperatures at sea outside of Grimsby [17]

8.5 Heat Balance

With the assumptions about the weather conditions, it was possible to calculate the heat balance for each mode and weather condition. This was done by considering the range where the AHUs are active from subsection 7.6 and assuming that there is a linear relationship between the outside temperatures and the consumption of the AHUs in this range. The consumption was then calculated as a percentage of the maximum capacity in each condition. The consumptions for the rest of the consumers were based on conclusions from subsection 7.10.

8.6 Alternatives for a Dynamic Central Heating System

After having explored different solutions to designing a dynamic flow system, it was found that there were two solutions that were promising. This was done by discussing different possibilities with experienced engineers at Vard to determine what realistically could be done to optimize the system.

8.6.1 Frequency Control and Flow Restriction

One of the solutions that were found is to use both frequency control of the central heating pump and to restrict the flow to each consumer to what is desired. This would possibly have the largest power-saving potential of the two solutions. As shown in formula 8.6 this would save power by both lowering the flow delivered by the pump and the pressure drop in the system. At low flows, this configuration would have very little power consumption. The main challenge with this configuration would be to find a way to control the frequency of the pump.

The pump would be at the optimal working point when the differential pressure over all the valves is barely above the minimum working pressure. This will ensure the right flow in all the consumers and that the pump is at the optimal working point. This is illustrated in figure 8.3. This could be done by having sensors over all the dynamic valves that could adjust the frequency of the pump. These sensors would have to be fine-tuned to ensure they are in sync with the independent valves, and the logic of the signal to the actuator, the feedback from the sensors, and the frequency converter would have to be programmed and tested. This could potentially be time-consuming and costly.

This system would also have to account for the possibility of manually closing valves. If there is a leakage somewhere in the pipe system, the differential pressure over the pump would suddenly drop and branches would be closed off manually. Until the pressure stabilizes. If one or more of the branches with AHUs are closed off, this would result in no flow through the branch and the differential pressure over the valve would be zero. The pump would then increase the frequency to deliver the right flow to the consumers, which would never happen because the branch is closed. If not accounted for, the frequency would increase until either the surge protector kicks in or the motor burns out. In either case, this is not ideal because this would halt the entire system.

8.6.2 Flow Restriction

The second solution that was found, was to only restrict the flow in the system using actuator-controlled pressure-independent valves. This would also decrease the power consumption for the pump, however, it would not benefit from the decrease in pressure that frequency control would have. The pressure would likely be slightly higher than without flow restriction because of the pump curve. Even if the power saving potential is lower, this configuration has the benefit of being much simpler than with additional frequency control. This would drive development costs down, as well as installation costs and maintenance costs. This system would only differ from the original system by replacing the three-way Oventropp valves and the pressure-independent Frese valve with actuators. This configuration would possibly need a bleed valve to bypass the throttling from the valve, this is to ensure there is always some flow in the system. This is necessary to make sure the pump does not overheat, since the pump is designed to self-cool from the fluid in the system.

Both options would have to be considered when designing the system. The development cost, installation cost and maintenance cost would have to be estimated and compared to the potential for power saving to make a decision on which configuration would be most beneficial for this vessel. Making detailed estimations for these costs would be too comprehensive for this project, however, it is possible to make an educated decision on which configuration to proceed with.

8.7 Calculating the Potential for Energy Saving

In order to compare the two solutions, it is necessary to estimate what the potential for fuel-saving would be in each configuration. This was done using the data gathered above about the three modes that would be considered, the working conditions and information about the AHUs, as shown in figure 8.6. As well as the different pump solutions that were provided by Allweiler and Grundfos. Firstly, it was necessary to develop a mathematical model of the pressure drop in the system. This was done with the assumption that the pressure drop in each pipe section is proportional to the square of the flow. This implies that the pressure drop would obey formula 7.4. Using the calculations of pressure drop, from section 7.7 and the nominal flow used in the calculations, it was possible to assign each section of the main pipeline with a respective k_v value such that the pressure drop could be calculated with varying flows.

By entering the capacity of each consumer in the system, the sheet automatically calculates the flow in each section, and then the pressure drop using the assigned K_v value. That would yield the pressure drop the central heating pump would have to overcome in each configuration and the flow, this is the working point of the pump which can be drawn on the pump curve chart.




Figure 8.6: Heat calculation during cold conditions

To compare the results with different pump solutions as well as the two different solutions for a dynamic system, this data was used in combination with the polynomials for efficiency and pump curves found in section 8.3. This makes it efficient to compare different solutions in various modes. In the results of these calculations, it was found that the flow is significantly lower than what the system is dimensioned for. Meaning that there is a large potential for power saving from the pump, which leads to fuel savings and lower operating costs.

The difference between the two solutions described in section 8.6 would be that with frequency control it is possible to lower the pressure drop as well as the flow. With just flow restriction it would only be possible to lower the flow, and the pressure drop would be the point on the pump curve at that flow. This is illustrated in figure 8.3. The calculations were done in three versions of the sheet: cold conditions, middle conditions and warm conditions. Where each sheet has three modes: harbor, dynamic positioning and transit. The reason this calculation was done using three different sheets is to keep it simple enough for other users to utilize. There has to be a balance between creating an efficient sheet that could do calculations quickly and still making it general enough, such that it can be used in different projects. It was therefore decided that it would be most user-friendly to do the calculation in three different versions of the document.




Figure 8.7: Heat calculation during cold conditions.

As shown in figure 8.7 the sheet takes in information about the pump and efficiency curve. The button labeled “Fit curve to working points” runs a macro with the goal seek function in Excel that fits the curve to the working points using frequency control. The button labeled “Reset frequency controlling” re-sets the frequency to the original frequency that is specified. This makes it simple to compare results from the two configurations.

To find the potential for fuel savings, the calculations from the dynamic systems would have to be compared to calculations from the original constant flow system. The calculations from the original system would be done similarly to a dynamic system, the only difference being that the flow would not be restricted by dynamic valves, the flow would be bypassed by the three-way valves, meaning that the flow through the central heating pump would be relatively constant at the value specified in the system documentation. As mentioned in section 7.3 the original pump frequency would be adjusted so that it can deliver flow at the maximum working point. This was found by setting all consumers to full capacity and fitting the pump curve to the working point. It was found that the original pump frequency would be adjusted to around 3513 rpm. This could also be done to a dynamic system using just active flow restriction, however, to include some safety in the calculations this was only done in the calculations for the constant flow system.




Figure 8.8: Pump calculations in the original constant flow system

Shown below are the calculations from the three weather conditions and three modes. The calculations compare the power consumption of a system that uses flow restriction with a constant pump frequency and a constant flow system that is used today.

8.7.1 Power Consumptions Using Flow Restriction




Figure 8.9: Summary of power consumption during cold conditions using flow restriction

Summary of the pump calculations middle weather		Dynamic system			
NB 32 125/01 Parallel		NB 32 125/01	NB 32-160/02	Grundfos HYDRO MULTI-E 4	
Harbor		Harbor	Harbor	Harbor	Harbor
Flow (m ³ /h)	4.00	Flow (m ³ /h)	2.06	Flow (m ³ /h)	2.06
Head required (m)	0	Head required (m)	0	Head required (m)	0
Frequency (1/min)	3420	Frequency (1/min)	3420	Frequency (1/min)	2640
Change of frequency C	100%	Change of frequency C	100%	Change of frequency C	100%
Efficiency [%]	10%	Efficiency [%]	11%	Efficiency [%]	10%
Power consumption (Kw)	3.91	Power consumption (Kw)	1.99	Power consumption (Kw)	2.25
	0		0		0
Transit		Transit		Transit	
Flow (m ³ /h)	4.00	Flow (m ³ /h)	2.00	Flow (m ³ /h)	2.00
Head required (m)	7	Head required (m)	7	Head required (m)	7
Frequency (1/min)	3420	Frequency (1/min)	3420	Frequency (1/min)	2640
Change of frequency C	100%	Change of frequency C	100%	Change of frequency C	100%
Efficiency [%]	10%	Efficiency [%]	10%	Efficiency [%]	9%
Power consumption (Kw)	3.91	Power consumption (Kw)	1.99	Power consumption (Kw)	2.25
	0		0		0
Dynamic positioning		Dynamic positioning		Dynamic positioning	
Flow (m ³ /h)	4.00	Flow (m ³ /h)	2.00	Flow (m ³ /h)	2.00
Head required (m)	7	Head required (m)	7	Head required (m)	7
Frequency (1/min)	3420	Frequency (1/min)	3420	Frequency (1/min)	2640
Change of frequency C	100%	Change of frequency C	100%	Change of frequency C	100%
Efficiency [%]	10%	Efficiency [%]	10%	Efficiency [%]	9%
Power consumption (Kw)	3.91	Power consumption (Kw)	1.99	Power consumption (Kw)	2.25
	0		0		0
Static system		Pump power consumption saving			
Harbor		Harbor			
Flow (m ³ /h)	27.40	Power consumption with static system (Kw)	4.40		
Head (m)	15	Power consumption with dynamic system (Kw)	1.12		
Frequency (1/min)	3513	Power saving (Kw)	3.28		
Change of frequency C	98%	Power saving potential [%]	75%		
Efficiency [%]	68%	Power consumption scaling factor [1]	0.25		
Power consumption (Kw)	4.40				
	0				
Transit		Transit			
Flow (m ³ /h)	27.4	Power consumption with static system (Kw)	4.40		
Head (m)	27	Power consumption with dynamic system (Kw)	1.09		
Frequency (1/min)	3513	Power saving (Kw)	3.31		
Change of frequency C	98%	Power saving potential [%]	75%		
Efficiency [%]	68%	Power consumption scaling factor [1]	0.25		
Power consumption (Kw)	4.40				
	0				
Dynamic positioning		Dynamic positioning			
Flow (m ³ /h)	27.4	Power consumption with static system (Kw)	4.40		
Head (m)	27	Power consumption with dynamic system (Kw)	1.09		
Frequency (1/min)	3513	Power saving (Kw)	3.31		
Change of frequency C	98%	Power saving potential [%]	75%		
Efficiency [%]	68%	Power consumption scaling factor [1]	0.25		
Power consumption (Kw)	4.40				

Figure 8.10: Summary of power consumption during average weather conditions using flow restriction

Summary of the pump calculations warm weather	
Dynamic system	
NB 32 125/01 Parallel	
Harbor	
Flow (m ³ /h)	4.00
Head required (m)	0
Frequency (1/min)	3420
Change of frequency C	100%
Efficiency [%]	10%
Power consumption (Kw)	3.91
	0
Transeit	
Flow (m ³ /h)	4.00
Head required (m)	6
Frequency (1/min)	3420
Change of frequency C	100%
Efficiency [%]	10%
Power consumption (Kw)	3.91
	0
Dynamic positioning	
Flow (m ³ /h)	4.00
Head required (m)	6
Frequency (1/min)	3420
Change of frequency C	100%
Efficiency [%]	10%
Power consumption (Kw)	3.91
	0
NB 32 125/01	
Harbor	
Flow (m ³ /h)	2.00
Head required (m)	0
Frequency (1/min)	3420
Change of frequency C	100%
Efficiency [%]	10%
Power consumption (Kw)	1.99
	0
Transeit	
Flow (m ³ /h)	2.00
Head required (m)	6
Frequency (1/min)	3420
Change of frequency C	100%
Efficiency [%]	10%
Power consumption (Kw)	1.99
	0
Dynamic positioning	
Flow (m ³ /h)	2.00
Head required (m)	6
Frequency (1/min)	3420
Change of frequency C	100%
Efficiency [%]	10%
Power consumption (Kw)	1.99
	0
NB 32-160/02	
Harbor	
Flow (m ³ /h)	2.00
Head required (m)	0
Frequency (1/min)	2640
Change of frequency C	100%
Efficiency [%]	9%
Power consumption (Kw)	2.25
	0
Transeit	
Flow (m ³ /h)	2.00
Head required (m)	6
Frequency (1/min)	2640
Change of frequency C	100%
Efficiency [%]	9%
Power consumption (Kw)	2.25
	0
Dynamic positioning	
Flow (m ³ /h)	2.00
Head required (m)	6
Frequency (1/min)	2640
Change of frequency C	100%
Efficiency [%]	9%
Power consumption (Kw)	2.25
	0
Grundfos HYDRO MULTI-E 4	
Harbor	
Flow (m ³ /h)	1.21
Head required (m)	0
Frequency (1/min)	3000
Change of frequency C	100%
Efficiency [%]	15%
Power consumption (Kw)	1.06
	0
Transeit	
Flow (m ³ /h)	1.21
Head required (m)	6
Frequency (1/min)	3000
Change of frequency C	100%
Efficiency [%]	15%
Power consumption (Kw)	1.06
	0
Dynamic positioning	
Flow (m ³ /h)	1.21
Head required (m)	6
Frequency (1/min)	3000
Change of frequency C	100%
Efficiency [%]	15%
Power consumption (Kw)	1.06
	0
Static system	
Harbor	
Flow (m ³ /h)	27.40
Head (m)	15
Frequency (1/min)	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption (Kw)	4.40
	0
Transeit	
Flow (m ³ /h)	27.4
Head (m)	27
Frequency (1/min)	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption (Kw)	4.40
	0
Dynamic positioning	
Flow (m ³ /h)	27.4
Head (m)	27
Frequency (1/min)	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption (Kw)	4.40
	0
Pump power consumption saving	
Harbor	
Power consumption with static system (Kw)	4.40
Power consumption with dynamic system (Kw)	1.06
Power saving (Kw)	3.34
Power saving potential [%]	76%
Power consumption scaling factor [1]	0.24
Transeit	
Power consumption with static system (Kw)	4.40
Power consumption with dynamic system (Kw)	1.06
Power saving (Kw)	3.34
Power saving potential [%]	76%
Power consumption scaling factor [1]	0.24
Dynamic positioning	
Power consumption with static system (Kw)	4.40
Power consumption with dynamic system (Kw)	1.06
Power saving (Kw)	3.34
Power saving potential [%]	76%
Power consumption scaling factor [1]	0.24

Figure 8.11: Summary of power consumption during warm conditions using flow restriction

8.7.2 Power Consumption Using Flow Restriction and Frequency Control

Summary of the pump calculations cold weather	
Dynamic system	
NB 32 125/01 Parallel	
Harbor	
Flow (m ³ /h)	5.12
Head required (m)	0
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	13%
Power consumption (Kw)	1.09
0	0
Transit	
Flow (m ³ /h)	4.44
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	11%
Power consumption (Kw)	1.09
0	0
Dynamic positioning	
Flow (m ³ /h)	4.44
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	11%
Power consumption (Kw)	1.09
NB 32 125/01	
Harbor	
Flow (m ³ /h)	5.12
Head required (m)	0
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	24%
Power consumption (Kw)	0.58
0	0
Transit	
Flow (m ³ /h)	4.44
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	21%
Power consumption (Kw)	0.58
0	0
Dynamic positioning	
Flow (m ³ /h)	4.44
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	21%
Power consumption (Kw)	0.58
NB 32-160/02	
Harbor	
Flow (m ³ /h)	5.12
Head required (m)	0
Frequency (1/min)	1800
Change of frequency C	68%
Efficiency [%]	22%
Power consumption (Kw)	1.13
0	0
Transit	
Flow (m ³ /h)	4.44
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	68%
Efficiency [%]	20%
Power consumption (Kw)	1.12
0	0
Dynamic positioning	
Flow (m ³ /h)	4.44
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	68%
Efficiency [%]	20%
Power consumption (Kw)	1.12
Grundfos HYDRO MULTI-E 4	
Harbor	
Flow (m ³ /h)	5.12
Head required (m)	0
Frequency (1/min)	1584
Change of frequency C	53%
Efficiency [%]	51%
Power consumption (Kw)	0.33
0	0
Transit	
Flow (m ³ /h)	4.44
Head required (m)	7
Frequency (1/min)	1584
Change of frequency C	53%
Efficiency [%]	46%
Power consumption (Kw)	0.33
0	0
Dynamic positioning	
Flow (m ³ /h)	4.44
Head required (m)	7
Frequency (1/min)	1584
Change of frequency C	53%
Efficiency [%]	46%
Power consumption (Kw)	0.33
Static system	
Harbor	
Flow (m ³ /h)	27.40
Head (m)	15
Frequency (1/min)	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption (Kw)	4.40
0	0
Transit	
Flow (m ³ /h)	27.4
Head (m)	27
Frequency (1/min)	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption (Kw)	4.40
0	0
Dynamic positioning	
Flow (m ³ /h)	27.4
Head (m)	27
Frequency (1/min)	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption (Kw)	4.40
Pump power consumption saving	
Harbor	
Power consumption with static system (Kw)	4.40
Power consumption with dynamic system (Kw)	0.33
Power saving (Kw)	4.07
Power saving potential [%]	92%
Power consumption scaling factor [1]	0.08
Transit	
Power consumption with static system (Kw)	4.40
Power consumption with dynamic system (Kw)	0.33
Power saving (Kw)	4.06
Power saving potential [%]	92%
Power consumption scaling factor [1]	0.08
Dynamic positioning	
Power consumption with static system (Kw)	4.40
Power consumption with dynamic system (Kw)	0.33
Power saving (Kw)	4.06
Power saving potential [%]	92%
Power consumption scaling factor [1]	0.08

Figure 8.12: Summary of power consumption during cold conditions using both flow restriction and frequency control

Summary of the pump calculations middle weather	
Dynamic system	
NB 32 125/01 Parallel	
Harbor	
Flow (m ³ /h)	4.00
Head required (m)	0
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	10%
Power consumption (Kw)	1.08
	0
Transit	
Flow (m ³ /h)	4.00
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	10%
Power consumption (Kw)	1.08
	0
Dynamic positioning	
Flow (m ³ /h)	4.00
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	10%
Power consumption (Kw)	1.08
	0
NB 32 125/01	
Harbor	
Flow (m ³ /h)	2.00
Head required (m)	0
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	11%
Power consumption (Kw)	0.55
	0
Transit	
Flow (m ³ /h)	2.00
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	10%
Power consumption (Kw)	0.55
	0
Dynamic positioning	
Flow (m ³ /h)	2.00
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	10%
Power consumption (Kw)	0.55
	0
NB 32-160/02	
Harbor	
Flow (m ³ /h)	2.00
Head required (m)	0
Frequency (1/min)	1800
Change of frequency C	68%
Efficiency [%]	10%
Power consumption (Kw)	1.05
	0
Transit	
Flow (m ³ /h)	2.00
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	68%
Efficiency [%]	9%
Power consumption (Kw)	1.05
	0
Dynamic positioning	
Flow (m ³ /h)	2.00
Head required (m)	7
Frequency (1/min)	1800
Change of frequency C	68%
Efficiency [%]	9%
Power consumption (Kw)	1.05
	0
Grundfos HYDRO MULTI-E 4	
Harbor	
Flow (m ³ /h)	2.00
Head required (m)	0
Frequency (1/min)	1800
Change of frequency C	53%
Efficiency [%]	25%
Power consumption (Kw)	0.31
	0
Transit	
Flow (m ³ /h)	1.66
Head required (m)	7
Frequency (1/min)	1584
Change of frequency C	53%
Efficiency [%]	21%
Power consumption (Kw)	0.31
	0
Dynamic positioning	
Flow (m ³ /h)	1.66
Head required (m)	7
Frequency (1/min)	1584
Change of frequency C	53%
Efficiency [%]	21%
Power consumption (Kw)	0.31
	0
Static system	
Harbor	
Flow (m ³ /h)	27.40
Head (m)	15
Frequency (1/min)	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption (Kw)	4.40
	0
Transit	
Flow (m ³ /h)	22.4
Head (m)	27
Frequency (1/min)	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption (Kw)	4.40
	0
Dynamic positioning	
Flow (m ³ /h)	27.4
Head (m)	27
Frequency (1/min)	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption (Kw)	4.40
	0
Pump power consumption saving	
Harbor	
Power consumption with static system (Kw)	4.40
Power consumption with dynamic system (Kw)	0.31
Power saving (Kw)	4.09
Power saving potential [%]	93%
Power consumption scaling factor [1]	0.07
Transit	
Power consumption with static system (Kw)	4.40
Power consumption with dynamic system (Kw)	0.31
Power saving (Kw)	4.09
Power saving potential [%]	93%
Power consumption scaling factor [1]	0.07
Dynamic positioning	
Power consumption with static system (Kw)	4.40
Power consumption with dynamic system (Kw)	0.31
Power saving (Kw)	4.09
Power saving potential [%]	93%
Power consumption scaling factor [1]	0.07

Figure 8.13: Summary of power consumption during average weather conditions using both flow restriction and frequency control

Summary of the pump calculations warm weather																																																																																																																																																																																																			
Dynamic system																																																																																																																																																																																																			
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr style="background-color: #f2f2f2;"> <th colspan="2" style="text-align: left;">NB 32 125/01 Parallel</th> </tr> </thead> <tbody> <tr style="background-color: #f2f2f2;"><td>Harbor</td><td></td></tr> <tr><td>Flow [m³/h]</td><td>4.00</td></tr> <tr><td>Head required [m]</td><td>0</td></tr> <tr><td>Frequency [1/min]</td><td>1800</td></tr> <tr><td>Change of frequency C</td><td>53%</td></tr> <tr><td>Efficiency [%]</td><td>10%</td></tr> <tr><td>Power consumption [Kw]</td><td>1.08</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Transeil</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>4.00</td></tr> <tr><td>Head required [m]</td><td>6</td></tr> <tr><td>Frequency [1/min]</td><td>1800</td></tr> <tr><td>Change of frequency C</td><td>53%</td></tr> <tr><td>Efficiency [%]</td><td>10%</td></tr> <tr><td>Power consumption [Kw]</td><td>1.08</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Dynamic positioning</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>4.00</td></tr> <tr><td>Head required [m]</td><td>6</td></tr> <tr><td>Frequency [1/min]</td><td>1800</td></tr> <tr><td>Change of frequency C</td><td>53%</td></tr> <tr><td>Efficiency [%]</td><td>10%</td></tr> <tr><td>Power consumption [Kw]</td><td>1.08</td></tr> </tbody> </table>	NB 32 125/01 Parallel		Harbor		Flow [m ³ /h]	4.00	Head required [m]	0	Frequency [1/min]	1800	Change of frequency C	53%	Efficiency [%]	10%	Power consumption [Kw]	1.08		0	Transeil	0	Flow [m ³ /h]	4.00	Head required [m]	6	Frequency [1/min]	1800	Change of frequency C	53%	Efficiency [%]	10%	Power consumption [Kw]	1.08		0	Dynamic positioning	0	Flow [m ³ /h]	4.00	Head required [m]	6	Frequency [1/min]	1800	Change of frequency C	53%	Efficiency [%]	10%	Power consumption [Kw]	1.08	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr style="background-color: #f2f2f2;"> <th colspan="2" style="text-align: left;">NB 32 125/01</th> </tr> </thead> <tbody> <tr style="background-color: #f2f2f2;"><td>Harbor</td><td></td></tr> <tr><td>Flow [m³/h]</td><td>2.00</td></tr> <tr><td>Head required [m]</td><td>0</td></tr> <tr><td>Frequency [1/min]</td><td>1800</td></tr> <tr><td>Change of frequency C</td><td>53%</td></tr> <tr><td>Efficiency [%]</td><td>10%</td></tr> <tr><td>Power consumption [Kw]</td><td>0.55</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Transeil</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>2.00</td></tr> <tr><td>Head required [m]</td><td>6</td></tr> <tr><td>Frequency [1/min]</td><td>1800</td></tr> <tr><td>Change of frequency C</td><td>53%</td></tr> <tr><td>Efficiency [%]</td><td>10%</td></tr> <tr><td>Power consumption [Kw]</td><td>0.55</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Dynamic positioning</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>2.00</td></tr> <tr><td>Head required [m]</td><td>6</td></tr> <tr><td>Frequency [1/min]</td><td>1800</td></tr> <tr><td>Change of frequency C</td><td>53%</td></tr> <tr><td>Efficiency [%]</td><td>10%</td></tr> <tr><td>Power consumption [Kw]</td><td>0.55</td></tr> </tbody> </table>	NB 32 125/01		Harbor		Flow [m ³ /h]	2.00	Head required [m]	0	Frequency [1/min]	1800	Change of frequency C	53%	Efficiency [%]	10%	Power consumption [Kw]	0.55		0	Transeil	0	Flow [m ³ /h]	2.00	Head required [m]	6	Frequency [1/min]	1800	Change of frequency C	53%	Efficiency [%]	10%	Power consumption [Kw]	0.55		0	Dynamic positioning	0	Flow [m ³ /h]	2.00	Head required [m]	6	Frequency [1/min]	1800	Change of frequency C	53%	Efficiency [%]	10%	Power consumption [Kw]	0.55	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr style="background-color: #f2f2f2;"> <th colspan="2" style="text-align: left;">NB 32-160/02</th> </tr> </thead> <tbody> <tr style="background-color: #f2f2f2;"><td>Harbor</td><td></td></tr> <tr><td>Flow [m³/h]</td><td>2.00</td></tr> <tr><td>Head required [m]</td><td>0</td></tr> <tr><td>Frequency [1/min]</td><td>1800</td></tr> <tr><td>Change of frequency C</td><td>68%</td></tr> <tr><td>Efficiency [%]</td><td>9%</td></tr> <tr><td>Power consumption [Kw]</td><td>1.05</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Transeil</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>2.00</td></tr> <tr><td>Head required [m]</td><td>6</td></tr> <tr><td>Frequency [1/min]</td><td>1800</td></tr> <tr><td>Change of frequency C</td><td>68%</td></tr> <tr><td>Efficiency [%]</td><td>9%</td></tr> <tr><td>Power consumption [Kw]</td><td>1.05</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Dynamic positioning</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>2.00</td></tr> <tr><td>Head required [m]</td><td>6</td></tr> <tr><td>Frequency [1/min]</td><td>1800</td></tr> <tr><td>Change of frequency C</td><td>68%</td></tr> <tr><td>Efficiency [%]</td><td>9%</td></tr> <tr><td>Power consumption [Kw]</td><td>1.05</td></tr> </tbody> </table>	NB 32-160/02		Harbor		Flow [m ³ /h]	2.00	Head required [m]	0	Frequency [1/min]	1800	Change of frequency C	68%	Efficiency [%]	9%	Power consumption [Kw]	1.05		0	Transeil	0	Flow [m ³ /h]	2.00	Head required [m]	6	Frequency [1/min]	1800	Change of frequency C	68%	Efficiency [%]	9%	Power consumption [Kw]	1.05		0	Dynamic positioning	0	Flow [m ³ /h]	2.00	Head required [m]	6	Frequency [1/min]	1800	Change of frequency C	68%	Efficiency [%]	9%	Power consumption [Kw]	1.05	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr style="background-color: #f2f2f2;"> <th colspan="2" style="text-align: left;">Grundfos HYDRO MULTI-E 4</th> </tr> </thead> <tbody> <tr style="background-color: #f2f2f2;"><td>Harbor</td><td></td></tr> <tr><td>Flow [m³/h]</td><td>1.21</td></tr> <tr><td>Head required [m]</td><td>0</td></tr> <tr><td>Frequency [1/min]</td><td>1584</td></tr> <tr><td>Change of frequency C</td><td>53%</td></tr> <tr><td>Efficiency [%]</td><td>15%</td></tr> <tr><td>Power consumption [Kw]</td><td>0.30</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Transeil</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>1.21</td></tr> <tr><td>Head required [m]</td><td>6</td></tr> <tr><td>Frequency [1/min]</td><td>1584</td></tr> <tr><td>Change of frequency C</td><td>53%</td></tr> <tr><td>Efficiency [%]</td><td>15%</td></tr> <tr><td>Power consumption [Kw]</td><td>0.30</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Dynamic positioning</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>1.21</td></tr> <tr><td>Head required [m]</td><td>6</td></tr> <tr><td>Frequency [1/min]</td><td>1584</td></tr> <tr><td>Change of frequency C</td><td>53%</td></tr> <tr><td>Efficiency [%]</td><td>15%</td></tr> <tr><td>Power consumption [Kw]</td><td>0.30</td></tr> </tbody> </table>	Grundfos HYDRO MULTI-E 4		Harbor		Flow [m ³ /h]	1.21	Head required [m]	0	Frequency [1/min]	1584	Change of frequency C	53%	Efficiency [%]	15%	Power consumption [Kw]	0.30		0	Transeil	0	Flow [m ³ /h]	1.21	Head required [m]	6	Frequency [1/min]	1584	Change of frequency C	53%	Efficiency [%]	15%	Power consumption [Kw]	0.30		0	Dynamic positioning	0	Flow [m ³ /h]	1.21	Head required [m]	6	Frequency [1/min]	1584	Change of frequency C	53%	Efficiency [%]	15%	Power consumption [Kw]	0.30
NB 32 125/01 Parallel																																																																																																																																																																																																			
Harbor																																																																																																																																																																																																			
Flow [m ³ /h]	4.00																																																																																																																																																																																																		
Head required [m]	0																																																																																																																																																																																																		
Frequency [1/min]	1800																																																																																																																																																																																																		
Change of frequency C	53%																																																																																																																																																																																																		
Efficiency [%]	10%																																																																																																																																																																																																		
Power consumption [Kw]	1.08																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Transeil	0																																																																																																																																																																																																		
Flow [m ³ /h]	4.00																																																																																																																																																																																																		
Head required [m]	6																																																																																																																																																																																																		
Frequency [1/min]	1800																																																																																																																																																																																																		
Change of frequency C	53%																																																																																																																																																																																																		
Efficiency [%]	10%																																																																																																																																																																																																		
Power consumption [Kw]	1.08																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Dynamic positioning	0																																																																																																																																																																																																		
Flow [m ³ /h]	4.00																																																																																																																																																																																																		
Head required [m]	6																																																																																																																																																																																																		
Frequency [1/min]	1800																																																																																																																																																																																																		
Change of frequency C	53%																																																																																																																																																																																																		
Efficiency [%]	10%																																																																																																																																																																																																		
Power consumption [Kw]	1.08																																																																																																																																																																																																		
NB 32 125/01																																																																																																																																																																																																			
Harbor																																																																																																																																																																																																			
Flow [m ³ /h]	2.00																																																																																																																																																																																																		
Head required [m]	0																																																																																																																																																																																																		
Frequency [1/min]	1800																																																																																																																																																																																																		
Change of frequency C	53%																																																																																																																																																																																																		
Efficiency [%]	10%																																																																																																																																																																																																		
Power consumption [Kw]	0.55																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Transeil	0																																																																																																																																																																																																		
Flow [m ³ /h]	2.00																																																																																																																																																																																																		
Head required [m]	6																																																																																																																																																																																																		
Frequency [1/min]	1800																																																																																																																																																																																																		
Change of frequency C	53%																																																																																																																																																																																																		
Efficiency [%]	10%																																																																																																																																																																																																		
Power consumption [Kw]	0.55																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Dynamic positioning	0																																																																																																																																																																																																		
Flow [m ³ /h]	2.00																																																																																																																																																																																																		
Head required [m]	6																																																																																																																																																																																																		
Frequency [1/min]	1800																																																																																																																																																																																																		
Change of frequency C	53%																																																																																																																																																																																																		
Efficiency [%]	10%																																																																																																																																																																																																		
Power consumption [Kw]	0.55																																																																																																																																																																																																		
NB 32-160/02																																																																																																																																																																																																			
Harbor																																																																																																																																																																																																			
Flow [m ³ /h]	2.00																																																																																																																																																																																																		
Head required [m]	0																																																																																																																																																																																																		
Frequency [1/min]	1800																																																																																																																																																																																																		
Change of frequency C	68%																																																																																																																																																																																																		
Efficiency [%]	9%																																																																																																																																																																																																		
Power consumption [Kw]	1.05																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Transeil	0																																																																																																																																																																																																		
Flow [m ³ /h]	2.00																																																																																																																																																																																																		
Head required [m]	6																																																																																																																																																																																																		
Frequency [1/min]	1800																																																																																																																																																																																																		
Change of frequency C	68%																																																																																																																																																																																																		
Efficiency [%]	9%																																																																																																																																																																																																		
Power consumption [Kw]	1.05																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Dynamic positioning	0																																																																																																																																																																																																		
Flow [m ³ /h]	2.00																																																																																																																																																																																																		
Head required [m]	6																																																																																																																																																																																																		
Frequency [1/min]	1800																																																																																																																																																																																																		
Change of frequency C	68%																																																																																																																																																																																																		
Efficiency [%]	9%																																																																																																																																																																																																		
Power consumption [Kw]	1.05																																																																																																																																																																																																		
Grundfos HYDRO MULTI-E 4																																																																																																																																																																																																			
Harbor																																																																																																																																																																																																			
Flow [m ³ /h]	1.21																																																																																																																																																																																																		
Head required [m]	0																																																																																																																																																																																																		
Frequency [1/min]	1584																																																																																																																																																																																																		
Change of frequency C	53%																																																																																																																																																																																																		
Efficiency [%]	15%																																																																																																																																																																																																		
Power consumption [Kw]	0.30																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Transeil	0																																																																																																																																																																																																		
Flow [m ³ /h]	1.21																																																																																																																																																																																																		
Head required [m]	6																																																																																																																																																																																																		
Frequency [1/min]	1584																																																																																																																																																																																																		
Change of frequency C	53%																																																																																																																																																																																																		
Efficiency [%]	15%																																																																																																																																																																																																		
Power consumption [Kw]	0.30																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Dynamic positioning	0																																																																																																																																																																																																		
Flow [m ³ /h]	1.21																																																																																																																																																																																																		
Head required [m]	6																																																																																																																																																																																																		
Frequency [1/min]	1584																																																																																																																																																																																																		
Change of frequency C	53%																																																																																																																																																																																																		
Efficiency [%]	15%																																																																																																																																																																																																		
Power consumption [Kw]	0.30																																																																																																																																																																																																		
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr style="background-color: #d9ead3;"> <th colspan="2" style="text-align: left;">Static system</th> </tr> </thead> <tbody> <tr style="background-color: #f2f2f2;"><td>Harbor</td><td></td></tr> <tr><td>Flow [m³/h]</td><td>27.40</td></tr> <tr><td>Head [m]</td><td>15</td></tr> <tr><td>Frequency [1/min]</td><td>3513</td></tr> <tr><td>Change of frequency C</td><td>98%</td></tr> <tr><td>Efficiency [%]</td><td>68%</td></tr> <tr><td>Power consumption [Kw]</td><td>4.40</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Transeil</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>27.4</td></tr> <tr><td>Head [m]</td><td>27</td></tr> <tr><td>Frequency [1/min]</td><td>3513</td></tr> <tr><td>Change of frequency C</td><td>98%</td></tr> <tr><td>Efficiency [%]</td><td>68%</td></tr> <tr><td>Power consumption [Kw]</td><td>4.40</td></tr> <tr><td></td><td>0</td></tr> <tr style="background-color: #d9ead3;"><td>Dynamic positioning</td><td>0</td></tr> <tr><td>Flow [m³/h]</td><td>27.4</td></tr> <tr><td>Head [m]</td><td>27</td></tr> <tr><td>Frequency [1/min]</td><td>3513</td></tr> <tr><td>Change of frequency C</td><td>98%</td></tr> <tr><td>Efficiency [%]</td><td>68%</td></tr> <tr><td>Power consumption [Kw]</td><td>4.40</td></tr> </tbody> </table>	Static system		Harbor		Flow [m ³ /h]	27.40	Head [m]	15	Frequency [1/min]	3513	Change of frequency C	98%	Efficiency [%]	68%	Power consumption [Kw]	4.40		0	Transeil	0	Flow [m ³ /h]	27.4	Head [m]	27	Frequency [1/min]	3513	Change of frequency C	98%	Efficiency [%]	68%	Power consumption [Kw]	4.40		0	Dynamic positioning	0	Flow [m ³ /h]	27.4	Head [m]	27	Frequency [1/min]	3513	Change of frequency C	98%	Efficiency [%]	68%	Power consumption [Kw]	4.40	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr style="background-color: #d9ead3;"> <th colspan="2" style="text-align: left;">Pump power consumption saving</th> </tr> </thead> <tbody> <tr style="background-color: #f2f2f2;"><td>Harbor</td><td></td></tr> <tr><td>Power consumption with static system [Kw]</td><td>4.40</td></tr> <tr><td>Power consumption with dynamic system [Kw]</td><td>0.30</td></tr> <tr><td>Power saving [Kw]</td><td>4.10</td></tr> <tr><td>Power saving potential [%]</td><td>93%</td></tr> <tr><td>Power consumption scaling factor [1]</td><td>0.07</td></tr> <tr style="background-color: #d9ead3;"><td>Transeil</td><td></td></tr> <tr><td>Power consumption with static system [Kw]</td><td>4.40</td></tr> <tr><td>Power consumption with dynamic system [Kw]</td><td>0.30</td></tr> <tr><td>Power saving [Kw]</td><td>4.10</td></tr> <tr><td>Power saving potential [%]</td><td>93%</td></tr> <tr><td>Power consumption scaling factor [1]</td><td>0.07</td></tr> <tr style="background-color: #d9ead3;"><td>Dynamic positioning</td><td></td></tr> <tr><td>Power consumption with static system [Kw]</td><td>4.40</td></tr> <tr><td>Power consumption with dynamic system [Kw]</td><td>0.30</td></tr> <tr><td>Power saving [Kw]</td><td>4.10</td></tr> <tr><td>Power saving potential [%]</td><td>93%</td></tr> <tr><td>Power consumption scaling factor [1]</td><td>0.07</td></tr> </tbody> </table>	Pump power consumption saving		Harbor		Power consumption with static system [Kw]	4.40	Power consumption with dynamic system [Kw]	0.30	Power saving [Kw]	4.10	Power saving potential [%]	93%	Power consumption scaling factor [1]	0.07	Transeil		Power consumption with static system [Kw]	4.40	Power consumption with dynamic system [Kw]	0.30	Power saving [Kw]	4.10	Power saving potential [%]	93%	Power consumption scaling factor [1]	0.07	Dynamic positioning		Power consumption with static system [Kw]	4.40	Power consumption with dynamic system [Kw]	0.30	Power saving [Kw]	4.10	Power saving potential [%]	93%	Power consumption scaling factor [1]	0.07																																																																																																												
Static system																																																																																																																																																																																																			
Harbor																																																																																																																																																																																																			
Flow [m ³ /h]	27.40																																																																																																																																																																																																		
Head [m]	15																																																																																																																																																																																																		
Frequency [1/min]	3513																																																																																																																																																																																																		
Change of frequency C	98%																																																																																																																																																																																																		
Efficiency [%]	68%																																																																																																																																																																																																		
Power consumption [Kw]	4.40																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Transeil	0																																																																																																																																																																																																		
Flow [m ³ /h]	27.4																																																																																																																																																																																																		
Head [m]	27																																																																																																																																																																																																		
Frequency [1/min]	3513																																																																																																																																																																																																		
Change of frequency C	98%																																																																																																																																																																																																		
Efficiency [%]	68%																																																																																																																																																																																																		
Power consumption [Kw]	4.40																																																																																																																																																																																																		
	0																																																																																																																																																																																																		
Dynamic positioning	0																																																																																																																																																																																																		
Flow [m ³ /h]	27.4																																																																																																																																																																																																		
Head [m]	27																																																																																																																																																																																																		
Frequency [1/min]	3513																																																																																																																																																																																																		
Change of frequency C	98%																																																																																																																																																																																																		
Efficiency [%]	68%																																																																																																																																																																																																		
Power consumption [Kw]	4.40																																																																																																																																																																																																		
Pump power consumption saving																																																																																																																																																																																																			
Harbor																																																																																																																																																																																																			
Power consumption with static system [Kw]	4.40																																																																																																																																																																																																		
Power consumption with dynamic system [Kw]	0.30																																																																																																																																																																																																		
Power saving [Kw]	4.10																																																																																																																																																																																																		
Power saving potential [%]	93%																																																																																																																																																																																																		
Power consumption scaling factor [1]	0.07																																																																																																																																																																																																		
Transeil																																																																																																																																																																																																			
Power consumption with static system [Kw]	4.40																																																																																																																																																																																																		
Power consumption with dynamic system [Kw]	0.30																																																																																																																																																																																																		
Power saving [Kw]	4.10																																																																																																																																																																																																		
Power saving potential [%]	93%																																																																																																																																																																																																		
Power consumption scaling factor [1]	0.07																																																																																																																																																																																																		
Dynamic positioning																																																																																																																																																																																																			
Power consumption with static system [Kw]	4.40																																																																																																																																																																																																		
Power consumption with dynamic system [Kw]	0.30																																																																																																																																																																																																		
Power saving [Kw]	4.10																																																																																																																																																																																																		
Power saving potential [%]	93%																																																																																																																																																																																																		
Power consumption scaling factor [1]	0.07																																																																																																																																																																																																		

Figure 8.14: Summary of power consumption during warm conditions using both flow restriction and frequency control

As shown in the tables above, there is a large potential for power saving in the central heating pump. As expected, the largest potential is with both flow restriction and frequency control, although the difference in power savings between the two solutions was surprisingly small. The two solutions have the potential to save ~ 70-80 % and ~ 90 % of the power consumed by the central heating pump respectively, where the largest potential is during warm conditions. This is because with a constant flow system, the power consumption is relatively constant, even if the demand for heat is low. This implies that if a vessel operates in warmer conditions than were assumed, then the potential for power saving would be even greater.

The pumps that were compared had some limitations in flow and frequency range that had to be accounted for. Because of the large variations of flow and pressure drop, it was hard to find a pump configuration that would be able to work well at low capacity, while still being cost-efficient. This is therefore a necessary compromise to keep the costs low, however as the calculations show there is still a large potential to save power.

8.7.3 Electrical Load Calculations

This vessel has four engines, with a marine diesel generator. Two of the engines are Caterpillar 3512C as shown in figure 8.15, with electric output of 1700 ekW. The other two engines are the Caterpillar C32 as shown in figure 8.16, with an electric output of 940 ekW. In harbour mode there is only one engine in use with 940 ekW in and the power load is 81 %. DP mode uses all four engines, each of which has a power load of 73.1 %. Also, transit mode has all engines in use, with each engine having a power load of 77.6 %.




Figure 8.15: Caterpillar 3512C engine

[18]




Figure 8.16: Caterpillar C32 engine

[19]

The fuel consumption per ekWh produced by the engines is also specified in the datasheet. These values can be found in figure 8.17.

Fuel Consumption data	
Harbor	
Fuel consumption per [g/Kwh]	215.50
Transit	
Fuel consumption per [g/Kwh]	202.80
Dynamic positioning	
Fuel consumption per [g/Kwh]	203.25

Figure 8.17: Fuel consumption per ekWh generated by the engines

8.7.4 Potential Fuel Savings

To calculate the potential savings would be the fuel price has to be considered as well. The engines use Marine Gas Oil (DMA/MGO) fuel, to find an estimation of the average fuel price, a contact person from Bunker Oil Norway was contacted. The average price was found to be 18 kr/L. In this project, it is assumed that the vessel will operate with Norwegian fuel prices.

8.7.5 Potential Emissions Savings

The potential fuel savings would also result in a reduced environmental impact on the vessel. The environmental impact can be quantized by calculating the potential reduction of greenhouse gasses, caused by fuel consumption.

CO₂

CO₂ is a well-known greenhouse gas. It is abundant in the atmosphere, however high concentrations of it cause a greenhouse effect. It is common to compare other greenhouse gasses with an CO₂ equivalent, this is because CO₂ is the most well-known greenhouse gas, which makes this a good metric to compare different types of emissions [20].

NO_x

NO_x is a common term for nitrogen oxides: N_2O , NO , N_2O_3 , NO_2 . These are all poisonous gasses and can cause asthma and other respiratory infections [21].

CO

CO is an odorless and colorless gas that is a common component in air pollution. High concentrations of the gas can cause major health problems by restricting oxygen delivery to the cells. Lower concentrations of it can also increase the risk of cardiovascular disease [22].

HC

HC gas is a common term for different hydrocarbons, including methane and propane. Which are gasses composed of only hydrogen and carbon bonds. These gasses are known to cause major health risks such as the increased risk of cancer and they can have a large environmental impact depending on which type of HC gas that is present [23].

Part Matter

Part matter is a common term for particles such as soot, ash, or fluid that are emitted as a result of incomplete combustion. This is most common in diesel combustion. Exposure to part matters can increase the risk of skin cancer, lung cancer and bladder cancer. It can also cause damage to the genetic material [24].

The emissions were calculated by using the provided specification for emissions per hour of engine runtime and fuel consumption per hour at a specific engine speed. The calculation was done with the specifications for the CAT 3512C engine. Even if the fuel consumption and emissions values differ, the relation between the two is relatively unchanged. The emissions were specified as grams per hour, for these purposes it would be beneficial to convert this to grams of emissions per kg of fuel consumed. If it's assumed that the emissions per hour and fuel consumption per hour are constant, then the relation between them would be as shown in formula 8.7.

$$\frac{Emissions/hr}{V_{fuel}/hr} = \frac{Emissions}{V_{fuel}} \quad (8.7)$$

To convert this to unit mass, the density of the fuel would have to be considered. For DMO/GMA the density is 0.89 kg/L and the mass can be found by the relation between mass and volume.

$$\begin{aligned} \rho_{fuel} &= \frac{V_{fuel}}{m_{fuel}} \\ V_{fuel} &= m_{fuel} \cdot \rho_{fuel} \\ \frac{Emissions}{m_{Fuel}} &= \frac{Emissions/hr}{V_{fuel}/hr \cdot \rho_{fuel}} \end{aligned} \quad (8.8)$$

That yields the following data for grams of emissions per kg of fuel.

	Hourly emissions	Hourly fuel consumption	Emissions per unit mass of fuel consumed
Units	kg/hr	L/hr	g/kg fuel
CO ₂	841	323.9	2918
NO _x	8547	323.9	29649
CO	458	323.9	1189
HC	265	323.9	919
Part matter	69.6	323.9	241

Table 8.5: Emission data per unit mass of fuel consumed [19]

9 Concept for a Dynamic System

By considering the results from the power consumption calculations and the available options for controlling. The solution that was chosen was a dynamic flow system using just flow restriction by throttling, without automatic frequency control. Even if a system using active frequency control to reduce the pressure drop, would be even more efficient. The reason this was chosen was to reduce the installation and development costs. As the power consumption calculations show, this system would still have a large impact on power consumption. This new system would require different pumps and dynamic valves. The three-way motor-operated valve and the dynamic valves which are placed on each AHU are replaced with dynamic valves.

9.1 Choice of Pump System

The selected pump is a Grundfos Hydro Multi-E 4 CRE 10-3 as shown in figure 9.1. This is the pump that proved to be the most efficient by the calculations in section 8.6. This pump has a different pipe dimension on the inlet/outlet than the original pump, which means the pipe dimensions would have to be changed to DN80 instead of DN100. The selected pump system has four pumps connected in parallel, with one of the pumps used as a backup.



Figure 9.1: Grundfos Hydro Multi-E 4 CRE 10-3

[25]

9.2 Choice of Valves

9.2.1 Pressure Independent Actuator Controlled Valves

In order to control the flow to the AHUs there has to be installed pressure independent dynamic valves. These valves ensure that the flow in each branch is as desired, as long as the pressure is between the working range. The selected dynamic valves are Frese Optima Compact with actuator control, illustrated in figure 9.2, these valves can be programmed to deliver a set flow based on the temperature of the air current going out from the AHUs. These valves would replace the three-way valves and the pressure-independent valves, currently located by the three AHUs. These valves have the possibility to fully close the flow, however, they have a minimum required flow that guarantees the right flow. If the valves are controlled by temperature output, this would not be a problem, since the valve would regulate to deliver the desired temperature output.




Figure 9.2: Frese Actuator Control Valve

[11]

9.2.2 Bleed Valve

To ensure the flow through the central heating pump is always above the minimum requirement, there has to be installed a bleed valve. This is a valve that bypasses the consumers with a constant minimum flow, unlike the three-way valves that bypass the consumer to control the heat, and the flow through the bleed valves is much smaller. The placement of these valves can be found in the attachment A.2. These valves are installed by the consumer that has the lowest differential pressure over it, this is to ensure that none of the consumers will be bypassed by the bleed valve. In this case, the bleed valve will be installed by AHU1.

The valve that was chosen was a Frese Sigma Compact DN25 High valve. This valve has a flow range from $0.14\text{-}2.4 \text{ m}^3/\text{h}$, which means that it will be suitable to ensure a minimum flow through the pump at $1.21 \text{ m}^3/\text{h}$. This valve will have a constant flow, that would have to be accounted for. This was considered when concluding the power consumption savings, although this has very little effect.

9.3 Performance during Worst-Case Scenario

Even if this central heating system likely would never operate at full capacity over longer periods of time, except during the startup of the system, it is still important that the system can function even in a worst-case scenario. The worst-case scenario for this system would be where all the consumers are in use at 100 % capacity. To determine if the system would function properly, the power consumption spreadsheet was once again used to calculate the power consumption. Similar to the calculations done in cold, middle and warm conditions, however in this calculation all the consumers were set to active, and at a 100 % capacity. The results of the calculations are shown in figure 9.3 and 9.4.




Figure 9.3: Pump calculations during worst case scenario for the Hydro Multi-E 4 pump

Pump power consumption saving	
Barbar	
Power consumption with static system [Kw]	4.73
Power consumption with dynamic system [Kw]	5.68
Power saving[Kw]	-0.95
Power saving potential [%]	-20%
Power consumption scaling factor [1]	1.20
Barab	
Power consumption with static system [Kw]	4.73
Power consumption with dynamic system [Kw]	5.68
Power saving[Kw]	-0.95
Power saving potential [%]	-20%
Power consumption scaling factor [1]	1.20
Dynamic positioning	
Power consumption with static system [Kw]	4.73
Power consumption with dynamic system [Kw]	5.68
Power saving[Kw]	-0.95
Power saving potential [%]	-20%
Power consumption scaling factor [1]	1.20

Figure 9.4: Pump calculations summary comparing the original system with a dynamic system

These calculations show that the chosen pump system would function even at full capacity, with an efficiency of $\sim 65\%$ which could be considered acceptable. The efficiency of the pump at this working point is somewhat lower than the original pump. This is because the original pump is optimized to work at this working point. Since the system likely would never work at this point over longer periods of time, this is acceptable. It can therefore be concluded that this system would also work well at full capacity.

9.4 Conclusions of the Total Savings

Now that all the components for the dynamic central heating system have been assessed and considering the assumptions made in section 8 it is possible to come to a conclusion of the total annual savings in fuel costs and emissions.

Summary of potential annual savings from all weather conditions	Cold conditions	Middle conditions	Warm conditions	Total annual savings		
Total annual savings	NOK 35 799	NOK 24 952	NOK 41 868	NOK 102 619		
Total annual fuel saving [kg]	1989	1386	2326	5 701		
Emissions						
Annual Co2 emissions [kg]	5803	4045	6787	16636		
Annual Nox emissions [kg]	59.0	41.1	69.0	169.0		
Annual Co emissions [kg]	3.2	2.2	3.7	9.1		
Annual HC emissions [kg]	1.8	1.3	2.1	5.2		
Annual part matter emissions [kg]	0.5	0.3	0.6	1.4		
Power scaling factor						
Harbor	0.33	0.27	0.24	0.28		
Potential power saving [%]	0.67	0.73	0.76	72%		
Distrobution throughout year	5.6%	3.6%	5.9%	15.0%		
Transit						
Transit	0.32	0.27	0.25	0.28		
Potential power saving [%]	68%	73%	75%	72%		
Distrobution throughout year	1%	1%	1%	3.5%		
Dynamic positioning						
Dynamic positioning	0.32	0.27	0.25	0.28		
Potential power saving [%]	68%	73%	75%	72%		
Distrobution throughout year [%]	30%	20%	32%	82%		
				Total Power saving factor	0.28	
Yearly distrobution check:				100%	Total power saving [%]	72%

Figure 9.5: Conclusions for the total annual savings in a dynamic central heating system using flow restriction

As shown in figure 9.5 the annual fuel-saving potential is 5 800 Kg/year, which would result in a reduction of fuel cost of 100 000 NOK/year. The details of greenhouse gas savings can be found under the "Total annual savings" column in the rows marked in green.

By considering the distribution spent in each mode and weather condition, it was also possible to calculate an average power saving factor, which is the proportional power saving in the central heating pump. This was calculated to be 0.28 on average, meaning that the power consumption in this optimized system is 28 % of the original system. This is an average power-saving potential of 72 %. It is important that this potential for power saving is for the central heating pump, this should not be confused with the total fuel consumption for the vessel, the power saving in the pump would be minuscule compared to the power consumption of the entire vessel.

9.5 System Documents

The documents described in this section are important system documents, normally produced by the machinery department when designing a system such as this. These documents help communicate the purpose and logic of the system to other departments, as well as other parties with an interest in the project.

P & ID

The Piping & Instrumentation Diagram (P & ID) shows the system schematically with pipe dimensions and valves. This is a schematic drawing of the components in the system, as well as the piping.

A.2

System Description

This is the written description to use alongside the P & ID and explains the system briefly. This makes it easy for someone to understand how the system works and how the components cooperate. This is very similar to the abstract of function, however, this document is less technical. The system description is meant to be understood by a person having some technical understanding, unlike the abstract of function, which requires slightly more knowledge about the system in general.

A.3

Abstract of Function

The abstract of function is a document that describes the contents in the P & ID in plain text. As the name implies, this is an abstract of how the system functions, where all the main components are described.

A.4

Armature List


This list shows all the components, including supplier and size. The armature list contains more detailed information of each component in the P & ID.

A.5

9.6 Eco Design

Eco design are requirements set by the EU and applies to electric motors that use variable-speed drives. This implies that these regulations apply to the central heating pump used in this project. The regulations set requirements for the efficiency of the pumps.

2.2.02 Motors - Step 2: Starting 1st July 2023



Picture 3: Starting 1st July 2023

Figure 9.6: Eco design regulations for motors starting July 1st 2023

Since the pumps have a power rating above 0.75 kW and below 75 kW, and the motor has two poles, the regulations require the pumps to be in an efficiency class of IE3 or above [26]. In the Grundfos data sheet it is specified that the pumps have an efficiency rating of IE5, which means that these pumps satisfy EU regulations for eco design.

9.7 How Can This Work be Used in Future Projects

The calculations done in this project are done on a relatively small central heating system. Meaning that there is potential for even greater savings in larger systems. It is therefore important that the work done with this system can be transferred to other projects. The results from these calculations could be used directly as a factor to estimate the power savings as a proportion to the current power consumption, or the documents produced in this project can be used to do a more detailed calculation. The documents were therefore created such that it would be easy for other engineers to do calculations for similar projects.

Calculations on a similar project will probably be done by engineers at Vard Design &

Engineering, it can therefore be assumed that the final users of these documents will have some understanding of software such as SF Pressure Drop and Microsoft Excel. This is something that will be accounted for when considering the user-friendliness of these documents.

A good indication of the proportional savings in other central heating systems is the relation between the capacity that the system is normally running, versus the capacity that the system is designed to run at. The existing system on this vessel, for example, is designed to deliver flows at $36.2 \text{ m}^3/h$, however, it usually requires flows significantly lower than that. This means that the system has great potential. A system that is normally running at a capacity close to full capacity, would probably have a much smaller potential.

9.7.1 User Tests

It is important that the work done in this project can be utilized in future projects. Therefore, the method to perform these calculations has to be user-friendly. To make it easy for other users to use this method for calculating potential fuel savings, a user manual was created for the entire procedure. This can be found in attachment A.1. To make sure the user manual and documents were as user-friendly as possible, engineers at Vard were provided the user manual and documents without further explanation of how to use the method to do calculations. The feedback received was positive that this is something that can be used in future projects.

10 Economic Analysis

When considering if switching to a dynamic system would be financially beneficial, an economic analysis has to be performed. This analysis accounts for the increased purchase costs as well as the annual potential for fuel savings. When it comes to the installation and maintenance cost, there is no indication that this system would have higher costs, since it is very similar to the existing system with just some modifications in a few of the parts. There is a possibility that these costs would be lower in a dynamic flow system, since a pump running at lower capacity would have less wear and there are fewer parts that have to be installed. Nevertheless, this analysis will not consider a difference in installation and maintenance costs.

10.1 Purchase Cost

The increased purchase cost can be assessed by considering the cost of the original parts, compared to the cost of the parts needed for the dynamic central heating system. The parts that will no longer be used are Oventropp three-way valve, Frese Sigma Compact valve for AHU1, AHU2 and AHU3 and Grundfos CR32-2-2 pump.

The parts that have to be installed in the new system are Frese Optima Compact for AHU1, 2, and 3, Frese Sigma Compact as a bleed valve, and Grundfos HYDRO MULTI-E 4 CRIE 10-3 circulation pump.

Because of competitive advantages, the exact prices of specific parts cannot be revealed, although the difference in price between the two systems will be used for economic analysis. The price difference was calculated by contacting the suppliers and asking for a price estimation for each part. The euro exchange rate that was used was the exchange rate as of May 9th 2023, even if the exchange rate would vary, this is just an indication of the economic benefit. The new pump is quite a bit more expensive than the original pump, while the price of the armature is relatively unchanged. A summary of the price difference can be found in table 10.1, where a positive value indicates the increased cost of a dynamic system.

Price difference on armature	-18 598 kr
Price difference on pump system	230 771 kr
Total price difference	212 173 kr

Table 10.1: Price difference for armature and pump system

10.2 Return on Investment

With the conclusions from sections 9.4 and 10.1 it is now possible to determine a return on investment. This is an indication of the amount of time before the economic benefits would outperform the increased costs. This would provide a value that makes it easy for a customer to visualize the benefits, and therefore easier to sell.

Total increase of purchase costs	212 173 kr
Annual savings	102 619 kr/year
Return on investment	2.1 years

Table 10.2: Total increase of purchase costs, annual savings and return on investment

11 Possibilities for the Use of Alternative Fuels

Because of the limited timeframe, it was decided to not include part four of the project in this project. This was done in cooperation with our supervisor at Vard Design & Engineering, Runar Fiske and our supervisor at NTNU, Lars Petter Bryne. While this segment was intended to be optional rather than mandatory, its inclusion hinged on the availability of sufficient time. As of writing this May 10th 2023 it is evident that this part has to be abandoned. If this part were to be included, it would not be comprehensive enough to actually bring something useful to this project. It was instead decided to focus on the three other parts of the project.

12 Conclusion

The purpose of this project was to investigate if there is potential to save power by doing changes to an already existing central heating system onboard a service operative vessel. Previously to this project, it was suspected that changing from a system using constant flow, to a system that dynamically controls the flow and differential pressure could save a significant amount of power, which results in lower fuel consumption and greenhouse gas emissions. This was something Vard Design & Engineering wanted to confirm.

In this project, the group analyzed an existing central heating system and performed calculations such as pressure drop, heat loss, and heat demand. With these results, it was possible to come up with alternative solutions for the central heating system, to lower the power consumption. In this project, the main emphasis has been on optimization of the pumps. There were two solutions that were considered for a dynamic flow system. The first solution was a system that uses both frequency control of the pumps, along with flow restriction to each consumer. The second solution was a system using just flow restriction. Expectedly, it was found that the first solution had the greatest potential for power saving, however, this system would be significantly more complex than the second solution. It was therefore decided to proceed with a system using just flow restriction. The system has been redesigned with changes in some valves, as well as the pump system. It was concluded this system has the potential to save $\sim 70\%$ of the power consumed by the central heating pumps, which results in an annual fuel saving of $\sim 100\,000$ NOK. With the estimated increase in installation costs compared to the original constant flow system, this investment would have a return on investment of 2.1 years.

After finishing this project, the group is convinced that the topics presented in this project should be explored further. The calculations made here show that there could be a large potential to save fuel in a relatively small central heating system, however, it can therefore be concluded that this research is worth proceeding with.

13 Future Work

While this project contains a comprehensive comparison of a system using constant flow and a system using various solutions for dynamic flow, there are still some improvements that can be done to the system. Unfortunately, there was not enough time to include these topics in the project, however, this section presents some suggestions on topics that could further improve this system.

13.1 Belimo Energy Valves

Pressure-independent flow and power control and transparent monitoring of heating systems are provided by the Belimo Energy valve. These valves are ensuring that they are not operated with a low temperature difference in the central heating fluid. According to the supplier, these valves are intelligent pressure-independent valves that can be connected to Belimo Cloud. Which is an application that monitors energy consumption and provides evaluations to improve product and system quality.

13.2 User Interface

In order to do calculations on similar vessels efficiently, it is important that the method and documents used to do the calculations are as user-friendly as possible. The feedback received from what has been produced in this project was positive, however, there is still room for improvement. Even if this method would possibly save a lot of time from doing the calculations from scratch, it is still a time-consuming process. Creating software to fully automate the process of calculating fuel save potential would be too comprehensive for this system. Still, this is something that can be explored in future systems. There is a possibility to use the 3D-model along with simulation software to automatize the pressure-drop calculations and use the results in the power consumption calculations.

13.3 Verifying the Calculations

Manual calculations have an uncertainty that must be taken into account. The results from these calculations should therefore be compared to real-life experiments. Values such as pressure drop, heat loss, and power consumption of the pump should be compared to

empirical data.

13.4 Further Improvements of the Pumping System

As of now the central heating pump and the freshwater evaporator pump are connected in parallel. There is a possibility that it could be beneficial to gather these two pumps in one pump system and control the entire system using pressure-independent valves, and frequency control. This would increase the range the pumps have to work well in, and it should be investigated if this has the potential to save even more power.

The possibility to connect the fresh water evaporator branch to the main pumping system could be explored. This would require an upscaling of the main pumping system. A possibility could be to connect several pumps in parallel with the two existing pumps and have them work together, with one as a backup. This would have to be explored further.

13.5 Alternative Fuels

The possibility to utilize an alternative fuel for this central heating system is also something that should be explored further. This can be done by using fuel like methanol, hydrogen, ammonia, or other low-carbon fuels. These fuels can be used to provide heat and replacing the oil heating that is occasionally used when the heat from the engines are low. There is also a possibility to use alternative fuels to generate electricity for the central heating system, as well as the rest of the vessel. The implications that these fuels would have is something that should be explored further.

13.6 Exploring how the Calculations Scale

As mentioned earlier, these calculations were done on a relatively small central heating system, it is still unclear however how these results would scale in a different size system. The proportional savings are probably dependent on the relationship between what the system is designed to work at, and what the system is normally working at. If the proportional savings is linear to the size of the pump, then transferring these results to systems of different sizes would be very easy, with the power saving factor explained in subsection 9.4. This is something that would have to be explored further in order to be verified.

References

- [1] *CR 32-2-2 A-J-A-E-HQQE* — Grundfos. NaN. URL: <https://product-selection.grundfos.com/products/cr-cre-cri-crie-crn-crne-crt-crte/cr/cr-32-2-2-96122256?tab=variant-curves&pumpssystemid=2096213958> (visited on 04/24/2023).
- [2] Process Engineer's Tools. *Heat loss calculation of insulated pipe to air (with calculator Excel)*. NaN. URL: https://myengineeringtools.com/Thermodynamics/Heat_Loss_Insulated_Pipe.html (visited on 03/22/2023).
- [3] Vard Design & Engineering. *STD-104-0030 Pipe Insulation Standard*. 2020.
- [4] *The Economic and Environmental Impact of Greenhouse Heating Pipe Insulation*. 2022. URL: <https://www.mdpi.com/2071-1050/14/1/549> (visited on 04/26/2023).
- [5] *AlfaLaval, PureBilge*. URL: <https://www.alfalaval.no/produkter/separering/sentrifugalseparatorer/separatorer/purebilge/> (visited on 02/16/2023).
- [6] *AlfaLaval PureBilge*. URL: <https://www.alfalaval.com/globalassets/documents/products/separation/centrifugal-separators/alfa-laval-purebilge-white-paper.pdf> (visited on 02/16/2023).
- [7] Alfa Laval. *Installation Manual Freshwater Generator AQUA type Blue C80 HW*. 2022.
- [8] Marinfloc M. Gombrii K. Erikson. *Black and Grey Water*. Marinfloc, 2016.
- [9] *EGO spjeldventil, EPDM sete, syrefast spjeld, LUG, PN10/16 |Dahl.no*. NaN. URL: https://www.dahl.no/industri/industriarmaturer/ventiler/ego-spjeldventil-epdm-sete-syrefast-spjeld-lug-pn1016-bs%5C_bd%5C_1380606474178?v=BS%5C_BD%5C_5521304 (visited on 02/16/2023).
- [10] *Stengbar tilbakeslagsventil GG25, rettløp, flenset. Fig. 10.159.SD* — Dahl.no. NaN. URL: https://www.dahl.no/industri/industriarmaturer/ventiler/stengbar-tilbakeslagsventil-gg25-rettlop-flenset.-fig.-10.159.sd-bs_bd_1467607985203 (visited on 03/16/2023).
- [11] *Frese SIGMA Compact DN50-DN300*. NaN. URL: <https://www.frese.eu/hvac/da-DK/Produkter/Dynamiske-flowbegransere/Frese-SIGMA-Compact-DN50-DN300> (visited on 02/23/2023).

- [12] *Frese SIGMA Compact DN15-DN50*. NaN. URL: <https://www.frese.eu/hvac/en-GB/Products/Flow-Limiting-Valves/Frese-SIGMA-Compact--DN15-DN50> (visited on 02/16/2023).
- [13] *Ball Valve - How They Work* |Tameson.com. NaN. URL: <https://tameson.com/pages/ball-valve-introduction> (visited on 02/16/2023).
- [14] *AVTB and AVTB-RA temperature controllers — Danfoss*. NaN. URL: <https://www.danfoss.com/en-us/products/dhs/differential-pressure-and-flow-controllers/self-acting-temperature-controllers/avtb-and-avtb-ra-temperature-controllers/#tab-overview> (visited on 03/14/2023).
- [15] *World's Largest Offshore Wind Farm Opens in North Sea — Engineering News-Record*. NaN. URL: <https://www.enr.com/articles/54739-worlds-largest-offshore-wind-farm-opens-in-north-sea> (visited on 03/27/2023).
- [16] Visual Crossing Corporation. *Historical Weather Data Weather Forecast Data at Grimsby 2020-2021— Visual Crossing*. 2023. URL: <https://www.visualcrossing.com/weather-data> (visited on 04/27/2023).
- [17] Visual Crossing Corporation. *Historical Weather Data Weather Forecast Data at Sea Position 53°53'06.0"N 1°47'27.6"E 2020-2021— Visual Crossing*. 2023. URL: <https://www.visualcrossing.com/weather-data> (visited on 04/27/2023).
- [18] *CAT 3512C – Pon Power Concept Explorer*. NaN. URL: <https://www.ponconcept.no/engine/3512c--1700ekw-1800rpm-marelli-dep> (visited on 04/19/2023).
- [19] *CAT C32 – Pon Power Concept Explorer*. NaN. URL: <https://www.ponconcept.no/engine/c32-940ekw-1800rpm-marelli-water-cooled> (visited on 04/19/2023).
- [20] *karbondioksid – Store norske leksikon*. NaN. URL: <https://snl.no/karbondioksid> (visited on 05/08/2023).
- [21] *Hva er NOx?* NaN. URL: <https://www.noxfondet.no/artikler/hva-er-nox/> (visited on 05/08/2023).
- [22] *Air Pollution from Carbon Monoxide - Texas Commission on Environmental Quality - www.tceq.texas.gov*. NaN. URL: <https://www.tceq.texas.gov/airquality/sip/criteria-pollutants/sip-co> (visited on 05/08/2023).
- [23] *eksos – Store norske leksikon*. NaN. URL: <https://snl.no/eksos> (visited on 05/08/2023).

- [24] *polysykliske aromatiske hydrokarboner* – *Store norske leksikon*. NaN. URL: https://snl.no/polysykliske_aromatiske_hydrokarboner (visited on 05/08/2023).
- [25] *HYDRO MULTI-E 4 CRE 10-3 - 98486764* — *Grundfos*. NaN. URL: <https://product-selection.grundfos.com/no/products/hydro-multi-e/hydro-multi-e-4-cre-10-3-98486764?tab=variant-curves&pumpsystemid=2081582923> (visited on 04/19/2023).
- [26] Capiel and Cemp. *Information about the Ecodesign Regulation (EU) 2019/1781 for Motors and Drives from CAPIEL and CEMEP*. Marinfloc, 2019.

List of Figures

7.1	P&ID of the central heating system	11
7.2	Grundfos C32 Centrifugal Pump	13
7.3	Main pumps connected in parallel on another SOV	14
7.4	Illustration of the constants for calculating the heat-loss in a pipe [4].	15
7.5	Illustration of Bilge Water Separator [6]	19
7.6	Aqua Blue C100-HW86-108 freshwater generator from AlfaLaval	20
7.7	Daily water production	21
7.8	Pressure drop overview	22
7.9	Lug butterfly valve [9].	23
7.10	k_v values of butterfly valves provided by Brødrene Dahl	24
7.11	Non-return closable valve	24
7.12	Illustration of a system curve using a dynamic regulating valve	25
7.13	Frese Sigma Compact flanged dynamic valve & Frese Sigma Compact dy- namic valve with pre-set	26
7.14	Ball valve mechanism [13]	26
7.15	Self-acting control valve[14]	27
7.16	Oventropp 3-way valve	28
7.17	k_{vs} -values for Oventrop three-way valves	28
8.1	Pump curve	32
8.2	Illustration of the system border for the shaft efficiency	33
8.3	The effect of frequency control	35
8.4	Distribution of average daily temperatures at Grimsby [16]	38
8.5	Distribution of average daily temperatures at sea outside of Grimsby [17]	38
8.6	Heat calculation during cold conditions	41
8.7	Heat calculation during cold conditions.	42
8.8	Pump calculations in the original constant flow system	43
8.9	Summary of power consumption during cold conditions using flow restriction	44
8.10	Summary of power consumption during average weather conditions using flow restriction	45
8.11	Summary of power consumption during warm conditions using flow restriction	46

8.12 Summary of power consumption during cold conditions using both flow restriction and frequency control	47
8.13 Summary of power consumption during average weather conditions using both flow restriction and frequency control	48
8.14 Summary of power consumption during warm conditions using both flow restriction and frequency control	49
8.15 Caterpillar 3512C engine	50
8.16 Caterpillar C32 engine	50
8.17 Fuel consumption per ekWh generated by the engines	51
9.1 Grundfos Hydro Multi-E 4 CRE 10-3	54
9.2 Frese Actuator Control Valve	55
9.3 Pump calculations during worst case scenario for the Hydro Multi-E 4 pump	56
9.4 Pump calculations summary comparing the original system with a dynamic system	57
9.5 Conclusions for the total annual savings in a dynamic central heating system using flow restriction	58
9.6 Eco design regulations for motors starting July 1st 2023	60

List of Tables

7.1 Heat loss in branches and sections	16
7.2 Values for freshwater generation for service vessels [8].	20
7.3 Hourly distribution in each mode	30
7.4 The consumers and when they are active in each mode	30
8.1 The polynomial used to estimate the pump and efficiency curves at varying flows and frequencies	36
8.2 The polynomial used to estimate the pump and efficiency curves at varying flows and frequencies	36
8.3 Temperatures at Grimsby	38
8.4 Temperatures at sea outside of Grimsby	38
8.5 Emission data per unit mass of fuel consumed [19]	53
10.1 Price difference for armature and pump system	63

10.2 Total increase of purchase costs, annual savings and return on investment . 63

A Attachments

A.1 Pump Calculation User Manual

Calculating the Potential Fuel Savings in a Central Heating System



a **Fincantieri** company

Introduction

This is a user manual on how to calculate the potential for fuel savings as well as savings in emissions for a central heating system. This can be achieved by switching from a constant flow system to a system using dynamic valves to regulate the flow in the system.

A constant flow system is hereby used to describe a system using a fixed pump speed with three-way regulating valves to bypass the flow to obtain the desired temperature output. In most cases, this is wasteful since the pump uses unnecessary power to pump the excess fluid around the system.

The power consumption of the pump can be reduced by having flow-regulating valves as well as a frequency-controlled pump, resulting in lower fuel consumption. This method compares results from just flow-regulating valves with a constant pump speed, a system using both flow-regulating valves and frequency controlling and a traditional constant flow system.

The results from this calculation will have significant uncertainty, however it will give an indication of what the potential fuel savings could be.

Step 1 – split and measure the pipe system

Gain an overview of the system and the consumers. Then chose the main pipeline where the flow is assumed to be highest. Split it into sections and branches where the pipe changes dimensions or where it's natural to split it.

Measure the entire piping system, all the bends and everything that will result in a pressure drop. The 3D-model in Navisworks is very helpful. If some pipes don't exist in the model, measure it in GA in AutoCAD.

All the measurements can be typed into the template Pipe Dimensions as shown in the screenshot below.

	Unit	Branch 1 Hot side	Branch 2 Cold side	Bilge water seperator
		Value		Value
Pipe diameter	mm	DN50	DN50	DN50
Inner diameter	mm	51.3	51.3	51.3
External diameter	mm	60.3	60.3	60.3
Bending radius	mm	90.45	90.45	90.45
Fluid temperature	°C	Hot side 80°C	Cold side 60°C	
Flow	m3/h	5.5	5.5	5.5
Length of pipes	m	13.3	4.22	
Bends	deg	3x40deg, 7x90deg, 1x30deg, 2x45deg, 2x50deg, 1x35deg		
Other losses (enlargements, contractions etc)	deg	2xbutterfly valve Kv=115.7, 1xdynamic valve contraction (50-25mm, 9deg) enlargement (25-50mm, 9deg)		0.21bar pressure drop

This template also calculates the heat loss in the pipe system. Based on the outer diameter, length of pipes and k-value the formula $A_o * k$ can be used to calculate heat loss per degree. The total heat loss in the system is presented in the sheet called *Heat loss Summary*.

Heat loss calculation				
Thickness of insulation	m	0.030	0.030	0.030
Outer radius r2	m	0.06015	0.06015	0.06015
Outer radius of pipe r1	m	0.03015	0.03015	0.03015
Innter radius r0	m	0.02565	0.02565	0.02565
Heat transfer rate k	w/m2k	0.971	0.971	0.971
Ao*k [w/k]	W/k	4.883	1.549	0.000
Cold side summary	w/k	0.000	1.549	0.000
Hot side summary	w/k	4.883	0.000	0.000

Step 2 – Calculate the Pressure-Drop at Full Flow

Once all the components causing a pressure drop have been located the pressure drop at full flow in the entire system can be calculated. This can be done with numerical pressure drop software such as SF Pressure Drop, with the attached template. Calculate the pressure drop in the main pipeline in one sheet, then all the branches in their own sheet. The results from the pressure drop can then be compared in the calculation summary. Specify which “column” each branch exits and enters the main pipeline. The “column” refers to the number in row two of the main pipeline sheet.

Column Comparison	
Branch 1	
Inlet Column	6
Outlet Column	40
Pressure through main pipe (bar)	1.35
Pressure through branching pipe (bar)	0.13
Pressure through the main pipe has the most severe pressure drop	

Figure 1 Branch 1 exits the main pipeline at column 6 and reenters at column 40. This means that the pressure-drop through the main pipeline is more severe.

The results from this calculation will be compared and this will determine which path has the most severe pressure drop. Sum up the pressure drop in row 39 for each section in the main pipeline that has the same flow and use this value to assign a kv value for each section. This value will be used further in the method to calculate pressure drop at varying flows.

Project:	Section 0				Section 1			
Column nr.	1	2	3	4	5	6	7	8
I. Flow medium								
Flow medium	Water		Water		Water		Water	
Condition	liquid		liquid		liquid		liquid	
Volume flow	36.2	36.2	36.2	36.2	36.2	36.2	36.2	36.2
Mass flow	36134.84	36134.84	36134.84	36134.84	36134.84	36134.84	36134.84	36134.84
Volume flow branch pipe								
Density	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2
Dyn.Viscos.	1002	1002	1002	1002	1002	1002	1002	1002
Kin.Viscos.	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852
5. Kv value								
Kv value for this node	0.003				0.01			
Kv value of section	639.52				342.39			

Figure 2 Section 0 has a cumulative pressure-drop of 0.003 bars and section 1 has a cumulative pressure-drop of 0.01 bars. This gives Kv values of 639.52m³/h and 342.39 respectively.

Step 3 – Use the Results in the Power Consumption Sheet

When all sections have their respective Kv vales assigned the results can be used in the power consumption sheet to calculate the potential savings.

Heat balance

Firstly, define all the consumers in the system and define their heat demand then the flow at maximum load. The template has 8 consumers, but more can be added by adding rows above the example consumer row, then copying the formulas from the row above. Make sure the pressure drop and flow is included in the sum below. The sum excludes the flow through the freshwater generator branch, since this has an external pump in the example calculation. The flow through the branch can be included by modifying the formula. Then define their status at each mode. This template has three modes, but more can be added as necessary.

Consumers	Location	Max Load (kW)	Maximum flow (m3/h)	Active	Capacity (%)
Bilge water separator	Branch 1	160	5.5	No	100%
Urea tank	Branch 2	25	1.8	No	100%
Bilge settling tank	Branch 3	18	1.5	No	100%
Fresh water evaporator	Branch 4	742.8	66.2	No	100%
AHU1 (ACC)	Main pipeline	489.5	21.5	Yes	17.5%
AHU2 (Wheelhouse)	Branch 5	44	1.94	Yes	34.0%
AHU3 (Galley)	Branch 6	90	3.96	Yes	17.5%
Example consumer		0	0		100.0%

Figure 3 All the consumers in the system with their capacity in harbor mode

Flow m3/h
-
-
-
66.20
-
0.29
-
-
=SUM(O9:O16)-O12

Figure 4 Formula for the flow through the central heating pump

Below row 19 the heat providers as well as the heat loss can be inserted. This calculation considers the heat that is required to all the consumers as well as the heat lost through the pipe and calculates what is required from the boiler. If there is enough heat from the heat recovery system this would be 0.

Heat providers and loss								
Heatloss	Entire system		5			100%	5	1%
Heat recovery units	Main pipeline		2368			21%	497.28	99%
Oil fired boiler	Main pipeline						0	0%

Figure 5 Specification for where the heat is delivered, and the heat loss.

Fill out the consumption data table to calculate the potential for power savings. Under the distribution throughout the year the user can specify what percentage of the year this calculation will account for. For example, if this calculation is valid for May-August the percentage would be 33% of the year. Under the fuel emission data, the user can insert data from the emissions from fuel consumption. The data in the template is from the CAT3512C engine.

Consumption data		
Distribution of year spent in these conditions [%]		37%
Average		
Average fuel price (€/g)	NOK	0.018
Fuel		
Fuel consumption per [g/kwh]		215.50
Distribution spent in mode [%]		15%
Emission		
Fuel consumption per [g/kwh]		202.80
Distribution spent in mode [%]		3.5%
Dynamic positioning		
Fuel consumption per [g/kwh]		203.25
Distribution spent in mode [%]		81.5%

Fuel emission data	
Greenhouse gas	[g/kg fuel]
Co2	2918
NOx	79.63
Co	1.39
HC	0.32
Part matter	0.24

Figure 6 Screenshot from consumption and fuel emission data.

Pressure Calculation

In the pressure calculation tab is where the logic of which consumer is connected to which section. For example the flow through section 0 will be the sum of all consumers except the freshwater generator, the flow through section 2 will be the sum of all the air handling units and so on the formulas in the flow column can be copied over to the flow constant flow system column. Do this for all modes and insert the appropriate Kv value for each section. The sheet will then calculate the pressure drop in the main pipeline and the flow through the central heating pump. This will define the necessary working point in each mode.

		Turbo				Turbop							
		Flow Constant flow system [m3/h]		Pressure drop in section [Bar]		Pressure drop Constant flow system [Bar]		Flow Constant flow system [m3/h]		Pressure drop in section [Bar]			
Pressure drop through main pipeline [in water column]				0.432		15.190				7.401		78.543	
Flow through central heating pump		5.110		27.40		0.000		4.44		4.4385		27.4	
		Kv value [m3/h/kv]		Flow [m3/h]		Flow Constant flow system [m3/h]		Flow Constant flow system [m3/h]		Flow Constant flow system [m3/h]		Flow Constant flow system [m3/h]	
Section 0	693.52	5.12	27.40	0.000	0.000	4.44	27.40	0.000	4.44	27.40	0.000	0.260	
Section 1	342.26	5.12	27.40	0.000	0.006	4.44	27.40	0.000	4.44	27.40	0.000	0.260	
Section 2	337.68	5.12	27.40	0.000	0.007	4.44	27.40	0.000	4.44	27.40	0.000	0.260	
Section 3	133.96	5.12	27.40	0.002	0.059	4.44	27.40	0.002	4.44	27.40	0.002	0.258	
Section 30	430.36	4.42	23.44	0.001	0.032	3.85	23.44	0.001	3.85	23.44	0.001	0.252	
Section 31	204.93	3.76	23.50	0.004	1.107	3.23	23.50	0.003	3.23	23.50	0.003	1.107	
Section 32	130.7	4.42	23.44	0.001	0.032	3.85	23.44	0.001	3.85	23.44	0.001	0.252	
Section 33	410.45	5.12	27.40	0.002	0.062	4.44	27.40	0.002	4.44	27.40	0.002	0.262	
Section 3	304.4	5.12	27.40	0.000	0.011	4.44	27.40	0.000	4.44	27.40	0.000	0.255	
Section 4	413.30	5.12	27.40	0.002	0.058	4.44	27.40	0.002	4.44	27.40	0.002	0.256	
Section 5	334.75	5.12	27.40	0.000	0.007	4.44	27.40	0.000	4.44	27.40	0.000	0.260	
Section 6	526.33	5.12	27.40	0.000	0.000	4.44	27.40	0.000	4.44	27.40	0.000	0.260	
Section 7	306.25	5.12	27.40	0.001	0.027	4.44	27.40	0.001	4.44	27.40	0.001	0.257	
Section 8	96.24	5.12	27.40	0.001	0.028	4.44	27.40	0.001	4.44	27.40	0.001	0.258	

Figure 7 Screenshot of the pressure calculation tab.

Find a Suitable Pump System

A dynamic system would most likely work at much lower flows than what the original system is designed for. It would therefore probably be beneficial to consider pumps that work well at lower flows and can still work at full capacity. This could be a single pump, or a parallel configuration of pumps. The power consumption template has multiple tabs where different pump configuration can be compared. This is done by estimating a second-degree polynomial for the pump curve and the efficiency curve as a function of the flow. This can be done with curve fitting software if the supplier cannot provide a function for the curve. (The efficiency should be a value between 0 and 1 not a percentage)

Pump curve polynomial

$$H(Q) = a + b \cdot Q + c \cdot Q^2$$

a	33.5
b	0.01675
c	-0.00317

Efficiency motor [1]	0.9
Frequency [1/min]	3420
Max flow at given frequency [m3/h]	68
Minimum flow [m3/h]	4
Minimum frequency [1/min]	1800

Efficiency polynomial

$$\eta(Q) = d + e \cdot Q + f \cdot Q^2$$

d	0
e	0.0271
f	-0.0003

Figure 8 Screenshot of the polynomials for Head and Efficiency.




Figure 9 Illustration of fitting pump curve to working points.

The sheet will then extract values from the pressure calculation to consider how to pump preforms at that working point. In the constant flow system tab, the calculation is done with the assumption that the flow in each open branch is constant at the maximum capacity. In the other pump tabs the calculation is done with an assumption that the system is using throttling to limit the flow to whatever is necessary to deliver.

The sheet can consider power consumptions at a constant frequency, or it can fit the curve to each working point to simulate automatic frequency controlling. By pressing the fit curves to working points the sheet fits the curves so that they intersect the system curve at the lowest possible point. By pressing the reset frequency button, the curve is reset to the original frequency. This makes it possible to compare frequency controlling with just flow limiting by throttling.

Comparing the results of the calculation

When all the values above have been specified it is possible to compare results from the original system with different pump configurations. The “Fuel consumption” column compares the results from the most efficient pump with a dynamic system with the original pump. It then calculates the fuel costs for each system in each mode, and then the annual savings in both fuel and economical savings. These are the potential savings in the timeframe that is specified in the heat balance. Meaning that if the calculation is valid from May to August, then these are the potential savings during these months.

Fuel consumption	
Barbo	
Annual energy dem and static (kWh)	2 139
Annual energy demand dynamic (kWh)	289
Fuel consumption static (kg)	460.8
Fuel consumption dynamic (kg)	62.3
Annual fuel cost static system (NOK)	8 294
Annual fuel cost dynamic system (NOK)	1 121
Annual savings (NOK)	7 173
Transit	
Annual energy dem and static (kWh)	499
Annual energy demand dynamic (kWh)	67
Fuel consumption static (kg)	101.2
Fuel consumption dynamic (kg)	13.6
Annual fuel cost static system (NOK)	1 821
Annual fuel cost dynamic system (NOK)	205
Annual savings (NOK)	1 576
Dynamic positioning	
Annual energy dem and static (kWh)	11 617
Annual energy demand dynamic (kWh)	1 562
Fuel consumption static (kg)	2361.2
Fuel consumption dynamic (kg)	327.5
Annual fuel cost static system (NOK)	42 502
Annual fuel cost dynamic system (NOK)	5 215
Annual savings (NOK)	36 787
Average daily savings (NOK)	337

Potential savings in emissions	
Annual CO2 emissions (kg)	7381.95
Annual NOx emissions (kg)	79.01
Annual CO emissions (kg)	4.02
Annual HC emissions (kg)	2.33
Annual particulate emissions (kg)	0.63

Figure 10 Screenshot of the potential for savings in fuel and emissions.

The potential savings in emissions column calculates how much this alternative system could save in greenhouse gas emissions, due to a lower fuel consumption. This is also in terms of the specified timeframe in heat balance.

A.3 System Description



a **Fincantieri** company

*****-577-001/002/003 CENTRAL HEATING SYSTEM**

A central heating system includes:

- **Four (4) off heat recovery units heat exchangers for main engines (577.0181.10, 577.0281.10, 577.0381.10, 577.0481.10)**
- Fresh Water Evaporator heating **(761.0101.10)**
- Fresh Water Evaporator pump **(761.0109.10)**
- Bilge Water Separator **(803.0125.10)**
- Hot Water Boiler, Oil Fired **(648.0101.10)**
- Heating elements for air handling units serving the following areas /compartments:
 - Accommodation
 - Wheelhouse
 - Galley

The system consists of:

- Four (4) off Central Heating Circulation Pumps, frequency will be adjusted during commissioning to find out the best working point, **(577.0101.10, 577.0101.20, 577.0101.30, 577.0101.40)**
- Dynamic flow-regulating valves
- All hot water pipes are thermal insulated.

The main purpose of the system is to distribute heated water, produced in central heating system and heat recovery unit (exchangers) to heat consumers.

There are four pumps in the engine room, three in operation and one in backup. The pumps are automatically turned on or off to ensure optimal working conditions.

Return flow from all consumers goes through (4) Heat recovery units in the Engine room. The heat recovery units have a by-pass line on each side.

The flow to consumers are mainly controlled by remote operated dynamic flow regulation valves. Either with controller in IAS, HVAC Control System or self-operated. In addition there are a few constant flow consumers.



a **Fincantieri** company

Different modes:

Harbour:

-One engine in use at 81% capacity. Specified to deliver 497KW of heat to the central heating system.

DP:

-All four engines in use at 73.1% capacity each. Specified to deliver maximum 1731KW of heat to the central heating system.

Transit:

-All four engines in use at 77.6% capacity each. Specified to deliver maximum 1838KW of heat to the central heating system.

A.4 Abstract of function

ABSTRACT OF FUNCTIONS



a Fincantieri company

ABSTRACT OF FUNCTIONS LIST DOC.NO: ***_577-0013		REVISION: -		PIPING DIAGRAM DOC.NO: ***_577-0010									
FUNCTIONS LIST DOC.NO: ***_577-0013		REVISION DATE: 5/4/2023		PIPING DIAGRAM TITLE: CENTRAL HEATING SYSTEM									
PREPARED DATE: 5/4/2023		REVIEWED BY: VO		SYSTEM DESIGN PRESSURE: 3									
DESIGN PROJECT NO: -		YARD: -		YARD: VARD									
BUILD NO: -		VESSEL TYPE: -											
REVISION	SFI NUMBER / ISA CODE (EQUIPMENT) MACHINERY, SENSOR, TANK	EQUIPMENT NAME / DESCRIPTION	FUNCTION						NOTES FROM IAS ID LIST				
			HARDWARE SIGNALS	MODBUS SIGNALS	EQUIPMENT QUANTITY	EQUIPMENT TYPE	SUPPLIER	SIGNAL TYPE		IAS ALARM	IAS MIMIC	IAS CONTROL	IAS / EXT. AUTO CONTROL
	648.0101.10	HOT WATER BOILER, OIL FIRED	X	X	1	MI	V	X	X	NO	EXT	To be communicated acc.to supplier documentation	No Suction or Discharge Pressure for this pumps.
	577.0101.10	CENTRAL HEATING CIRCULATION PUMP 1		X	1	MI	V	D	-	X	EXT.	Regulation by dif.pressure in suction/discharge side	No Suction or Discharge Pressure for this pumps.
	577.0101.20	CENTRAL HEATING CIRCULATION PUMP 2		X	1	MI	V	D	-	X	EXT.	Regulation by dif.pressure in suction/discharge side	No Suction or Discharge Pressure for this pumps.
	577.0101.30	CENTRAL HEATING CIRCULATION PUMP 3		X	1	MI	V	D	-	X	EXT.	Regulation by dif.pressure in suction/discharge side	No Suction or Discharge Pressure for this pumps.
	577.0101.40	CENTRAL HEATING CIRCULATION PUMP 4		X	1	MI	V	D	-	X	EXT.	Regulation by dif.pressure in suction/discharge side	No Suction or Discharge Pressure for this pumps.
	577.1421	BILGE SETLING Tk 92 regulating valve	-	-	1	TT	V	V	-	NO	EXT	Valve regulating by sensor in the tank 92	Not To or From IAS
	577.1451	UREA Tk 58 regulating valve	-	-	1	TT	V	V	-	NO	EXT	Valve regulating by sensor in the tank 58	Not To or From IAS
	577.1171	AHU-1 HEATING SECTION Actuator controlled dynamic valve	-	-	1	TT	Y	Y	-	NO	EXT	Valve regulating by sensor at AHU-1	Not To or From IAS
	577.1231	AHU-2 HEATING SECTION Actuator controlled dynamic valve	-	-	1	TT	Y	Y	-	NO	EXT	Valve regulating by sensor at AHU-2	Not To or From IAS
	577.1261	AHU-3 HEATING SECTION Actuator controlled dynamic valve	-	-	1	TT	Y	Y	-	NO	EXT	Valve regulating by sensor at AHU-3	Not To or From IAS
	761.0109.10	FW GENERATOR, HOT WATER CIRC. PUMP	X	-	1					NO	-	Local start/stop	Not To or From IAS
	761.0101.10	FW GENERATOR	X		1	MI	V	X	X	X	EXT	To be communicated acc.to supplier documentation	Not To or From IAS

Central Heating System Design

A.5 Armature list

Page 1 of 1

ARMATURE LIST										ARMATURE LIST DOC NO: ***-577-0011	REVISION: PIPING DIAGRAM DOC NO:	***-577-0010			SIGNS ACC. TO VARD STANDARD:				
VARD a Fincantieri company										REVISION DATE:	PIPING DIAGRAM TITLE:	CENTRAL HEATING SYSTEM			Type	Dimensions	Text size	Typical valves	
										MADE BY:	SYSTEM DESIGN PRESSURE:	3 BAR			1	748 mm	3,5 mm	Ball valves < 3/4"	
										DESIGN PROJECT NO:	YARD:	BRATTVÁG			2	ø40/6 mm	3,5 mm	Threaded globe valves	
										BUILD NO:	VESSEL TYPE:				3	ø50/15 mm	5,0 mm	Flanged globe valves	
													4	85x10 mm	5,0 mm	Ball valves > 1"			
													5	100x15 mm	5,0 mm	NR valves < DN80 Butterfly valves > DN80			
TO BE COMPLETED BY THE YARD										TO BE COMPLETED BY THE YARD									
TAG	ACTUATOR TAG	P.O. NUMBER	SUPPLIER	DESTINATION (YARD)	SFI	DESCRIPTION	SIZE	CONNECTION	PRESSURE RATING	HOUSING (BODY)	TYPE	PIPE CLASS	CLASS CERTIFICATION	REMARKS	SIGN TYPE	SIGN TEXT			
HNL02803		660112	BD	BRALA	577.1021	Ball valve	1 1/4"	Threaded	PN100	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1021	TO FW EXP. TANK		
HNL02804		660112	BD	BRALA	577.1022	Ball valve	1 1/4"	Threaded	PN100	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1022	FROM FW EXP. TANK		
HNL02805		660112	BD	BRALA	577.1151	Ball valve	1/2"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		1	577.1151	TO AUTO. AIR VAL. DEAERATOR		
HNL02807		660112	BD	BRALA	577.1221	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1221	TO AHU-2 WHEELHOUSE		
HNL02808		660112	BD	BRALA	577.1233	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1233	FROM AHU-2 WHEELHOUSE		
HNL02809		660112	BD	BRALA	577.1241	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1241	CONNECT LINE 122 AND 123		
HNL02810		660112	BD	BRALA	577.1251	Ball valve	1 1/2"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1251	TO AHU-3 GALLEY		
HNL02811		660112	BD	BRALA	577.1263	Ball valve	1 1/2"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1263	FROM AHU-3 GALLEY		
HNL02812		660112	BD	BRALA	577.1271	Ball valve	1 1/2"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1271	CONNECT LINE 125 AND 126		
HNL02813		660112	BD	BRALA	577.1431	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1431	TO HOSE COUPLING		
HNL02815		660112	BD	BRALA	577.1432	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1432	TO BLS SETL. TANK 92		
HNL02816		660112	BD	BRALA	577.1431	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1431	FROM BLS SETL. TANK 92		
RKL4604		660112	BD	From stock	BRATTVÁG	577.1434	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.	4	577.1434	FROM UREA TANK 58		
HNL02818		660112	BD	BRALA	577.1452	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1452	TO UREA TANK 58		
		660112	BD	BRALA	577.1183	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2007	Class III	N.A.		4	577.1183	FROM BLEED VALVE 577.1182		
		660112	BD	BRALA	577.1181	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2007	Class III	N.A.		4	577.1181	TO BLEED VALVE 577.1182		
		660112	BD	WARD ACC scope	WARD ACC scope	577.1182	Dynamic regulating valve	1"	Threaded	PN150	DZR Brass	Free Sigma Compact	Class III	N.A.		4	577.1182	BLEED FROM LINE 116 TO 117	
HNL02819		660112	BD	BRALA	577.1461	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1461	FROM UREA TANK 58		
RKL4605		660112	BD	From stock	BRATTVÁG	577.1464	Ball valve	1"	Threaded	PN150	A351-CFBM	Hastima 2006	Class III	N.A.		4	577.1464	FROM BLS SETL. TANK 92	
HNL02823		660112	BD	BRALA	577.1011	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1011	FROM HOT WATER BOILER, OIL FIRED		
HNL02824		660112	BD	BRALA	577.1091	Butterfly valve	DN100	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1091	TO FW GENERATOR, HOT WATER CIRC. PUMP		
HNL02826		660112	BD	BRALA	577.1102	Butterfly valve	DN100	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1102	TO FRESH WATER GENERATOR		
HNL02827		660112	BD	BRALA	577.1111	Butterfly valve	DN100	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1111	FROM FRESH WATER GENERATOR		
HNL02828		660112	BD	BRALA	577.1123	Butterfly valve	DN80	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	4	577.1123	FROM CENTRAL HEATING CIRCULATION PUMP		
HNL02829		660112	BD	BRALA	577.1131	Butterfly valve	DN80	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	4	577.1131	FROM CENTRAL HEATING CIRCULATION PUMP		
HNL02860		660112	BD	BRALA	577.1141	Butterfly valve	DN80	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	4	577.1141	FROM CENTRAL HEATING CIRCULATION PUMP		
HNL02861		660112	BD	BRALA	577.1161	Butterfly valve	DN65	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	4	577.1161	TO AHU-3 ACCOMMODATION		
HNL02862		660112	BD	BRALA	577.1173	Butterfly valve	DN65	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	4	577.1173	FROM AHU-3 ACCOMMODATION		
HNL02863		660112	BD	BRALA	577.1181	Butterfly valve	DN65	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	4	577.1181	CONNECT LINE 116 AND 117		
HNL02864		660112	BD	BRALA	577.1291	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1291	TO ME2, HEAT RECOVERY		
HNL02865		660112	BD	BRALA	577.1301	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1301	FROM ME2, HEAT RECOVERY		
HNL02866		660112	BD	BRALA	577.1302	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1302	TO ME2, HEAT RECOVERY		
HNL02867		660112	BD	BRALA	577.1311	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1311	ME2, HEAT RECOVERY BYPASS		
HNL02868		660112	BD	BRALA	577.1321	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1321	FROM ME2, HEAT RECOVERY		
HNL02869		660112	BD	BRALA	577.1331	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1331	ME2, HEAT RECOVERY BYPASS		
HNL02870		660112	BD	BRALA	577.1341	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1341	TO ME2, HEAT RECOVERY		
HNL02871		660112	BD	BRALA	577.1351	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1351	FROM ME2, HEAT RECOVERY		
HNL02872		660112	BD	BRALA	577.1352	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1352	TO ME2, HEAT RECOVERY		
HNL02873		660112	BD	BRALA	577.1361	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1361	ME2, HEAT RECOVERY BYPASS		
HNL02874		660112	BD	BRALA	577.1371	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1371	FROM ME2, HEAT RECOVERY		
HNL02875		660112	BD	BRALA	577.1381	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1381	ME2, HEAT RECOVERY BYPASS		
HNL02876		660112	BD	BRALA	577.1391	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1391	TO HOT WATER BOILER, OIL FIRED		
HNL02877		660112	BD	BRALA	577.1401	Butterfly valve	DN125	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1401	BYPASS HOT WATER BOILER, OIL FIRED		
HNL02878		660112	BD	BRALA	577.1501	Butterfly valve	DN50	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	5	577.1501	TO BW SEPARATOR		
HNL02879		660112	BD	BRALA	577.1521	Butterfly valve	DN50	Lug	PN16	Ductile iron	EGO (EPDM)	Class III	N.A.	Type B - Lever operated	4	577.1521	FROM BW SEPARATOR		
HNL02806		660112	BD	BRALA	577.1152	Deaerator	1/2"	Threaded	PN10	Bronze	Flamco Flawless Saper	Class III	N.A.		5	577.1152	AUTO. AIR VAL. DEAERATOR		
HNL02806		662969	FRESE	BRALA	577.1112	Dynamic regulating valve	DN100	Flanged	PN16	GR-250	Free SIGMA Compact	Class III	N.A.		5	577.1112	FROM FRESH WATER GENERATOR		
		662969	FRESE	WARD ACC scope	WARD ACC scope	577.1172	Dynamic regulating valve	DN65	Flanged	PN16	GR-250	Free SIGMA Compact	Class III	N.A.		4	577.1172	FROM AHU-3 ACCOMMODATION	
		662969	FRESE	WARD ACC scope	WARD ACC scope	577.1232	Dynamic regulating valve	1"	Threaded	PN16	DZR Brass	Free Optima Compact	Class III	N.A.		4	577.1232	FROM AHU-2 WHEELHOUSE	
		662969	FRESE	WARD ACC scope	WARD ACC scope	577.1262	Dynamic regulating valve	1 1/4"	Threaded	PN16	DZR Brass	Free Optima Compact	Class III	N.A.		4	577.1262	FROM AHU-3 GALLEY	
HNL05016		690892	FRESE	BRATTVÁG	577.1433	Dynamic regulating valve	1"	Threaded	PN16	DZR Brass	Free SIGMA Compact	Class III	N.A.	Flow Q = 1.5 m³/h	No Sign	577.1433			
HNL05017		690892	FRESE	BRATTVÁG	577.1463	Dynamic regulating valve	1"	Threaded	PN16	DZR Brass	Free SIGMA Compact	Class III	N.A.	Flow Q = 1.8 m³/h	No Sign	577.1463			
HNL02907		662969	FRESE	BRALA	577.1511	Dynamic regulating valve	DN50	Flanged	PN16	GR-250	Free SIGMA Compact	Class III	N.A.	Flow Q = 1.5 m³/h	No Sign	577.1511	FROM BW SEPARATOR		
		662969	FRESE	WARD ACC scope	WARD ACC scope	577.1412	Hose coupling	1"	Female end	PN16	Ca. Ir.	Camlock	Class III	N.A.		No Sign	577.1412	HOSE COUPLING	
HNL02855		660112	BD	BRALA	577.1101	NR valve closable	DN100	Flanged	PN10	Cast iron	Fig 10.195.50	Class III	N.A.	Straight type with spring	5	577.1101	FROM FW GENERATOR, HOT WATER CIRC. PUMP		
		660112	BD	ULMATEC PYRO	BRATTVÁG	577.1021	Pressure relief valve	1 1/4"	Threaded	PN10		Class III	N.A.	Ultimate Pyro delivery	4	577.1021	DRAIN TO NEAREST BLS WELL		
		660112	BD	ULMATEC PYRO	BRATTVÁG	577.1041	Pressure relief valve	1 1/4"	Threaded	PN10		Class III	N.A.	Ultimate Pyro delivery	4	577.1041	DRAIN TO NEAREST BLS WELL		
HNL02814		660112	BD	BRALA	577.1432	Self acting temp control valve	1"	Threaded	PN16	Danfoss AVTB		Class III	N.A.	Sensor Max temp. 45oC, Stainless steel pockets for urf	No Sign	577.1432	FROM BLS SETL. TANK 92		
HNL02817		660112	BD	BRALA	577.1462	Self acting temp control valve	1"	Threaded	PN16	Danfoss AVTB		Class III	N.A.	Sensor Max temp. 35oC, Stainless steel pockets for urf	No Sign	577.1462	FROM UREA TANK 58		

Page 1 of 1

A.6 Pipe Dimensions and Heat Losses

Pipe dimensions and losses

Highest point of elevation

	Section 0	Section 1	Section 2	Section 9	Section 10	Section 11	Section 11 Hot Side	Section 11 Cold Side	Section 11	Section 12	Section 13	Section 3	Section 4	Section 5	Section 6	Section 7	Section 8		
DN	DN150	DN80	DN80	DN80	DN80	DN80	DN80	DN80	DN80	DN80	DN80	DN80	DN80	DN80	DN80	DN80	DN125	DN125	
Inner diameter	158.75	76.2	76.2	76.2	76.2	76.2	76.2	76.2	76.2	76.2	76.2	76.2	76.2	76.2	76.2	76.2	101.6	101.6	
External diameter	171.3	88.9	88.9	88.9	88.9	88.9	88.9	88.9	88.9	88.9	88.9	88.9	88.9	88.9	88.9	88.9	114.3	114.3	
Bending radius	175.75	133.35	133.35	133.35	133.35	133.35	133.35	133.35	133.35	133.35	133.35	133.35	133.35	133.35	133.35	133.35	209.55	209.55	
Fluid temperature	Hot side 120.00	Hot side 120.00	Hot side 120.00	Hot side 120.00	Hot side 120.00	Hot side 120.00	Hot side 120.00	Cold side 10.00	Cold side 10.00	Cold side 10.00	Cold side 10.00	Cold side 10.00	Cold side 10.00	Cold side 10.00	Cold side 10.00	Cold side 10.00	Hot side 120.00	Hot side 120.00	
Flow	m ³ /h	36.3	36.3	27.4	27.4	23.44	21.5	21.5	21.5	23.44	27.4	27.4	27.4	27.4	34.7	34.7	302.4	302.4	
Length of pipe	m	0.5	0.65	0.22	4.94	9	2.9	11.57	14.42	8.94	4.83	1.98	7.3	0.53	0.28	18.5	7.62	7.62	
Bends	deg	0 deg	45 deg	45 deg	Sharp bend	90 deg	90 deg	90 deg	90 deg	90 deg	90 deg	90 deg	90 deg	90 deg	90 deg	90 deg	90 deg	90 deg	
Other losses (enlargements, contractions etc)	deg	Contraction (120.00mm, 80deg)						Butterfly valve (see 118.5m/3h, AC Return Air, 1.0-3.0 bar pressure drop (11mwater, 15.5m), Butterfly valve, Sharp valve (V, w/3m/3h), Square compact flange (10 (10 Standard High flow (0.12bar pressure drop)(4m/100, 80mm, Solid)								Enlargement (80-125mm, 10deg)		Butterfly valve (see 27.4m/3h/4G, Heat exchanger (18 (0.24bar, 12deg)	Butterfly valve, lag type x1, Contraction (121.80mm, 11deg)


Heat loss calculation

Thickness of insulation	m	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040	0.040
Outer radius r2	m	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840	0.0840
Outer radius of pipe r1	m	0.0900	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440	0.0440
Inner radius of	m	0.0425	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395	0.0395
Heat transfer rate k	W/m ² K	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753	0.753
deg ² /h ²	W/h	0.147	0.258	0.088	3.778	3.588	1.158	4.107	5.143	3.368	1.708	0.431	2.911	0.111	0.111	0.111	0.111	0.111
Cold side summary	W/h	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.143	1.310	3.383	1.928	0.431	2.911	0.111	0.111	0.000	0.000
Hot side summary	W/h	0.147	0.258	0.088	3.778	3.588	1.158	4.107	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	3.641

Reducer/enlarger degree calculator

Here is a calculator to find the angle of a reducer/enlarger. The value is required to be in degrees in if pressure drop, however it is more accurate to measure the difference in diameters

	Unit	Value
Smaller diameter (d ₁)	mm	80
Larger diameter (d ₂)	mm	125
Length in between (L)	m	0.12
Angle (w)	deg	11



Pipe dimensions and losses

		Branch 1 Hot side	Branch 2 Cold side	Bilge water seperator
	Unit	Value		Value
Pipe diameter	mm	DN50	DN50	DN50
Inner diameter	mm	51.3	51.3	51.3
External diameter	mm	60.3	60.3	60.3
Bending radius	mm	90.45	90.45	90.45
Fluid temperature	c°	Hot side 80°C	Cold side 60°C	
Flow	m3/h	5.5	5.5	5.5
Length of pipes	m	13.3	4.22	
Bends	deg	3x40deg, 7x90deg, 1x30deg, 2x45deg, 2x50deg, 1x35deg		
Other losses (enlargements, contractions etc)	deg	2xbutterfly valve Kv=115.7, 1xdynamic valve contraction (50-25mm, 9deg) enlargement (25-50mm, 9deg)		0.21bar pressure drop

Heat loss calculation				
Thickness of insulation	m	0.030	0.030	0.030
Outer radius r2	m	0.06015	0.06015	0.06015
Outer radius of pipe r1	m	0.03015	0.03015	0.03015
Innter radius r0	m	0.02565	0.02565	0.02565
Heat transfer rate k	w/m2k	0.971	0.971	0.971
Ao*k [w/k]	W/k	4.883	1.549	0.000
Cold side summary	w/k	0.000	1.549	0.000
Hot side summary	w/k	4.883	0.000	0.000

Pipe dimensions and losses

		Branch 2 Hot side	Branch 2 Cold side	UREA Tank
	Unit	Value	Value	Value
Pipe diameter	mm	PT28	PT28	PT28
Inner diameter	mm	25	25	25
External diameter	mm	28	28	28
Bending radius	mm	42	42	42
Fluid temperature	°C	Hot side 80°C	Cold side 60°C	
Flow	m ³ /h	1.8	1.8	1.8
Length of pipes	m	7	7	20
Bends	deg			90degX16, 60degX1, 45degX3
Other losses (enlargements, contractions etc)	deg	Ball valve x3 Selfacting temp. control valve x1 Dynamic regulating valve x1		

Heat loss calculation				
Thickness of insulation	m	0.030	0.030	0.030
Outer radius r2	m	0.044	0.044	0.044
Outer radius of pipe r1	m	0.014	0.014	0.014
Innter radius r0	m	0.0125	0.0125	0.0125
Heat transfer rate k	w/m ² k	0.806	0.806	0.806
Ao*k [w/k]	W/k	1.561	1.561	4.459
Cold side summary	w/k	0.000	1.561	0.000
Hot side summary	w/k	1.561	0.000	0.000

Pipe dimensions and losses

		Branch 3 Hot side	Branch Cold side	Bilge settle
	Unit	Value	Value	Value
Pipe diameter	mm	PT28	PT28	PT18
Inner diameter	mm	25	25	15.6
External diameter	mm	28	28	18
Bending radius	mm	42	42	27
Fluid temperature	c°	Hot side 80°C	Cold side 60°C	
Flow	m3/h	1.5	1.5	1.5
Length of pipes	m	6	6	16
Bends	deg			90deg x23
Other losses (enlargements, contractions etc)	deg	Ball valve x3 Selfacting temp. control valve x1 Dynamic regulating valve x1		

Heat loss calculation				
Thickness of insulation	m	0.030	0.030	0.030
Outer radius r2	m	0.044	0.044	0.039
Outer radius of pipe r1	m	0.014	0.014	0.009
Innter radius r0	m	0.0125	0.0125	0.0078
Heat transfer rate k	w/m2k	0.806	0.806	0.713
Ao*k [w/k]	W/k	1.338	1.338	2.797
Cold side summary	w/k	0.000	1.338	0.000
Hot side summary	w/k	1.338	0.000	0.000

Pipe dimensions and losses

		Branch 4 Hot side	Branch 4 Cold side	Fresh Water Generator
	Unit	Value		Value
Pipe diameter	mm	DN100	DN100	DN100
Inner diameter	mm	108.3	108.3	108.3
External diameter	mm	117.3	117.3	117.3
Bending radius	mm	175.95	175.95	175.95
Fluid temperature	c°	Hot side 80°C	Cold side 60°C	
Flow	m3/h	66.2	67.2	66.2
Length of pipes	m	18.88	21.8	16
Bends	deg	14x90deg, 1x60deg, 1x45deg, 6x35deg, 2x25deg, 1x15deg, 1xSharp bend, 1xConnected pipe, 1xcheck valve, 1xdynamic valve, 3xbutterfly valve,		1x50deg, 1x90deg
Other losses (enlargements, contractions etc)	deg	Enlarger 80-100mm(6deg), Enlarger 100-125mm(6deg) Contraction 100-80mm(6deg)		0.2bar pressure drop

Heat loss calculation				
Thickness of insulation	m	0.040	0.040	0.040
Outer radius r2	m	0.09865	0.09865	0.09865
Outer radius of pipe r1	m	0.05865	0.05865	0.05865
Innter radius r0	m	0.05415	0.05415	0.05415
Heat transfer rate k	w/m2k	0.793	0.793	0.793
Ao*k [w/k]	W/k	9.276	10.710	7.861
Cold side summary	w/k	0.000	10.710	0.000
Hot side summary	w/k	9.276	0.000	0.000

Pipe dimensions and losses

	Unit	Hot side Value	Cold side Value	Wheelhouse Room Value
Pipe diameter	mm	PT28	PT28	N/A
Inner diameter	mm	25	25	#N/A
External diameter	mm	28	28	#N/A
Bending radius	mm	42	42	#N/A
Fluid temperature	c°	Hot side 80°C	Cold side 60°C	
Flow	m3/h	1.94	1.94	1.94
Length of pipes	m	17.5	17.5	
Bends	deg	Gjetter at det er rundt 90degX4, Inlet/outlet		AHU 2 har veldig liten flow og med stor sansynlighet små plastrør, jeg foreslår derfor å neglisjere trykkfallet som følge av røret og rørbøyer her siden de ikke er modellert.
Other losses (enlargements, contractions etc)	deg	3 way valve(0.06 bar pressure drop), dynamic valve DN25 High flow (0.2 bar pressure drop)		Pressure drop in AHU 2= 0.376 bar (K_vs=10m3/h)
Heat loss calculation				
Thickness of insulation	m	0.030	0.030	
Outer radius r2	m	0.044	0.044	
Outer radius of pipe r1	m	0.014	0.014	
Innter radius r0	m	0.0125	0.0125	
Heat transfer rate k	w/m2k	0.806	0.806	
Ao*k [w/k]	w/k	3.902	3.902	
Cold side summary	w/k	0.000	3.902	0.000
Hot side summary	w/k	3.902	0.000	0.000

Pipe dimensions and losses

		Hot side	Cold side	Galley Room
	Unit	Value	Value	Value
Pipe diameter	mm	PT35	PT35	PT35
Inner diameter	mm	32	32	32
External diameter	mm	35	35	35
Bending radius	mm	52.5	52.5	52.5
Flow	m ³ /h	3.96	3.96	
Fluid temperature	°C	Hot side 80°C	Cold side 60°C	
Length of pipes	m	17.5	17.5	
Bends	deg	Gjetter at det er rundt 90degX4, Inlet/outlet		
Other losses (enlargements, contractions etc)	deg	3 way valve(0.05 bar pressure drop), dynamic valve DN32 (0.19 bar pressure drop)		AHU 3 pressure drop= 0.015bar K_vs=16m ³ /h)

Heat loss calculation				
Thickness of insulation	m	0.030	0.030	0.030
Outer radius r2	m	0.0475	0.0475	0.0475
Outer radius of pipe r1	m	0.0175	0.0175	0.0175
Innter radius r0	m	0.016	0.016	0.016
Heat transfer rate k	w/m ² k	0.855	0.855	0.855
Ao*k [w/k]	W/k	4.466	4.466	
Cold side summary	w/k	0.000	4.466	0.000
Hot side summary	w/k	4.466	0.000	0.000

Heatloss entire system	
Heat loss [W]	4956
Heat loss [kW]	4.96

Main pipeline	A_o*k [w/k]	Outside temperature [°C]	Delta T [k]	Heat loss [w]
Cold side	15.53	15	45	699
Hot side	23.78	15	65	1546

Branch 1	A_o*k [w/k]			
Cold side	1.55	15	45	70
Hot side	4.88	15	65	317

Branch 2	A_o*k [w/k]			
Cold side	1.56	15	45	70
Hot side	1.56	15	65	101

Branch 3	A_o*k [w/k]			
Cold side	1.34	15	45	60
Hot side	1.34	15	65	87

Branch 4	A_o*k [w/k]			
Cold side	10.71	15	45	482
Hot side	9.28	15	65	603

AHU2	A_o*k [w/k]			
Cold side	3.90	15	45	176
Hot side	3.90	15	65	254

AHU3	A_o*k [w/k]			
Cold side	4.47	15	45	201
Hot side	4.47	15	65	290

A.7 SF Pressure Drop Calculation

Project: Blue water separator	Pipe	Butterfly valve	Construction	Enlargement	Dynamic valve	Bend	Bend	Bend	Bend	Bend	Bend	Bend	Bend	Connected pipes	10
1. Flow medium															
Flow medium	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water
Condition	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid
Volume flow	m ³ /h	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	5.0	2750.00
Mass flow	kg/h	5400.1	5400.1	5400.1	5400.1	5400.1	5400.1	5400.1	5400.1	5400.1	5400.1	5400.1	5400.1	5400.1	27500.00
Volume flow branch pipe	m ³ /h														5.3
Density	kg/m ³	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2
Dyn. Viscos.	10 ⁻⁶ kg/m.s	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002
Kin. Viscos.	10 ⁻⁶ m ² /s	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852
2. Additional data for gases															
Pressure (inlet, abs.)	bar														
Temperature (inlet)	°C														
Temperature (outlet)	°C														
Norm volume flow	Nm ³ /h														
3. Element of pipe															
Element of pipe	Branch 1, pipe	Branch 1, butterfly valve	Branch 1, construction	Branch 1, enlargement	Branch 1, dynamic valve	Branch 1, bend	Branch 1, bend	Branch 1, bend	Branch 1, bend	Branch 1, bend	Branch 1, bend	Branch 1, bend	Branch 1, bend	Section 2, sharp bends pipe	Section 2, sharp bends pipe
Number	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
Dimensions of element	SI	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 51.30 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm
		Length of pipe L: 17.52 m		Angle w: 90.00 degree	Angle w: 90.00 degree	Angle w: 40.00 degree	Angle w: 90.00 degree	Angle w: 90.00 degree	Angle w: 45.00 degree	Angle w: 45.00 degree	Angle w: 45.00 degree	Angle w: 45.00 degree	Angle w: 45.00 degree	Angle w: 90.00 degree	Angle w: 90.00 degree

4. Result of calculation															
Veloc. of flow	m/s	0.73915099	0.73915099	0.73915099	2.94317227	0.73915099	0.73915099	0.73915099	0.73915099	0.73915099	0.73915099	0.73915099	0.73915099	0.73915099	1.51797603
Reynolds number		37774.85225	37774.85225	37774.85225	7465.72274	37774.85225	37774.85225	37774.85225	37774.85225	37774.85225	37774.85225	37774.85225	37774.85225	37774.85225	120826.2357
Veloc. of flow 2	m/s				2.94317227										1.018591636
Reynolds number 2					7465.72272										25368.21784
Flow	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent
Absolute roughness	mm	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Pipe friction number		0.03091118	0.03091118	0.03091118	0.03091118	0.03091118	0.03091118	0.03091118	0.03091118	0.03091118	0.03091118	0.03091118	0.03091118	0.03091118	0.03091118
Resistance coefficient		10.44468813	1.93	0.76200055	0.20488213	3.93	0.35368425	0.58164225	0.24109214	0.36377512	0.27239134	0.27239134	0.27239134	0.27239134	0.081178971
Resistance coefficient branch pipe															0.492202520
Press. drop branch pipe	mbar	28.7311945	2.0460891	0.86611385	2.44240078	10.2176002	0.657382154	1.021297024	0.412307024	0.518800179	0.382344423	0.382344423	0.382344423	0.382344423	76.4666466
Pressure drop	bar	0.002875187	0.000204443	0.000866494	0.00244078	0.001021022	0.000657154	0.001021022	0.000412307	0.000518802	0.000382344	0.000382344	0.000382344	0.000382344	0.00764666466
Sum Pressure drop	bar	0.02875187	0.00204443	0.00866494	0.0244078	0.1021022	0.00657154	0.01021022	0.00412307	0.00518802	0.00382344	0.00382344	0.00382344	0.00382344	0.0764666466

Project: Urea tank	Ball valve	Self acting temp. control valve	Dynamic regulating valve	Pipe urea tank	Pipe	Bend, urea tank	Bend, urea tank	Bend, urea tank	Bend, urea tank	Connected pipes	9
1. Flow medium											
Flow medium	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water	Water
Condition	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid	liquid
Volume flow	m ³ /h	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8
Mass flow	kg/h	1796.76	1796.76	1796.76	1796.76	1796.76	1796.76	1796.76	1796.76	1796.76	1796.76
Volume flow branch pipe	m ³ /h										
Density	kg/m ³	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2	998.2
Dyn. Viscos.	10 ⁻⁶ kg/m.s	1002	1002	1002	1002	1002	1002	1002	1002	1002	1002
Kin. Viscos.	10 ⁻⁶ m ² /s	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852
2. Additional data for gases											
Pressure (inlet, abs.)	bar										
Temperature (inlet)	°C										
Temperature (outlet)	°C										
Norm volume flow	Nm ³ /h										
3. Element of pipe											
Element of pipe	Ball valve	Branch 2, self acting temp. control valve	Branch 2, dynamic regulating valve	Pipe urea tank	Pipe branch 2	Bend, urea tank	Bend, urea tank	Bend, urea tank	Bend, urea tank	Section 2, sharp bends pipe	Section 2, sharp bends pipe
Number	1	1	1	1	1	1	1	1	1	1	1
Dimensions of element	SI	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm
		Angle w: 0.00 degree	Angle w: 0.00 degree	Angle w: 0.00 degree	Length of pipe L: 20.00 m	Length of pipe L: 14.00 m	Angle w: 90.00 degree	Angle w: 45.00 degree	Angle w: 60.00 degree	Angle w: 90.00 degree	Angle w: 90.00 degree

4. Result of calculation											
Veloc. of flow	m/s	1.018591636	1.018591636	1.018591636	1.018591636	1.018591636	1.018591636	1.018591636	1.018591636	1.018591636	1.51797603
Reynolds number		25368.21784	25368.21784	25368.21784	25368.21784	25368.21784	25368.21784	25368.21784	25368.21784	25368.21784	120826.2357
Veloc. of flow 2	m/s										1.018591636
Reynolds number 2											25368.21784
Flow	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent
Absolute roughness	mm	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15	0.15
Pipe friction number		0.035091118	0.035091118	0.035091118	0.035091118	0.035091118	0.035091118	0.035091118	0.035091118	0.035091118	0.035091118
Resistance coefficient		28.07389458	19.6310263	5.99595257	0.374602152	0.472121736	0.215423777	0.215423777	0.215423777	0.215423777	0.081178971
Resistance coefficient branch pipe											0.492202520
Press. drop branch pipe	mbar	0	0	145.1700621	101.7590435	49.6782706	5.819430203	2.444796396	0.173869222	0.173869222	76.4666466
Pressure drop	bar	0	0	0.145170062	0.101759043	0.049678267	0.005819403	0.002444796	0.001738692	0.001738692	0.00764666466
Sum Pressure drop	bar	0	0.107890671	0.308890671	0.454267793	0.556019776	0.605698043	0.611517474	0.61396227	0.61396227	0.0764666466

Project: Bilge settle Dynamic regulating valve Self acting temp. control valve Ball valve Pipe Pipe big settl Bends, big settl Connected pipes

Column nr.	1	2	3	4	5	6	12
1. Flow medium							
Flow medium	Water	Water	Water	Water	Water	Water	Water
Condition	liquid	liquid	liquid	liquid	liquid	liquid	liquid
Volume flow	m3/h	1.5	1.5	1.5	1.5	1.5	36.2
Mass flow	kg/h	1497.3	1497.3	1497.3	1497.3	1497.3	36134.84
Volume flow branch pipe	m3/h						1.5
Density	kg/m3	998.2	998.2	998.2	998.2	998.2	998.2
Dyn.Viscos.	10-6 kg/ms	1002	1002	1002	1002	1002	1002
Kin.Viscos.	10-6 m2/s	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852

2. Additional data for gases

Pressure (inlet, abs.) bar
 Temperature (inlet) °C
 Temperature (outlet) °C
 Norm volume flow Nm3/h

3. Element of pipe

Pipe identification	Branch 3m dynamic regulating valve	Branch 3, self acting temp. control valve	Branch 3, ball valve	Pipe, branch 3	Pipe, big settl	Bends, big settl	Section 1, sharp bends pipe
Element of pipe	Dynamic regulating valve	Self acting temp. control valve	Ball valve	circular	circular	Circular bend	Branch flowing asunder
Number	1	1	1	1	1	1	23
Dimensions of element	SI Diameter of pipe D: 25.00 mm Angle w: 0.00 degree	Diameter of pipe D: 25.00 mm Angle w: 0.00 degree	Diameter of pipe D: 25.00 mm Angle w: 0.00 degree	Diameter of pipe D: 25.00 mm Length of pipe L: 11.70 m	Diameter of pipe D: 25.00 mm Length of pipe L: 16.00 m	Diameter of pipe D: 25.00 mm Radius R: 42.00 mm Angle w: 90.00 degree	Diameter of pipe D1: 79.90 mm Diameter of pipe D2: 25.00 mm Radius R: 0.00 mm Angle w: 90.00 degree

4. Result of calculation

Veloc. of flow	m/s	0.848826363	0.848826363	0.848826363	0.848826363	0.848826363	0.848826363	2.005499831
Reynolds number		21140.18153	21140.18153	21140.18153	21140.18153	21140.18153	21140.18153	159631.742
Veloc. of flow 2	m/s							0.848826363
Reynolds number 2								21140.18153
Flow	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent	turbulent
Absolute roughness	mm				0.15	0.15	0.15	
Pipe friction number					0.035622616	0.035622616	0.035622616	
Resistance coefficient				0	16.67138428	22.79847423	0.623804416	0.02022368
Resistance coefficient branch pipe								1.128693441
Press. drop branch pipe	mbar							22.53688995
Pressure drop	mbar			0	59.95107174	81.98437161	51.59428162	0.405942797
Pressure drop	bar	0.0171	0.074924077	0	0.059951072	0.081984372	0.051594282	0.000405943
Sum Pressure drop	bar	0.0171	0.092024077	0.092024077	0.151975149	0.23395952	0.285553802	0.285959745

Input data summary

Element	1	2	3	4	5	6	12
Flow medium	Water	Water	Water	Water	Water	Water	Water
Condition	liquid	liquid	liquid	liquid	liquid	liquid	liquid
Volume flow	1.5	1.5	1.5	1.5	1.5	1.5	36.2
Mass flow	1497.3	1497.3	1497.3	1497.3	1497.3	1497.3	36134.84
Volume flow branch pipe							1.5
Density	998.2	998.2	998.2	998.2	998.2	998.2	998.2
Dyn.Viscos.	1002	1002	1002	1002	1002	1002	1002
Kin.Viscos.	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852

Temperature summary

Element	1	2	3	4	5	6	12
Pressure (inlet, abs.)							
Temperature (inlet)							
Temperature (outlet)							
Norm volume flow							

Project: Weelhouse

Column nr. 1 2 3 4 5 6

1. Flow medium		Water	Water	Water	Water	Water	Water
Condition		liquid	liquid	liquid	liquid	liquid	liquid
Volume flow	m ³ /h	1.94	1.94	1.94	1.94	1.94	1.94
Mass flow	kg/h	1936.508	1936.508	1936.508	1936.508	1936.508	1936.508
Volume flow branch pipe	m ³ /h						
Density	kg/m ³	998.2	998.2	998.2	998.2	998.2	998.2
Dyn.Viscos.	10 ⁻⁶ kg/ms	1002	1002	1002	1002	1002	1002
Kin.Viscos.	10 ⁻⁶ m ² /s	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852

2. Additional data for gases							
Pressure (inlet, abs.)	bar						
Temperature (inlet)	°C						
Temperature (outlet)	°C						
Norm volume flow	Nm ³ /h						

3. Element of pipe		Pipe, branch 5	Bends	Section 5 Inlet	Section 5 3-Way valve (Manual Calculation)	Section 5 Dynamic valve (Manual Calculation)	Section 5 AHUZ (Manual Calculation)
Pipe identification		Pipe, branch 5	Bends	Section 5 Inlet	Section 5 3-Way valve (Manual Calculation)	Section 5 Dynamic valve (Manual Calculation)	Section 5 AHUZ (Manual Calculation)
Element of pipe		circular	Circular bend	Sharp edged entrance	Swing valve	Swing valve	Air Handling Unit 2
Number		1	1	1	1	1	1
Dimensions of element	SI	Diameter of pipe D: 25.00 mm Length of pipe L: 35.00 m	Diameter of pipe D: 25.00 mm Radius R: 42.00 mm Angle w: 90.00 degree	Diameter of pipe D: 25.00 mm	Diameter of pipe D: 25.00 mm Angle w: 0.00 degree	Diameter of pipe D: 25.00 mm Angle w: 0.00 degree	

The pipe entrance is: sharp-edged

4. Result of calculation							
Veloc. of flow	m/s	1.09781543	1.09781543	1.09781543	1.09781543	1.09781543	1.09781543
Reynolds number		27341.30144	27341.30144	27341.30144	27341.30144	27341.30144	27341.30144
Veloc. of flow 2	m/s						
Reynolds number 2							
Flow		turbulent	turbulent	turbulent	turbulent	turbulent	turbulent
Absolute roughness	mm	0.15	0.15				
Pipe friction number		0.034894417	0.034894417				
Resistance coefficient		48.85218363	0.590116387	0.5	0	0	0 Kvs=10m ³ /h
Resistance coefficient branch pipe							
Press. drop branch pipe	mbar						
Pressure drop	mbar	293.853056	3.549636696	3.0075734	60	200	376
Pressure drop	bar	0.293853056	0.003549637	0.003007573	0.06	0.2	0.376
Sum Pressure drop	bar	0.293853056	0.297402693	0.300410266	0.360410266	0.560410266	0.936410266

Project: Galley	Pipe	90 deg bend	Dynamic valve	3-way motor valve	AH3
Column nr.	1	2	3	4	

1. Flow medium						
Flow medium		Water	Water	Water	Water	Water
Condition		liquid	liquid	liquid	liquid	liquid
Volume flow	m3/h	3.96	3.96	3.96	3.96	3.96
Mass flow	kg/h	3952.872	3952.872	3952.872	3952.872	3952.872
Volume flow branch.pipe	m3/h					
Density	kg/m3	998.2	998.2	998.2	998.2	998.2
Dyn.Viscos.	10-6 kg/ms	1002	1002	1002	1002	1002
Kin.Viscos.	10-6 m2/s	1.003806852	1.003806852	1.003806852	1.003806852	1.003806852

2. Additional data for gases	
Pressure (inlet, abs.)	bar
Temperature (inlet)	°C
Temperature (outlet)	°C
Norm volume flow	Nm3/h

3. Element of pipe						
Pipe identification		Pipe, branch 6	Bend	Dynamic valve, Frese Sigma compact	3-way motor valve	AH3
Element of pipe		circular	Circular bend	Dynamic valve, Frese Sigma compact	3-way motor valve	AH3
Number		1	4	1	1	
Dimensions of element	SI	Diameter of pipe D: 32.00 mm	Diameter of pipe D: 32.00 mm	Diameter of pipe D: 32.00 mm	Diameter of pipe D: 32.00 mm	Diameter of pipe D: 32.00 mm
		Length of pipe L: 35.00 m	Radius R: 52.50 mm			
			Angle w: 90.00 degree			

4. Result of calculation						
Veloc. of flow	m/s	1.367737792	1.367737792	1.367737792	1.367737792	1.367737792
Reynolds number		43601.6244	43601.6244	43601.6244	43601.6244	43601.6244
Veloc. of flow 2	m/s					
Reynolds number 2						
Flow		turbulent	turbulent	turbulent	turbulent	
Absolute roughness	mm	0.15	0.15			
Pipe friction number		0.031878247	0.031878247			
Resistance coefficient		34.86683283	0.534489868	3.91	3.91	3.91
Resistance coefficient branch.pipe						
Press. drop branch.pipe	mbar					
Pressure drop	mbar	325.5410529	19.96147976			
Pressure drop	bar	0.325541053	0.01996148	0.19	0.05	0.015
Sum Pressure drop	bar	0.325541053	0.345502533	0.535502533	0.585502533	0.600502533

Branch	Cumulative Pressure drop (bar)	Flow m ³ /h
Main Pipeline	2.89	21.5
Branch 1	0.13	5.5
Branch 2	0.61	1.8
Branch 3	0.29	1.5
Branch 4	1.51	66.2
Branch 5	0.94	1.94
Branch 6	0.60	3.96

One or more of the Nodes has a more severe Pressure drop than the main pipeline

Column Comparison Tool

This is a tool to compare pressure through the main pipe and the pressure through each branching pipe. Select the inlet column in the dropdown menu, this is where the branch leaves the main pipeline.

Then proceed to select the outlet column, this is where the node returns. The tool then compares the pressure drop from the fluid traveling through the main pipeline and from traveling in the branch.

If the pressure in the main pipeline is most severe then the cumulative pressure drop from the main pipeline can be used.

Column Comparison	
Branch 1	
Inlet Column	6
Outlet Column	40
Pressure through main pipe (bar)	1.35
Pressure through branching pipe (bar)	0.13
Pressure through the main pipe has the most severe pressure drop	
Branch 2	
Inlet Column	6
Outlet Column	44
Pressure through main pipe (bar)	1.40
Pressure through branching pipe (bar)	0.61
Pressure through the main pipe has the most severe pressure drop	
Branch 3	
Inlet Column	6
Outlet Column	46
Pressure through main pipe (bar)	1.41
Pressure through branching pipe (bar)	0.29
Pressure through the main pipe has the most severe pressure drop	
Branch 4	
Inlet Column	62
Outlet Column	48
Pressure through main pipe (bar)	1.50
Pressure through branching pipe (bar)	1.51
Pressure through the branching pipe has the most severe pressure drop	
Branch 5	
Inlet Column	16
Outlet Column	30
Pressure through main pipe (bar)	1.13
Pressure through branching pipe (bar)	0.94
Pressure through the main pipe has the most severe pressure drop	
Branch 6	
Inlet Column	14
Outlet Column	33
Pressure through main pipe (bar)	1.18
Pressure through branching pipe (bar)	0.60
Pressure through the main pipe has the most severe pressure drop	

Caution, outlet node is before inlet node

A.8 Power Consumption During Cold Conditions

Pump curve polynomial

$$H(Q) = a + b \cdot Q + c \cdot Q^2$$

Estimate a curve for the pump at a constant frequency using curve fitting software. With Q values in m³/h and H in m.

a	0.0
b	0.0000
c	0.0000

Minimum frequency	50
Maximum frequency	50
Minimum flow rate (m³/h)	0.0
Maximum flow rate (m³/h)	0.0
Minimum head (m)	0.0
Maximum head (m)	0.0

Efficiency polynomial

$$\eta(Q) = d + e \cdot Q + f \cdot Q^2$$

d	0.0
e	0.0000
f	0.0000

Modes

Mode	Frequency (Hz)	Flow rate (m³/h)	Head (m)	Efficiency (%)
1	50	0.0	0.0	0.0
2	50	10.0	0.0	0.0
3	50	20.0	0.0	0.0
4	50	30.0	0.0	0.0
5	50	40.0	0.0	0.0
6	50	50.0	0.0	0.0
7	50	60.0	0.0	0.0
8	50	70.0	0.0	0.0
9	50	80.0	0.0	0.0
10	50	90.0	0.0	0.0
11	50	100.0	0.0	0.0
12	50	110.0	0.0	0.0
13	50	120.0	0.0	0.0
14	50	130.0	0.0	0.0
15	50	140.0	0.0	0.0
16	50	150.0	0.0	0.0
17	50	160.0	0.0	0.0
18	50	170.0	0.0	0.0
19	50	180.0	0.0	0.0
20	50	190.0	0.0	0.0
21	50	200.0	0.0	0.0
22	50	210.0	0.0	0.0
23	50	220.0	0.0	0.0
24	50	230.0	0.0	0.0
25	50	240.0	0.0	0.0
26	50	250.0	0.0	0.0
27	50	260.0	0.0	0.0
28	50	270.0	0.0	0.0
29	50	280.0	0.0	0.0
30	50	290.0	0.0	0.0
31	50	300.0	0.0	0.0
32	50	310.0	0.0	0.0
33	50	320.0	0.0	0.0
34	50	330.0	0.0	0.0
35	50	340.0	0.0	0.0
36	50	350.0	0.0	0.0
37	50	360.0	0.0	0.0
38	50	370.0	0.0	0.0
39	50	380.0	0.0	0.0
40	50	390.0	0.0	0.0
41	50	400.0	0.0	0.0
42	50	410.0	0.0	0.0
43	50	420.0	0.0	0.0
44	50	430.0	0.0	0.0
45	50	440.0	0.0	0.0
46	50	450.0	0.0	0.0
47	50	460.0	0.0	0.0
48	50	470.0	0.0	0.0
49	50	480.0	0.0	0.0
50	50	490.0	0.0	0.0
51	50	500.0	0.0	0.0
52	50	510.0	0.0	0.0
53	50	520.0	0.0	0.0
54	50	530.0	0.0	0.0
55	50	540.0	0.0	0.0
56	50	550.0	0.0	0.0
57	50	560.0	0.0	0.0
58	50	570.0	0.0	0.0
59	50	580.0	0.0	0.0
60	50	590.0	0.0	0.0
61	50	600.0	0.0	0.0
62	50	610.0	0.0	0.0
63	50	620.0	0.0	0.0
64	50	630.0	0.0	0.0
65	50	640.0	0.0	0.0
66	50	650.0	0.0	0.0
67	50	660.0	0.0	0.0
68	50	670.0	0.0	0.0
69	50	680.0	0.0	0.0
70	50	690.0	0.0	0.0
71	50	700.0	0.0	0.0
72	50	710.0	0.0	0.0
73	50	720.0	0.0	0.0
74	50	730.0	0.0	0.0
75	50	740.0	0.0	0.0
76	50	750.0	0.0	0.0
77	50	760.0	0.0	0.0
78	50	770.0	0.0	0.0
79	50	780.0	0.0	0.0
80	50	790.0	0.0	0.0
81	50	800.0	0.0	0.0
82	50	810.0	0.0	0.0
83	50	820.0	0.0	0.0
84	50	830.0	0.0	0.0
85	50	840.0	0.0	0.0
86	50	850.0	0.0	0.0
87	50	860.0	0.0	0.0
88	50	870.0	0.0	0.0
89	50	880.0	0.0	0.0
90	50	890.0	0.0	0.0
91	50	900.0	0.0	0.0
92	50	910.0	0.0	0.0
93	50	920.0	0.0	0.0
94	50	930.0	0.0	0.0
95	50	940.0	0.0	0.0
96	50	950.0	0.0	0.0
97	50	960.0	0.0	0.0
98	50	970.0	0.0	0.0
99	50	980.0	0.0	0.0
100	50	990.0	0.0	0.0
101	50	1000.0	0.0	0.0
102	50	1010.0	0.0	0.0
103	50	1020.0	0.0	0.0
104	50	1030.0	0.0	0.0
105	50	1040.0	0.0	0.0
106	50	1050.0	0.0	0.0
107	50	1060.0	0.0	0.0
108	50	1070.0	0.0	0.0
109	50	1080.0	0.0	0.0
110	50	1090.0	0.0	0.0
111	50	1100.0	0.0	0.0
112	50	1110.0	0.0	0.0
113	50	1120.0	0.0	0.0
114	50	1130.0	0.0	0.0
115	50	1140.0	0.0	0.0
116	50	1150.0	0.0	0.0
117	50	1160.0	0.0	0.0
118	50	1170.0	0.0	0.0
119	50	1180.0	0.0	0.0
120	50	1190.0	0.0	0.0
121	50	1200.0	0.0	0.0
122	50	1210.0	0.0	0.0
123	50	1220.0	0.0	0.0
124	50	1230.0	0.0	0.0
125	50	1240.0	0.0	0.0
126	50	1250.0	0.0	0.0
127	50	1260.0	0.0	0.0
128	50	1270.0	0.0	0.0
129	50	1280.0	0.0	0.0
130	50	1290.0	0.0	0.0
131	50	1300.0	0.0	0.0
132	50	1310.0	0.0	0.0
133	50	1320.0	0.0	0.0
134	50	1330.0	0.0	0.0
135	50	1340.0	0.0	0.0
136	50	1350.0	0.0	0.0
137	50	1360.0	0.0	0.0
138	50	1370.0	0.0	0.0
139	50	1380.0	0.0	0.0
140	50	1390.0	0.0	0.0
141	50	1400.0	0.0	0.0
142	50	1410.0	0.0	0.0
143	50	1420.0	0.0	0.0
144	50	1430.0	0.0	0.0
145	50	1440.0	0.0	0.0
146	50	1450.0	0.0	0.0
147	50	1460.0	0.0	0.0
148	50	1470.0	0.0	0.0
149	50	1480.0	0.0	0.0
150	50	1490.0	0.0	0.0
151	50	1500.0	0.0	0.0
152	50	1510.0	0.0	0.0
153	50	1520.0	0.0	0.0
154	50	1530.0	0.0	0.0
155	50	1540.0	0.0	0.0
156	50	1550.0	0.0	0.0
157	50	1560.0	0.0	0.0
158	50	1570.0	0.0	0.0
159	50	1580.0	0.0	0.0
160	50	1590.0	0.0	0.0
161	50	1600.0	0.0	0.0
162	50	1610.0	0.0	0.0
163	50	1620.0	0.0	0.0
164	50	1630.0	0.0	0.0
165	50	1640.0	0.0	0.0
166	50	1650.0	0.0	0.0
167	50	1660.0	0.0	0.0
168	50	1670.0	0.0	0.0
169	50	1680.0	0.0	0.0
170	50	1690.0	0.0	0.0
171	50	1700.0	0.0	0.0
172	50	1710.0	0.0	0.0
173	50	1720.0	0.0	0.0
174	50	1730.0	0.0	0.0
175	50	1740.0	0.0	0.0
176	50	1750.0	0.0	0.0
177	50	1760.0	0.0	0.0
178	50	1770.0	0.0	0.0
179	50	1780.0	0.0	0.0
180	50	1790.0	0.0	0.0
181	50	1800.0	0.0	0.0
182	50	1810.0	0.0	0.0
183	50	1820.0	0.0	0.0
184	50	1830.0	0.0	0.0
185	50	1840.0	0.0	0.0
186	50	1850.0	0.0	0.0
187	50	1860.0	0.0	0.0
188	50	1870.0	0.0	0.0
189	50	1880.0	0.0	0.0
190	50	1890.0	0.0	0.0
191	50	1900.0	0.0	0.0
192	50	1910.0	0.0	0.0
193	50	1920.0	0.0	0.0
194	50	1930.0	0.0	0.0
195	50	1940.0	0.0	0.0
196	50	1950.0	0.0	0.0
197	50	1960.0	0.0	0.0
198	50	1970.0	0.0	0.0
199	50	1980.0	0.0	0.0
200	50	1990.0	0.0	0.0
201	50	2000.0	0.0	0.0
202	50	2010.0	0.0	0.0
203	50	2020.0	0.0	0.0
204	50	2030.0	0.0	0.0
205	50	2040.0	0.0	0.0
206	50	2050.0	0.0	0.0
207	50	2060.0	0.0	0.0
208	50	2070.0	0.0	0.0
209	50	2080.0	0.0	0.0
210	50	2090.0	0.0	0.0
211	50	2100.0	0.0	0.0
212	50	2110.0	0.0	0.0
213	50	2120.0	0.0	0.0
214	50	2130.0	0.0	0.0
215	50	2140.0	0.0	0.0
216	50	2150.0	0.0	0.0
217	50	2160.0	0.0	0.0
218	50	2170.0	0.0	0.0
219	50	2180.0	0.0	0.0
220	50	2190.0	0.0	0.0
221	50	2200.0	0.0	0.0
222	50	2210.0	0.0	0.0
223	50	2220.0	0.0	0.0
224	50	2230.0	0.0	0.0
225	50	2240.0	0.0	0.0
226	50	2250.0	0.0	0.0
227	50	2260.0	0.0	0.0
228	50	2270.0	0.0	0.0
229	50	2280.0	0.0	0.0
230	50	2290.0	0.0	0.0
231	50	2300.0	0.0	0.0
232	50	2310.0	0.0	0.0
233	50	2320.0	0.0	0.0
234	50	2330.0	0.0	0.0
235	50	2340.0	0.0	0.0
236	50	2350.0	0.0	0.0
237	50	2360.0	0.0	0.0
238	50	2370.0	0.0	0.0
239	50	2380.0	0.0	0.0
240	50	2390.0	0.0	0.0
241	50	2400.0	0.0	0.0
242	50	2410.0	0.0	0.0
243	50	2420.0	0.0	0.0
244	50	2430.0	0.0	0.0
245	50	2440.0	0.0	0.0
246	50	2450.0	0.0	0.0
247	50	2460.0	0.0	0.0
248	50	2470.0	0.0	0.0
249	50	2480.0	0.0	0.0
250	50	2490.0	0.0	0.0
251	50	2500.0	0.0	0.0
252	50	25		

Summary of the pump calculations cold weather

Dynamic system

NB 32 125/01 Parallel		NB 32 125/01		NB 32-160/02		Grundfos HYDRO MULTI-E 4	
Flow [m ³ /h]	9.12	Flow [m ³ /h]	2.12	Flow [m ³ /h]	2.12	Flow [m ³ /h]	6.12
Head required [m]	7	Head required [m]	0	Head required [m]	0	Head required [m]	7
Frequency [2/min]	39.29	Frequency [2/min]	88.29	Frequency [2/min]	39.45	Frequency [2/min]	3000
Change of Frequency C	100%	Change of Frequency C	100%	Change of Frequency C	100%	Change of Frequency C	100%
Efficiency [%]	2.75	Efficiency [%]	1.74	Efficiency [%]	3.05	Efficiency [%]	5.71
Power consumption [kW]	4.14	Power consumption [kW]	2.21	Power consumption [kW]	2.12	Power consumption [kW]	4.40
0	0	0	0	0	0	0	0
Head [m]	8.44	Head [m]	6.44	Head [m]	6.44	Head [m]	5.61
Flow [m ³ /h]	9.12	Flow [m ³ /h]	2.12	Flow [m ³ /h]	2.12	Flow [m ³ /h]	6.12
Frequency [2/min]	39.29	Frequency [2/min]	88.29	Frequency [2/min]	39.45	Frequency [2/min]	3000
Change of Frequency C	100%	Change of Frequency C	100%	Change of Frequency C	100%	Change of Frequency C	100%
Efficiency [%]	2.75	Efficiency [%]	1.74	Efficiency [%]	2.75	Efficiency [%]	5.61
Power consumption [kW]	4.14	Power consumption [kW]	2.21	Power consumption [kW]	2.40	Power consumption [kW]	4.40
0	0	0	0	0	0	0	0
Dynamic adjustment	0	Dynamic adjustment	0	Dynamic adjustment	0	Dynamic adjustment	0
Head required [m]	8.44	Head required [m]	6.44	Head required [m]	6.44	Head required [m]	5.61
Flow [m ³ /h]	9.12	Flow [m ³ /h]	2.12	Flow [m ³ /h]	2.12	Flow [m ³ /h]	6.12
Frequency [2/min]	39.29	Frequency [2/min]	88.29	Frequency [2/min]	39.45	Frequency [2/min]	3000
Change of Frequency C	100%	Change of Frequency C	100%	Change of Frequency C	100%	Change of Frequency C	100%
Efficiency [%]	2.75	Efficiency [%]	1.74	Efficiency [%]	2.75	Efficiency [%]	5.61
Power consumption [kW]	4.14	Power consumption [kW]	2.21	Power consumption [kW]	2.40	Power consumption [kW]	4.40

Constant flow system	
Flow [m ³ /h]	27.40
Head [m]	15
Frequency [2/min]	39.13
Change of Frequency C	100%
Efficiency [%]	0.80
Power consumption [kW]	4.40
0	0
Head [m]	27.4
Flow [m ³ /h]	27
Frequency [2/min]	39.13
Change of Frequency C	100%
Efficiency [%]	0.80
Power consumption [kW]	4.40
0	0
Dynamic adjustment	0
Flow [m ³ /h]	27.4
Head [m]	27
Frequency [2/min]	39.13
Change of Frequency C	100%
Efficiency [%]	0.80
Power consumption [kW]	4.40

Pump power consumption saving	
Power consumption with static system [kW]	4.40
Power consumption with dynamic system [kW]	1.45
Power saving [kW]	2.94
Power saving potential [%]	67%
Power consumption scaling factor [1]	0.33
Power consumption with static system [kW]	4.40
Power consumption with dynamic system [kW]	1.40
Power saving [kW]	3.00
Power saving potential [%]	68%
Power consumption scaling factor [1]	0.33
Power consumption with static system [kW]	4.40
Power consumption with dynamic system [kW]	1.40
Power saving [kW]	3.00
Power saving potential [%]	68%
Power consumption scaling factor [1]	0.32

Fuel consumption	
Annual energy demand static [kWh]	2.118
Annual energy demand dynamic [kWh]	707
Fuel consumption static [kg]	401.8
Fuel consumption dynamic [kg]	151.5
Annual fuel cost static system [NOK]	8.294
Annual fuel cost dynamic system [NOK]	2.742
Annual savings [NOK]	5.552
Annual energy demand static [kWh]	499
Annual energy demand dynamic [kWh]	158
Fuel consumption static [kg]	101.2
Fuel consumption dynamic [kg]	31.2
Annual fuel cost static system [NOK]	1.813
Annual fuel cost dynamic system [NOK]	0.78
Annual savings [NOK]	1.243
Annual energy demand static [kWh]	11.017
Annual energy demand dynamic [kWh]	3.089
Fuel consumption static [kg]	2361.2
Fuel consumption dynamic [kg]	749.8
Annual fuel cost static system [NOK]	42.502
Annual fuel cost dynamic system [NOK]	13.491
Annual savings [NOK]	29.015

Potential savings in emissions	
Annual CO ₂ emissions [kg]	5893.48
Annual Non-emissions [kg]	58.87
Annual CO emissions [kg]	9.38
Annual HC emissions [kg]	1.83
Annual particulate emissions [kg]	0.48

Average daily savings [NOK]	165
Total annual savings [NOK]	35.799
Total annual fuel saving [kg]	1088.4

This is the potential for savings by switching from a static flow system without throttling to a dynamic flow system, either with frequency controlling or using just throttling depending on the pump curves were fit the the working points or kept at a constant frequency.

A.9 Power Consumption During Middle Conditions

Pump curve polynomial

$$H(Q) = a + b \cdot Q + c \cdot Q^2$$

a	0
b	0.001
c	-0.0001

Estimate a curve for the pump at a constant frequency using our fitting software. Web Q values in m³/h and m in m.

Efficiency polynomial

$$\eta(Q) = d + e \cdot Q + f \cdot Q^2$$

d	0
e	0.001
f	-0.0001

Modes

Mode	Flow (m³/h)	Head (m)	Efficiency (%)
1	0	0	0
2	10	10	10
3	20	20	20
4	30	30	30
5	40	40	40
6	50	50	50
7	60	60	60
8	70	70	70
9	80	80	80
10	90	90	90
11	100	100	100
12	110	110	110
13	120	120	120
14	130	130	130
15	140	140	140
16	150	150	150
17	160	160	160
18	170	170	170
19	180	180	180
20	190	190	190
21	200	200	200
22	210	210	210
23	220	220	220
24	230	230	230
25	240	240	240
26	250	250	250
27	260	260	260
28	270	270	270
29	280	280	280
30	290	290	290
31	300	300	300
32	310	310	310
33	320	320	320
34	330	330	330
35	340	340	340
36	350	350	350
37	360	360	360
38	370	370	370
39	380	380	380
40	390	390	390
41	400	400	400
42	410	410	410
43	420	420	420
44	430	430	430
45	440	440	440
46	450	450	450
47	460	460	460
48	470	470	470
49	480	480	480
50	490	490	490
51	500	500	500
52	510	510	510
53	520	520	520
54	530	530	530
55	540	540	540
56	550	550	550
57	560	560	560
58	570	570	570
59	580	580	580
60	590	590	590
61	600	600	600
62	610	610	610
63	620	620	620
64	630	630	630
65	640	640	640
66	650	650	650
67	660	660	660
68	670	670	670
69	680	680	680
70	690	690	690
71	700	700	700
72	710	710	710
73	720	720	720
74	730	730	730
75	740	740	740
76	750	750	750
77	760	760	760
78	770	770	770
79	780	780	780
80	790	790	790
81	800	800	800
82	810	810	810
83	820	820	820
84	830	830	830
85	840	840	840
86	850	850	850
87	860	860	860
88	870	870	870
89	880	880	880
90	890	890	890
91	900	900	900
92	910	910	910
93	920	920	920
94	930	930	930
95	940	940	940
96	950	950	950
97	960	960	960
98	970	970	970
99	980	980	980
100	990	990	990
101	1000	1000	1000
102	1010	1010	1010
103	1020	1020	1020
104	1030	1030	1030
105	1040	1040	1040
106	1050	1050	1050
107	1060	1060	1060
108	1070	1070	1070
109	1080	1080	1080
110	1090	1090	1090
111	1100	1100	1100
112	1110	1110	1110
113	1120	1120	1120
114	1130	1130	1130
115	1140	1140	1140
116	1150	1150	1150
117	1160	1160	1160
118	1170	1170	1170
119	1180	1180	1180
120	1190	1190	1190
121	1200	1200	1200
122	1210	1210	1210
123	1220	1220	1220
124	1230	1230	1230
125	1240	1240	1240
126	1250	1250	1250
127	1260	1260	1260
128	1270	1270	1270
129	1280	1280	1280
130	1290	1290	1290
131	1300	1300	1300
132	1310	1310	1310
133	1320	1320	1320
134	1330	1330	1330
135	1340	1340	1340
136	1350	1350	1350
137	1360	1360	1360
138	1370	1370	1370
139	1380	1380	1380
140	1390	1390	1390
141	1400	1400	1400
142	1410	1410	1410
143	1420	1420	1420
144	1430	1430	1430
145	1440	1440	1440
146	1450	1450	1450
147	1460	1460	1460
148	1470	1470	1470
149	1480	1480	1480
150	1490	1490	1490
151	1500	1500	1500
152	1510	1510	1510
153	1520	1520	1520
154	1530	1530	1530
155	1540	1540	1540
156	1550	1550	1550
157	1560	1560	1560
158	1570	1570	1570
159	1580	1580	1580
160	1590	1590	1590
161	1600	1600	1600
162	1610	1610	1610
163	1620	1620	1620
164	1630	1630	1630
165	1640	1640	1640
166	1650	1650	1650
167	1660	1660	1660
168	1670	1670	1670
169	1680	1680	1680
170	1690	1690	1690
171	1700	1700	1700
172	1710	1710	1710
173	1720	1720	1720
174	1730	1730	1730
175	1740	1740	1740
176	1750	1750	1750
177	1760	1760	1760
178	1770	1770	1770
179	1780	1780	1780
180	1790	1790	1790
181	1800	1800	1800
182	1810	1810	1810
183	1820	1820	1820
184	1830	1830	1830
185	1840	1840	1840
186	1850	1850	1850
187	1860	1860	1860
188	1870	1870	1870
189	1880	1880	1880
190	1890	1890	1890
191	1900	1900	1900
192	1910	1910	1910
193	1920	1920	1920
194	1930	1930	1930
195	1940	1940	1940
196	1950	1950	1950
197	1960	1960	1960
198	1970	1970	1970
199	1980	1980	1980
200	1990	1990	1990
201	2000	2000	2000
202	2010	2010	2010
203	2020	2020	2020
204	2030	2030	2030
205	2040	2040	2040
206	2050	2050	2050
207	2060	2060	2060
208	2070	2070	2070
209	2080	2080	2080
210	2090	2090	2090
211	2100	2100	2100
212	2110	2110	2110
213	2120	2120	2120
214	2130	2130	2130
215	2140	2140	2140
216	2150	2150	2150
217	2160	2160	2160
218	2170	2170	2170
219	2180	2180	2180
220	2190	2190	2190
221	2200	2200	2200
222	2210	2210	2210
223	2220	2220	2220
224	2230	2230	2230
225	2240	2240	2240
226	2250	2250	2250
227	2260	2260	2260
228	2270	2270	2270
229	2280	2280	2280
230	2290	2290	2290
231	2300	2300	2300
232	2310	2310	2310
233	2320	2320	2320
234	2330	2330	2330
235	2340	2340	2340
236	2350	2350	2350
237	2360	2360	2360
238	2370	2370	2370
239	2380	2380	2380
240	2390	2390	2390
241	2400	2400	2400
242	2410	2410	2410
243	2420	2420	2420
244	2430	2430	2430
245	2440	2440	2440
246	2450	2450	2450
247	2460	2460	2460
248	2470	2470	2470
249	2480	2480	2480
250	2490	2490	2490
251	2500	2500	2500
252	2510	2510	2510
253	2520	2520	2520
254	2530	2530	2530
255	2540	2540	2540
256	2550	2550	2550
257	2560	2560	2560
258	2570	2570	2570
259	2580	2580	2580
260	2590	2590	2590
261	2600	2600	2600
262	2610	2610	2610
263	2620	2620	2620
264	2630	2630	2630
265	2640	2640	2640
266	2650	2650	2650
267	2660	2660	2660
268	2670	2670	2670
269	2680	2680	2680
270	2690	2690	2690
271	2700	2700	2700
272	2710	2710	2710
273	2720	2720	2720
274	2730	2730	2730
275	2740	2740	2740
276	2750	2750	2750
277	2760	2760	2760
278	2770	2770	2770
279	2780	2780	2780
280	2790	2790	2790
281	2800	2800	2800
282	2810	2810	2810
283	2820	2820	2820
284	2830	2830	2830
285	2840	2840	2840
286	2850	2850	2850
287	2860	2860	2860
288	2870	2870	2870
289	2880	2880	2880
290	2890	2890	2890
291	2900	2900	2900
292	2910	2910	2910
293	2920	2920	2920
294	2930	2930	2930
295	2940	2940	2940
296	2950	2950	2950
297	2960	2960	2960
298	2970	2970	2970
299	2980	2980	2980
300	2990	2990	2990
301	3000	3000	3000
302	3010	3010	3010
303	3020	3020	3020
304	3030	3030	3030
305	3040	3040	3040
306	3050	3050	3050
307	3060	3060	3060
308	3070	3070	3070
309	3080	3080	3080
310	3090	3090	

Pump curve polynomial

$$H(Q) = a + b \cdot Q + c \cdot Q^2$$

a	4.22
b	0.001
c	-0.002

Flow rate (m³/h)	0	10	20	30	40	50
Head (m)	4.22	4.22	4.22	4.22	4.22	4.22

Efficiency polynomial

$$\eta(Q) = d + e \cdot Q + f \cdot Q^2$$



d	0.001
e	0.002
f	0.001

Estimated curves for the purpose of constant frequency using curve fitting software. With Q values in m³/h and H in m.

Modes	
Flow rate (m³/h)	0
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	10
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	20
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	30
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	40
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	50
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001

Fit curves to working points

Reset frequency



Pump curve polynomial

$$H(Q) = a + b \cdot Q + c \cdot Q^2$$

a	4.22
b	0.001
c	-0.002

Flow rate (m³/h)	0	10	20	30	40	50
Head (m)	4.22	4.22	4.22	4.22	4.22	4.22

Efficiency polynomial

$$\eta(Q) = d + e \cdot Q + f \cdot Q^2$$



d	0.001
e	0.002
f	0.001

Estimated curves for the purpose of constant frequency using curve fitting software. With Q values in m³/h and H in m.

Modes	
Flow rate (m³/h)	0
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	10
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	20
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	30
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	40
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001
Flow rate (m³/h)	50
Head (m)	4.22
Efficiency (%)	0.001
Power (kW)	0.001

Fit curves to working points

Reset frequency



Summary of the pump calculations middle weather

Dynamic system

NB 32 125/01 Parallel

Flow [m ³ /h]	4.05
Head required [m]	0
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	20%
Power consumption [kW]	4.05
0	
0	
Flow [m ³ /h]	5.66
Head required [m]	7
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	33%
Power consumption [kW]	3.38
0	
0	
Flow [m ³ /h]	5.66
Head required [m]	7
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	14%
Power consumption [kW]	3.38

NB 32 125/01

Flow [m ³ /h]	4.05
Head required [m]	0
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	20%
Power consumption [kW]	2.59
0	
0	
Flow [m ³ /h]	3.66
Head required [m]	7
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	18%
Power consumption [kW]	2.07
0	
0	
Flow [m ³ /h]	3.66
Head required [m]	7
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	18%
Power consumption [kW]	2.07

NB 32-160/02

Flow [m ³ /h]	4.05
Head required [m]	0
Frequency [1/min]	2640
Change of frequency C	100%
Efficiency [%]	18%
Power consumption [kW]	2.38
0	
0	
Flow [m ³ /h]	3.66
Head required [m]	7
Frequency [1/min]	2640
Change of frequency C	100%
Efficiency [%]	16%
Power consumption [kW]	2.34
0	
0	
Flow [m ³ /h]	3.66
Head required [m]	7
Frequency [1/min]	2640
Change of frequency C	100%
Efficiency [%]	16%
Power consumption [kW]	2.34

Grundfos HYDRO MULTI-E 4

Flow [m ³ /h]	3.21
Head required [m]	0
Frequency [1/min]	3000
Change of frequency C	100%
Efficiency [%]	27%
Power consumption [kW]	1.21
0	
0	
Flow [m ³ /h]	2.87
Head required [m]	7
Frequency [1/min]	3000
Change of frequency C	100%
Efficiency [%]	33%
Power consumption [kW]	1.13
0	
0	
Flow [m ³ /h]	2.87
Head required [m]	7
Frequency [1/min]	3000
Change of frequency C	100%
Efficiency [%]	33%
Power consumption [kW]	1.13

Constant flow system

Factor	
Flow [m ³ /h]	27.4
Head [m]	15
Frequency [1/min]	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption [kW]	4.45
0	
0	
Flow [m ³ /h]	27.4
Head [m]	27
Frequency [1/min]	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption [kW]	4.45
0	
0	
Flow [m ³ /h]	27.4
Head [m]	27
Frequency [1/min]	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption [kW]	4.45

Pump power consumption saving

Factor	
Power consumption with Constant flow system [kW]	4.45
Power consumption with dynamic system [kW]	1.21
Power saving [kW]	3.13
Power saving potential [%]	73%
Power consumption scaling factor [%]	0.27
0	
0	
Power consumption with Constant flow system [kW]	4.45
Power consumption with dynamic system [kW]	1.13
Power saving [kW]	3.22
Power saving potential [%]	73%
Power consumption scaling factor [%]	0.27

Fuel consumption

Factor	
Annual energy demand Constant flow [kWh]	1 387
Annual energy demand dynamic [kWh]	391
Fuel consumption Constant flow [kg]	288.9
Fuel consumption dynamic [kg]	81.1
Annual fuel cost Constant flow system	NOK 5 389
Annual fuel cost dynamic system	NOK 1 478
Annual savings	NOK 3 902
0	
0	
Annual energy demand Constant flow [kWh]	324
Annual energy demand dynamic [kWh]	87
Fuel consumption Constant flow [kg]	65.6
Fuel consumption dynamic [kg]	17.4
Annual fuel cost Constant flow system	NOK 1 181
Annual fuel cost dynamic system	NOK 316
Annual savings	NOK 865
0	
0	
Annual energy demand Constant flow [kWh]	7 536
Annual energy demand dynamic [kWh]	2 018
Fuel consumption Constant flow [kg]	151.6
Fuel consumption dynamic [kg]	41.0
Annual fuel cost Constant flow system	NOK 27 569
Annual fuel cost dynamic system	NOK 7 584
Annual savings	NOK 20 185

Potential savings in emissions

Annual CO ₂ emissions [kg]	4944.93
Annual NO _x emissions [kg]	41.30
Annual CO emissions [kg]	2.20
Annual HC emissions [kg]	1.28
Annual part matter emissions [kg]	0.33

Average daily savings	NOK	385
Total annual savings	NOK	24 852
Total annual fuel saving [kg]		1386.2

This is the potential for savings by switching from a static flow system without throttling to a dynamic flow system, either with frequency controllig or using just throttling depending on the pump curves were fit the the working points or kept at a constant frequency.

A.10 Power Consumption During Warm Conditions

Pump curve polynomial

$$H(Q) = a + b \cdot Q + c \cdot Q^2$$

Estimate a curve for the pump at a constant frequency using curve fitting software. With Q related to H2O and H in m.

a	10.1
b	-0.004
c	-0.0002

Efficiency polynomial

$$\eta(Q) = d + e \cdot Q + f \cdot Q^2$$



d	0.000
e	0.000
f	0.000

Modes

Mode	Frequency [Hz]	Flow [m³/s]	Head [m]	Efficiency [%]
1	1500	0.0	10.1	0.000
2	1500	0.1	9.996	0.000
3	1500	0.2	9.892	0.000
4	1500	0.3	9.788	0.000
5	1500	0.4	9.684	0.000
6	1500	0.5	9.580	0.000
7	1500	0.6	9.476	0.000
8	1500	0.7	9.372	0.000
9	1500	0.8	9.268	0.000
10	1500	0.9	9.164	0.000
11	1500	1.0	9.060	0.000
12	1500	1.1	8.956	0.000
13	1500	1.2	8.852	0.000
14	1500	1.3	8.748	0.000
15	1500	1.4	8.644	0.000
16	1500	1.5	8.540	0.000
17	1500	1.6	8.436	0.000
18	1500	1.7	8.332	0.000
19	1500	1.8	8.228	0.000
20	1500	1.9	8.124	0.000
21	1500	2.0	8.020	0.000
22	1500	2.1	7.916	0.000
23	1500	2.2	7.812	0.000
24	1500	2.3	7.708	0.000
25	1500	2.4	7.604	0.000
26	1500	2.5	7.500	0.000
27	1500	2.6	7.396	0.000
28	1500	2.7	7.292	0.000
29	1500	2.8	7.188	0.000
30	1500	2.9	7.084	0.000
31	1500	3.0	6.980	0.000
32	1500	3.1	6.876	0.000
33	1500	3.2	6.772	0.000
34	1500	3.3	6.668	0.000
35	1500	3.4	6.564	0.000
36	1500	3.5	6.460	0.000
37	1500	3.6	6.356	0.000
38	1500	3.7	6.252	0.000
39	1500	3.8	6.148	0.000
40	1500	3.9	6.044	0.000
41	1500	4.0	5.940	0.000
42	1500	4.1	5.836	0.000
43	1500	4.2	5.732	0.000
44	1500	4.3	5.628	0.000
45	1500	4.4	5.524	0.000
46	1500	4.5	5.420	0.000
47	1500	4.6	5.316	0.000
48	1500	4.7	5.212	0.000
49	1500	4.8	5.108	0.000
50	1500	4.9	5.004	0.000
51	1500	5.0	4.900	0.000
52	1500	5.1	4.796	0.000
53	1500	5.2	4.692	0.000
54	1500	5.3	4.588	0.000
55	1500	5.4	4.484	0.000
56	1500	5.5	4.380	0.000
57	1500	5.6	4.276	0.000
58	1500	5.7	4.172	0.000
59	1500	5.8	4.068	0.000
60	1500	5.9	3.964	0.000
61	1500	6.0	3.860	0.000
62	1500	6.1	3.756	0.000
63	1500	6.2	3.652	0.000
64	1500	6.3	3.548	0.000
65	1500	6.4	3.444	0.000
66	1500	6.5	3.340	0.000
67	1500	6.6	3.236	0.000
68	1500	6.7	3.132	0.000
69	1500	6.8	3.028	0.000
70	1500	6.9	2.924	0.000
71	1500	7.0	2.820	0.000
72	1500	7.1	2.716	0.000
73	1500	7.2	2.612	0.000
74	1500	7.3	2.508	0.000
75	1500	7.4	2.404	0.000
76	1500	7.5	2.300	0.000
77	1500	7.6	2.196	0.000
78	1500	7.7	2.092	0.000
79	1500	7.8	1.988	0.000
80	1500	7.9	1.884	0.000
81	1500	8.0	1.780	0.000
82	1500	8.1	1.676	0.000
83	1500	8.2	1.572	0.000
84	1500	8.3	1.468	0.000
85	1500	8.4	1.364	0.000
86	1500	8.5	1.260	0.000
87	1500	8.6	1.156	0.000
88	1500	8.7	1.052	0.000
89	1500	8.8	0.948	0.000
90	1500	8.9	0.844	0.000
91	1500	9.0	0.740	0.000
92	1500	9.1	0.636	0.000
93	1500	9.2	0.532	0.000
94	1500	9.3	0.428	0.000
95	1500	9.4	0.324	0.000
96	1500	9.5	0.220	0.000
97	1500	9.6	0.116	0.000
98	1500	9.7	0.012	0.000
99	1500	9.8	-0.088	0.000
100	1500	9.9	-0.188	0.000
101	1500	10.0	-0.288	0.000

Fit curves to working points

Reset frequency



Pump curve polynomial

$$H(Q) = a + b \cdot Q + c \cdot Q^2$$

Estimate a curve for the pump at a constant frequency using curve fitting software. With Q related to H2O and H in m.

a	10.1
b	-0.004
c	-0.0002

Efficiency polynomial

$$\eta(Q) = d + e \cdot Q + f \cdot Q^2$$



d	0.000
e	0.000
f	0.000

Modes

Mode	Frequency [Hz]	Flow [m³/s]	Head [m]	Efficiency [%]
1	1500	0.0	10.1	0.000
2	1500	0.1	9.996	0.000
3	1500	0.2	9.892	0.000
4	1500	0.3	9.788	0.000
5	1500	0.4	9.684	0.000
6	1500	0.5	9.580	0.000
7	1500	0.6	9.476	0.000
8	1500	0.7	9.372	0.000
9	1500	0.8	9.268	0.000
10	1500	0.9	9.164	0.000
11	1500	1.0	9.060	0.000
12	1500	1.1	8.956	0.000
13	1500	1.2	8.852	0.000
14	1500	1.3	8.748	0.000
15	1500	1.4	8.644	0.000
16	1500	1.5	8.540	0.000
17	1500	1.6	8.436	0.000
18	1500	1.7	8.332	0.000
19	1500	1.8	8.228	0.000
20	1500	1.9	8.124	0.000
21	1500	2.0	8.020	0.000
22	1500	2.1	7.916	0.000
23	1500	2.2	7.812	0.000
24	1500	2.3	7.708	0.000
25	1500	2.4	7.604	0.000
26	1500	2.5	7.500	0.000
27	1500	2.6	7.396	0.000
28	1500	2.7	7.292	0.000
29	1500	2.8	7.188	0.000
30	1500	2.9	7.084	0.000
31	1500	3.0	6.980	0.000
32	1500	3.1	6.876	0.000
33	1500	3.2	6.772	0.000
34	1500	3.3	6.668	0.000
35	1500	3.4	6.564	0.000
36	1500	3.5	6.460	0.000
37	1500	3.6	6.356	0.000
38	1500	3.7	6.252	0.000
39	1500	3.8	6.148	0.000
40	1500	3.9	6.044	0.000
41	1500	4.0	5.940	0.000
42	1500	4.1	5.836	0.000
43	1500	4.2	5.732	0.000
44	1500	4.3	5.628	0.000
45	1500	4.4	5.524	0.000
46	1500	4.5	5.420	0.000
47	1500	4.6	5.316	0.000
48	1500	4.7	5.212	0.000
49	1500	4.8	5.108	0.000
50	1500	4.9	5.004	0.000
51	1500	5.0	4.900	0.000
52	1500	5.1	4.796	0.000
53	1500	5.2	4.692	0.000
54	1500	5.3	4.588	0.000
55	1500	5.4	4.484	0.000
56	1500	5.5	4.380	0.000
57	1500	5.6	4.276	0.000
58	1500	5.7	4.172	0.000
59	1500	5.8	4.068	0.000
60	1500	5.9	3.964	0.000
61	1500	6.0	3.860	0.000
62	1500	6.1	3.756	0.000
63	1500	6.2	3.652	0.000
64	1500	6.3	3.548	0.000
65	1500	6.4	3.444	0.000
66	1500	6.5	3.340	0.000
67	1500	6.6	3.236	0.000
68	1500	6.7	3.132	0.000
69	1500	6.8	3.028	0.000
70	1500	6.9	2.924	0.000
71	1500	7.0	2.820	0.000
72	1500	7.1	2.716	0.000
73	1500	7.2	2.612	0.000
74	1500	7.3	2.508	0.000
75	1500	7.4	2.404	0.000
76	1500	7.5	2.300	0.000
77	1500	7.6	2.196	0.000
78	1500	7.7	2.092	0.000
79	1500	7.8	1.988	0.000
80	1500	7.9	1.884	0.000
81	1500	8.0	1.780	0.000
82	1500	8.1	1.676	0.000
83	1500	8.2	1.572	0.000
84	1500	8.3	1.468	0.000
85	1500	8.4	1.364	0.000
86	1500	8.5	1.260	0.000
87	1500	8.6	1.156	0.000
88	1500	8.7	1.052	0.000
89	1500	8.8	0.948	0.000
90	1500	8.9	0.844	0.000
91	1500	9.0	0.740	0.000
92	1500	9.1	0.636	0.000
93	1500	9.2	0.532	0.000
94	1500	9.3	0.428	0.000
95	1500	9.4	0.324	0.000
96	1500	9.5	0.220	0.000
97	1500	9.6	0.116	0.000
98	1500	9.7	0.012	0.000
99	1500	9.8	-0.088	0.000
100	1500	9.9	-0.188	0.000
101	1500	10.0	-0.288	0.000

Fit curves to working points

Reset frequency



Pump curve polynomial

$$H(Q) = a + b \cdot Q + c \cdot Q^2$$

Estimate a curve for the pump at a constant frequency using curve fitting software. With Q related to H2O and H in m.

a	10.1
b	-0.004
c	-0.0002

Efficiency polynomial

$$\eta(Q) = d + e \cdot Q + f \cdot Q^2$$

d	0.000
e	0.000
f	0.000

Modes

Mode	Frequency [Hz]	Flow [m³/s]	Head [m]	Efficiency [%]
1	1500	0.0	10.1	0.000
2	1500	0.1	9.996	0.

Summary of the pump calculations warm weather

Dynamic system

NB 32 125/01 Parallel

Parameter	Value
Flow [m ³ /h]	4.23
Head required [m]	0
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	11%
Power consumption [Kw]	3.92
0	0
Transit	0
Flow [m ³ /h]	4.23
Head required [m]	0
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	11%
Power consumption [Kw]	3.92
0	0
Dynamic positioning	0
Flow [m ³ /h]	4.23
Head required [m]	0
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	11%
Power consumption [Kw]	3.92

NB 32 125/01

Parameter	Value
Flow [m ³ /h]	2.21
Head required [m]	0
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	12%
Power consumption [Kw]	2.01
0	0
Transit	0
Flow [m ³ /h]	2.21
Head required [m]	0
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	12%
Power consumption [Kw]	2.01
0	0
Dynamic positioning	0
Flow [m ³ /h]	2.21
Head required [m]	0
Frequency [1/min]	3420
Change of frequency C	100%
Efficiency [%]	12%
Power consumption [Kw]	2.01

NB 32-160/02

Parameter	Value
Flow [m ³ /h]	2.21
Head required [m]	0
Frequency [1/min]	2640
Change of frequency C	100%
Efficiency [%]	10%
Power consumption [Kw]	2.27
0	0
Transit	0
Flow [m ³ /h]	2.21
Head required [m]	0
Frequency [1/min]	2640
Change of frequency C	100%
Efficiency [%]	11%
Power consumption [Kw]	2.27
0	0
Dynamic positioning	0
Flow [m ³ /h]	2.21
Head required [m]	0
Frequency [1/min]	2640
Change of frequency C	100%
Efficiency [%]	11%
Power consumption [Kw]	2.27

Grundfos HYDRO MULTI-E 4

Parameter	Value
Flow [m ³ /h]	1.44
Head required [m]	0
Frequency [1/min]	3000
Change of frequency C	100%
Efficiency [%]	19%
Power consumption [Kw]	1.08
0	0
Transit	0
Flow [m ³ /h]	1.50
Head required [m]	0
Frequency [1/min]	3000
Change of frequency C	100%
Efficiency [%]	19%
Power consumption [Kw]	1.08
0	0
Dynamic positioning	0
Flow [m ³ /h]	1.50
Head required [m]	0
Frequency [1/min]	3000
Change of frequency C	100%
Efficiency [%]	19%
Power consumption [Kw]	1.08

Constant flow system

Parameter	Value
Flow [m ³ /h]	27.4
Head [m]	11
Frequency [1/min]	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption [Kw]	4.40
0	0
Transit	0
Flow [m ³ /h]	27.4
Head [m]	27
Frequency [1/min]	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption [Kw]	4.40
0	0
Dynamic positioning	0
Flow [m ³ /h]	27.4
Head [m]	27
Frequency [1/min]	3513
Change of frequency C	98%
Efficiency [%]	68%
Power consumption [Kw]	4.40

Pump power consumption saving

Parameter	Value
Power consumption with Constant flow system [Kw]	4.40
Power consumption with dynamic system [Kw]	1.08
Power saving [Kw]	3.32
Power saving potential [%]	75%
Power consumption scaling factor [1]	0.24
0	0
Power consumption with Constant flow system [Kw]	4.40
Power consumption with dynamic system [Kw]	1.08
Power saving [Kw]	3.32
Power saving potential [%]	75%
Power consumption scaling factor [1]	0.24

Fuel consumption

Parameter	Value
Annual energy demand Constant flow [kWh]	2.254
Annual energy demand dynamic [kWh]	552
Fuel consumption Constant flow [kg]	485.7
Fuel consumption dynamic [kg]	118.9
Annual fuel cost Constant flow system	NOK 8.742
Annual fuel cost dynamic system	NOK 2.140
Annual savings	NOK 6.602
0	0
Annual energy demand Constant flow [kWh]	526
Annual energy demand dynamic [kWh]	129
Fuel consumption Constant flow [kg]	106.6
Fuel consumption dynamic [kg]	26.1
Annual fuel cost Constant flow system	NOK 1.930
Annual fuel cost dynamic system	NOK 471
Annual savings	NOK 1.459
0	0
Annual energy demand Constant flow [kWh]	12.245
Annual energy demand dynamic [kWh]	3.002
Fuel consumption Constant flow [kg]	2488.9
Fuel consumption dynamic [kg]	610.1
Annual fuel cost Constant flow system	NOK 44.709
Annual fuel cost dynamic system	NOK 10.982
Annual savings	NOK 33.817

Potential savings in emissions

Parameter	Value
Annual CO2 emissions [kg]	6787.25
Annual NOx emissions [kg]	68.97
Annual CO emissions [kg]	3.70
Annual HC emissions [kg]	2.14
Annual particulate emissions [kg]	0.56

Average daily savings	NOK	294
Total annual savings	NOK	41.868
Total annual fuel saving [kg]		2326.0

This is the potential for savings by switching from a static flow system without throttling to a dynamic flow system, either with frequency control or using just throttling depending on the pump curves were fit the the working points or kept at a constant frequency.

A.11 Power Consumption Summary

Summary of potential annual savings from all weather conditions	Cold conditions	Middle conditions	Warm conditions	Total annual savings	
Total annual savings	NOK 35 799	NOK 24 952	NOK 41 868	NOK 102 619	
Total annual fuel saving [kg]	1989	1386	2326	5 701	
Emissions					
Annual Co2 emissions [kg]	5803	4045	6787	16636	
Annual Nox emissions [kg]	59.0	41.1	69.0	169.0	
Annual Co emissions [kg]	3.2	2.2	3.7	9.1	
Annual HC emissions [kg]	1.8	1.3	2.1	5.2	
Annual part matter emissions [kg]	0.5	0.3	0.6	1.4	
Power scaling factor					
Harbor	0.33	0.27	0.24	0.28	
Potential power saving [%]	0.67	0.73	0.76	72%	
Distrobution throughout year	5.6%	3.6%	5.9%	15.0%	
Transit	0.32	0.27	0.25	0.28	
Potential power saving [%]	68%	73%	75%	72%	
Distrobution throughout year	1%	1%	1%	3.5%	
Dynamic positioning	0.32	0.27	0.25	0.28	
Potential power saving [%]	68%	73%	75%	72%	
Distrobution throughout year [%]	30%	20%	32%	82%	
				Total Power saving factor	0.28
Yearly distrobution check:		100%	Total power saving [%]	72%	

A.12 Power Consumption During Worst Case Scenario

Summary of the pump calculations worst case

Dynamic system

NB 32 125/01 Paralel	
Flow [m ³ /h]	36.20
Head required [m]	29
Frequency [1/min]	1420
Change of Frequency C	100%
Efficiency [%]	59%
Power consumption [kW]	0.00
Dynamic positioning	0
Flow [m ³ /h]	36.20
Head required [m]	29
Frequency [1/min]	1420
Change of Frequency C	100%
Efficiency [%]	59%
Power consumption [kW]	0.00

NB 32 125/01	
Flow [m ³ /h]	36.20
Head required [m]	29
Frequency [1/min]	1420
Change of Frequency C	100%
Efficiency [%]	59%
Power consumption [kW]	0.00
Dynamic positioning	0
Flow [m ³ /h]	36.20
Head required [m]	29
Frequency [1/min]	1420
Change of Frequency C	100%
Efficiency [%]	59%
Power consumption [kW]	0.00

NB 32-160/02	
Flow [m ³ /h]	36.20
Head required [m]	29
Frequency [1/min]	2640
Change of Frequency C	100%
Efficiency [%]	68%
Power consumption [kW]	0.00
Dynamic positioning	0
Flow [m ³ /h]	36.20
Head required [m]	29
Frequency [1/min]	2640
Change of Frequency C	100%
Efficiency [%]	68%
Power consumption [kW]	0.00

Grundfos HYDRO MULTI-E 4	
Flow [m ³ /h]	36.20
Head required [m]	29
Frequency [1/min]	3000
Change of Frequency C	100%
Efficiency [%]	52%
Power consumption [kW]	1.68
Dynamic positioning	0
Flow [m ³ /h]	36.20
Head required [m]	29
Frequency [1/min]	3000
Change of Frequency C	100%
Efficiency [%]	52%
Power consumption [kW]	1.68

Constant flow system	
Flow [m ³ /h]	36.20
Head [m]	29
Frequency [1/min]	1511
Change of Frequency C	98%
Efficiency [%]	68%
Power consumption [kW]	4.73
Dynamic positioning	0
Flow [m ³ /h]	36.20
Head [m]	29
Frequency [1/min]	1511
Change of Frequency C	98%
Efficiency [%]	68%
Power consumption [kW]	4.73

Pump power consumption saving	
Power consumption with static system [kW]	4.73
Power consumption with dynamic system [kW]	0.00
Power saving [kW]	-0.95
Power saving potential [%]	-20%
Power consumption scaling factor [%]	1.20
Power consumption with static system [kW]	4.73
Power consumption with dynamic system [kW]	0.00
Power saving [kW]	-0.95
Power saving potential [%]	-20%
Power consumption scaling factor [%]	1.20
Dynamic positioning	0
Power consumption with static system [kW]	4.73
Power consumption with dynamic system [kW]	0.00
Power saving [kW]	-0.95
Power saving potential [%]	-20%
Power consumption scaling factor [%]	1.20

Fuel consumption	
Annual energy demand static [kWh]	2 300
Annual energy demand dynamic [kWh]	2 763
Fuel consumption static [kg]	495.8
Fuel consumption dynamic [kg]	595.2
Annual fuel cost static system [NOK]	8 924
Annual fuel cost dynamic system [NOK]	10 711
Annual savings [NOK]	(1 789)
Annual energy demand static [kWh]	532
Annual energy demand dynamic [kWh]	644
Fuel consumption static [kg]	108.0
Fuel consumption dynamic [kg]	130.7
Annual fuel cost static system [NOK]	1 953
Annual fuel cost dynamic system [NOK]	2 352
Annual savings [NOK]	(399)
Annual energy demand static [kWh]	12 490
Annual energy demand dynamic [kWh]	15 000
Fuel consumption static [kg]	2540.1
Fuel consumption dynamic [kg]	3048.8
Annual fuel cost static system [NOK]	35 728
Annual fuel cost dynamic system [NOK]	54 897
Annual savings [NOK]	(19 169)

Potential savings in emissions	
Annual CO ₂ emissions [kg]	-1840.00
Annual NO _x emissions [kg]	-18.70
Annual CO emissions [kg]	-1.00
Annual HC emissions [kg]	-4.58
Annual particulate emissions [kg]	-0.13

Average daily savings	NOK	(81)
Total annual savings	NOK	(13 351)
Total annual fuel saving [kg]		(891)

This is the potential for savings by switching from a static flow system without throttling to a dynamic flow system, either with frequency controll or using just throttling depending on the pump curves were fit the the working points or kept at a constant frequency.

A.13 Weather Data at Grimsby

In [22]:

```
#Beregning av i harbor 2020-2021
```

```
import pandas as pd  
import numpy as np  
import csv  
import matplotlib.pyplot as plt
```

In [23]:

```
spreadsheet = pd.read_csv(r"\Users\sindr\Downloads\grimsby 2020-03-25 to 2021-03-24.csv")
```

In [26]:

```
file_name = r'C:\Users\sindr\Downloads\grimsby 2020-03-25 to 2021-03-24.csv'

temp_values = []

with open(file_name, 'r') as csv_file:
    csv_reader = csv.DictReader(csv_file)
    for row in csv_reader:
        temp_values.append(float(row['temp']))

total_humidity = 0
num_rows = 0

with open(file_name, 'r') as csv_file:
    csv_reader = csv.DictReader(csv_file)
    for row in csv_reader:
        # Adds the humidities to a list to find the average
        total_humidity += float(row['humidity'])

        # Row count
        num_rows += 1

average_humidity = total_humidity / num_rows

# Converts the column to a np.array
temp_array = np.array(temp_values)

# Upper and Lower quartile and the average
lower_quartile = np.percentile(temp_array, 25)
upper_quartile = np.percentile(temp_array, 75)
average = np.percentile(temp_array, 50)

# Printing the results
print(f'Lower quartile (Q1): {lower_quartile}')
print(f'Upper quartile (Q3): {upper_quartile}')
print(f'Average temperature {average}')
print(f'The average humidity is: {average_humidity}')

count_above_1225 = 0
count_below_885 = 0
num_rows = 0

with open(file_name, 'r') as csv_file:
    csv_reader = csv.DictReader(csv_file)

    for row in csv_reader:
        # Check if the 'temp' value is above 12.25
        if float(row['temp']) > 12.25:
            # Counting the number of days
            count_above_1225 += 1
        # Check if the 'temp' value is above 12.25
        if float(row['temp']) < 8.85:
            # Counting the number of days
            count_below_885 += 1
```

```
# Counting the total number of rows
num_rows += 1


count_middle=num_rows-count_above_1225-count_below_885

# Printing the results
print(f'The number of warm days is: {count_above_1225}')
print(f'The number of cold days is: {count_below_885}')
print(f'The number of days in with middle temeprature: {count_middle}')

temp_column = spreadsheet['temp']

#Creating a plot of the temperatures
plt.figure(figsize=(10, 6)) #Size of figure
plt.hist(temp_column, bins=20, color='skyblue', edgecolor='black')
plt.xlabel('Temperature (°C)')
plt.ylabel('Number of days')
plt.title('Distribution of temepratures Grimsby')
plt.show() # Display the chart

Lower quartile (Q1): 6.4
Upper quartile (Q3): 14.4
Average temeprature 10.0
The average humidity is: 81.30082191780815
The number of warm days is: 135
The number of cold days is: 148
The number of days in with middle temeprature: 82
```



In []:

A.14 Weather Data at Hornsea

In [9]:

```
#Weather data at the North Sea outside of Grimsby 2020-2021
```

```
import pandas as pd  
import numpy as np  
import csv  
import matplotlib.pyplot as plt
```

In [10]:

```
spreadsheet = pd.read_csv(r"\Users\sindr\Downloads\53.928223 0.571587 2020-03-25 to 2021")
```

In []:

In [11]:

```
file_name = r'C:\Users\sindr\Downloads\53.928223 0.571587 2020-03-25 to 2021-03-24.csv'

temp_values = []

with open(file_name, 'r') as csv_file:
    csv_reader = csv.DictReader(csv_file)

    for row in csv_reader:
        # Adds the values in temp to a list
        temp_values.append(float(row['temp']))

total_humidity = 0
num_rows = 0

with open(file_name, 'r') as csv_file:
    csv_reader = csv.DictReader(csv_file)

    # Calculates the average humidity
    for row in csv_reader:
        total_humidity += float(row['humidity'])

    # Total number of elements
    num_rows += 1

# Calculate the average humidity
average_humidity = total_humidity / num_rows

# Convert the temp column to a numpy array
temp_array = np.array(temp_values)

# Calculating the upper and lower quartile
lower_quartile = np.percentile(temp_array, 25)
upper_quartile = np.percentile(temp_array, 75)
average = np.percentile(temp_array, 50)

# Printing the results
print(f'Lower quartile (Q1): {lower_quartile}')
print(f'Upper quartile (Q3): {upper_quartile}')
print(f'Average temperature {average}')
print(f'The average humidity is: {average_humidity}')

count_above_1225 = 0
count_below_885 = 0
num_rows = 0

with open(file_name, 'r') as csv_file:
    csv_reader = csv.DictReader(csv_file)

    for row in csv_reader:
        # Check if the 'temp' value is above 12.25
        if float(row['temp']) > 12.25:
            # Counts the number of elements
            count_above_1225 += 1
        # Check if the 'temp' value is below 8.85
        if float(row['temp']) < 8.85:
```

```
# Counts the number of elements
count_below_885 += 1

# Total number of elements
num_rows += 1


count_middle=num_rows-count_above_1225-count_below_885

# Print the result
print(f'The number of warm days is: {count_above_1225}')
print(f'The number of cold days is: {count_below_885}')
print(f'The number of days in with middle temeprature: {count_middle}')

temp_column = spreadsheet['temp']

#Creating a plot of the temperatures
plt.figure(figsize=(10, 6)) #Size of figure
plt.hist(temp_column, bins=20, color='skyblue', edgecolor='black')
plt.xlabel('Temperature (°C)')
plt.ylabel('Number of days')
plt.title('Distribution of temperatures at sea')
plt.show() # Display the chart

Lower quartile (Q1): 7.2
Upper quartile (Q3): 14.0
Average temeprature 10.5
The average humidity is: 80.73863013698632
The number of warm days is: 144
The number of cold days is: 136
The number of days in with middle temeprature: 85
```



In []:

A.15 Data Sheet Grundfos pump

Qty. Description

1 HYDRO MULTI-E 4 CRIE 10-3



Note! Product picture may differ from actual product

Product No.: [98486782](#)

GRUNDFOS Hydro Multi-E booster sets are designed for the transfer and pressure boosting of clean water in waterworks, blocks of flats, hotels, industry, hospitals, schools, etc.

GRUNDFOS Hydro Multi-E booster set consists of 2 to 4 CRIE pumps coupled in parallel and mounted on a common base frame provided with all the necessary fittings.

Hydro Multi-E is mounted on a common base frame made of stainless steel (DIN W.-Nr. 1.4301).

On the suction side are fitted a suction manifold (DIN W.-Nr.

1.4401 or DIN W.-Nr.

1.4571), a pressure switch mounted on a drainable valve and an isolating valve.

On the discharge side of the pumps are fitted a non-return valve, an isolating valve, a pressure gauge, two pressure transmitters mounted on a drainable valve a diaphragm tank and a stainless steel discharge manifold (DIN W.-Nr.

1.4401 or DIN W.-Nr.

1.4571).

The Hydro Multi-E is fitted with an on/off-switch for the supply voltage.

The Hydro Multi-E is designed for maintaining a constant pressure regardless of flow changes and fluctuation.

The internal PI-controller regulates the number of running pumps and the speed of the pumps according to the required flow.

The system can be operated directly on the panel of any of the pumps or via Grundfos GO (available as accessory)

Besides the system features:

2 Digital outputs

2 Digital inputs (one used for dry run protection)

2 Analogue inputs (one used for discharge pressure sensor)

Multi-Master functionality

2 Limit functions

Set-point influence function

Pipe filling function

High efficient PM motors

Available communication protocols:

•LON

•Profibus

•Modbus

•SMS/GSM/GPRS

•GRM

•BACnet

•BACnet IP

•Modbus TCP

•PROFINET

Qty. Description

1 When delivered, the GRUNDFOS Hydro Multi-E booster set is factory tested and ready for operation.

Liquid:

Pumped liquid: Vann
Liquid temperature range: 5 .. 60 °C
Selected liquid temperature: 20 °C
Density: 998.2 kg/m³
Kinematic viscosity: 1 mm²/s

Technical:

Max flow: 62.8 m³/h

Materials:

Pump housing: Stainless steel

Installation:

Maximum operating pressure: 10 bar
Maximum permissible inlet pressure: PN 10 bar
Flange standard: DIN2642
Manifold inlet: DN 80
Manifold outlet: DN 80

Electrical data:

IE Efficiency class: IE5
Power (P2) main pump: 2.2 kW
Mains frequency: 50 / 60 Hz
Rated voltage: 3 x 380-415 V
Rated current: 16.1 A
Start. method: electronically
Enclosure class (IEC 34-5): IP54


Tank:

Volume of pressure tank: 8 l
Diaphragm tank: Yes


Others:

Net weight: 268 kg
Gross weight: 284 kg
Shipping volume: 0.8 m³
Language: GB
Country of origin: DE
Custom tariff no.: 84137075

98486782 HYDRO MULTI-E 4 CRIE 10-3 50 Hz



Losses in fittings and valves not included
 Pumped liquid = Vann
 Liquid temperature during operation = 20 °C
 Density = 998.2 kg/m³








Company name: Grundfos
Created by:
Phone:

Date: 14/04/2023

98486782 HYDRO MULTI-E 4 CRIE 10-3 50 Hz



98486782 HYDRO MULTI-E 4 CRIE 10-3 50 Hz



Note! All units are in [mm] unless others are stated.
Disclaimer: This simplified dimensional drawing does not show all details.

A.16 Data Sheet Allweiler pump

Charact. curves acc. **DIN EN ISO 9906:2013.03 3B**
 Minmum capacity at continous operation: $Q_{min} = 0.1 \cdot Q_{opt}$
 Attention! At temperature $t < -10^{\circ}C$ please note materials!

Item:
Pos.No:

Created by


Date
2023-02-23

Power data referred to:

Water, pure

	Q	H	P	Vis	Temp	Density	rated Torque
1)	18,00 m³/h	30,00 m	2,41 kW	0,3 mm²/s	85,0 °C	0,97 kg/dm³	6,7 Nm
2)							

Speed
3420 1/min



Charact. curves acc. **DIN EN ISO 9906:2013.03 3B**
 Minmum capacity at continous operation: $Q_{min} = 0.1 \cdot Q_{opt}$
 Attention! At temperature $t < -10^{\circ}C$ please note materials!

Item:
Pos.No:

Created by





Date
2023-02-23

Power data referred to:

Water, pure

	Q	H	P	Vis	Temp	Density	rated Torque
1)	18,00 m³/h	30,00 m	2,41 kW	0,3 mm²/s	85,0 °C	0,97 kg/dm³	6,7 Nm
2)							

Speed
3420 1/min



Flow

Charact. curves acc. **DIN EN ISO 9906:2013.03 3B**
 Minimum capacity at continuous operation: $Q_{min} = 0.1 \cdot Q_{opt}$
 Attention! At temperature $t < -10^{\circ}C$ please note materials!

Item:
Pos.No:

Created by





Date
2023-02-23

Power data referred to:

Water, pure

	Q	H	P	Vis	Temp	Density	rated Torque
1)	19,31 m³/h	34,52 m	2,85 kW	0,3 mm²/s	85,0 °C	0,97 kg/dm³	10,3 Nm
2)							

Speed
2640 1/min



Flow

